

# **UNIFIED FACILITIES CRITERIA (UFC)**

## **UNACCOMPANIED ENLISTED PERSONNEL HOUSING (UEPH) COMPLEXES**

### Volume 2: Model Request for Proposals

U.S. ARMY CORPS OF ENGINEERS (Preparing Activity)

NAVAL FACILITIES ENGINEERING COMMAND

AIR FORCE CIVIL ENGINEER SUPPORT AGENCY

**APPROVED FOR PUBLIC RELEASE: DISTRIBUTION UNLIMITED**

**TABLE OF CONTENTS**  
REQUEST FOR PROPOSALS  
**[PROJECT TITLE ]**  
**[PROJECT LOCATION]**

SECTION/ ATTACHMENT NUMBER	DESCRIPTION
00010	SOLICITATION, OFFER AND AWARD (STANDARD FORM 1442) AND PRICING SCHEDULE
00100	INSTRUCTIONS, CONDITIONS AND NOTICES TO BIDDERS/OFFERORS
00110	PROPOSAL SUBMISSION REQUIREMENTS AND INSTRUCTIONS
00120	PROPOSAL EVALUATION AND CONTRACT AWARD
00600	REPRESENTATIONS AND CERTIFICATIONS
00700	CONTRACT CLAUSES
00800	SPECIAL CONTRACT REQUIREMENTS
	<b>STATEMENT OF WORK</b>
	<b>ATTACHMENTS TO THE STATEMENT OF WORK</b>
1	TECHNICAL SPECIFICATIONS
	Section 01012 - Design After Award (Design/Build)
	11\ 11/
2	RESERVED
3	RESERVED
4	RESERVED
5	PROPOSAL DRAWING FORMAT
6	SITE AND LOCALITY MAPS
7	PROJECT AND SAFETY SIGNS
8	GEOTECHNICAL REPORT
9	EXCERPTS FROM THE INSTALLATION DESIGN GUIDE

SECTION/ ATTACHMENT NUMBER	DESCRIPTION
10	FIRE FLOW DATA
11	LIST OF DRAWINGS
12	ASBESTOS AND LEAD PAINT SURVEY RESULTS
13	<u>[Additional Attachments may be included if necessary]</u>

### NOTES

- 
1. See additional tables of contents in each section for paragraph references. See the Technical Specifications table of contents for specification sections included in this solicitation/contract.
  2. Drawings are provided as a separate package.

### NOTES TO USACE ACTIVITY PREPARING SOLICITATION

- 
1. Contracting guidance contained herein should not be used as a substitute for thorough knowledge of the current acquisition regulations. If a conflict arises between this guidance and the acquisition regulations, the acquisition regulations govern.
  2. Local provisions and clauses may be substituted.
  3. General Wage Decisions, although not specifically listed as an attachment to the Statement of Work must be included in the complete solicitation.
  4. \1\ Electronic editable versions of these documents are available from Norfolk District. Point of Contact, Mr. Peter G. Reilly, [Peter.G.Reilly@usace.army.mil](mailto:Peter.G.Reilly@usace.army.mil) /1/

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**SECTION 00010**  
**SOLICITATION, OFFER AND AWARD (STANDARD FORM 1442) AND PRICING SCHEDULE**

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

SECTION 00010 Solicitation Contract Form

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001					

For the complete design and construction of \_\_\_\_\_ Barracks, \_\_\_\_\_ Battalion Headquarters, and \_\_\_\_\_ Company Operations Buildings [USACE Design District to complete number and type of facilities for project being advertised] and supporting facilities at [USACE Design District to indication Installation and location] with a 120 day acceptance period.



ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001AA		1.00	Lump Sum		

All construction work on the \_\_\_\_\_ Barracks Buildings in Item 0001 within the 1524 [five (5) foot] line (includes all work inside of a line drawn at a perpendicular distance of five feet outside of the exterior face of foundation walls).

---

NET AMT

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001AB		1.00	Lump Sum		

Reserved.

---

NET AMT

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001AC		1.00	Lump Sum		

All construction work on the \_\_\_\_\_ Company Operations Buildings in Item 0001 within the 1524 [five (5) foot] line (includes all work inside of a line drawn at a perpendicular distance of five feet outside of the exterior face of foundation walls). [USACE Design District to edit to the type and number of buildings in the particular project.]

---

NET AMT

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001AD		1.00	Lump Sum		

All construction work on the \_\_\_\_\_ Battalion Headquarters Buildings in Item 0001 within the 1524 [five (5) foot] line (includes all work inside of a line drawn at a perpendicular distance of five feet outside of the exterior face of foundation walls). [USACE Design District to edit to the type and number of buildings in the particular project.]

---

NET AMT

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001AE		1.00	Lump Sum		

All construction work outside of the 1524 [five (5) foot] line, excluding Items 0001AA, 0001AB, 0001AC, 0001AD, 0001AE, 0001AG, and 0001AH.

---

NET AMT

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001AF		1.00	Lump Sum		
Design work for all items (construct new facilities, and all other features required by this solicitation)					

---

NET AMT

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001AG		1.00	Lump Sum		
Demolition of existing structures and associated site improvements. [USACE Design District to include this bid item only when demolition is included in the project. If asbestos and lead paint abatement are expected in the demolition activities, Design District shall consider a separate pricing item to capture those costs specifically.]					

---

NET AMT

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001AH		1.00	Lump Sum		
Construction of supplemental facilities complete and as shown on the plans and in the specifications, including all work incidental thereto as required by the statement of work. <u>[USACE Design District shall clearly list and indicate what supplemental facilities/features are included in this item.]</u>					

---

NET AMT

**3. NOTES.**

a. The Army will procure these new facilities through a technical/price competition in accordance with the provisions set forth in this Request for Proposals (RFP). When a contract is awarded, it will be a "Firm Fixed Price Contract."

b. The Congress, in authorizing and funding this contract, has established certain cost limitations for the project. The current authorization for the complete design and construction of this project is [Dollars]. [This dollar figure is provided by HQUSACE by directive when authority to advertise and Code 7 are authorized.] Proposals that exceed this funding limit after exercising any options may be rejected. Submission of desirable alternative features exceeding minimum requirements set forth in the Statement of Work may be considered as long as award can be made within the established funds.

c. Any proposal which is materially unbalanced as to prices for the Base Schedule may be rejected. An unbalanced proposal is one which is based on prices significantly less than the cost for some work and prices which are significantly overstated for other work and can also exist where only overpricing or underpricing exists. A proposal may be rejected if the Contracting Officer determines that the lack of balance poses an unacceptable risk to the Government.

d. Failure to insert prices for each item in the Base Schedule and each item in any Option Schedules may cause the proposal to be rejected.

e. The offeror agrees if he or she is awarded a contract under this RFP, which includes any option items, that the Government reserves the right to reinstate any option item(s) into the contract at any time up to 120 calendar days after notice to proceed, provided that such reinstatement would not alter the original determination of the successful offeror. If an option item is reinstated in the contract, it is also agreed that the reinstated price will be the same as the schedule price.

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**SECTION 00100**  
**INSTRUCTIONS, CONDITIONS AND NOTICES TO BIDDERS/OFFERORS**

**SECTION 00100**  
**Bidding Schedule/Instructions to Bidders**

Note: SPS and titled paragraphs provide example text. FAR and DFAR paragraphs are shown only for reference. All contractual information and requirements must be coordinated and produced through the PDT Contract Specialist. This TI is not meant to serve as contracting authority or direction.

PARAGRAPH	DESCRIPTION
52.204-6	DATA UNIVERSAL NUMBERING SYSTEM (DUNS) NUMBER (JUN 99)
52.215-1	INSTRUCTIONS TO OFFERORS--COMPETITIVE ACQUISITION (NOV 1999)
52.222-23	NOTICE OF REQUIREMENT FOR AFFIRMATIVE ACTION TO ENSURE EQUAL EMPLOYMENT OPPORTUNITY FOR CONSTRUCTION (FEB 1999)
52.225-12	NOTICE OF BUY AMERICAN ACT REQUIREMENT-- CONSTRUCTION MATERIALS (MAY 1997)
52.233-2	SERVICE OF PROTEST (AUG 1996)
52.225-13	NOTICE OF BUY AMERICAN ACT REQUIREMENT-- CONSTRUCTION MATERIALS UNDER TRADE AGREEMENTS ACT AND NORTH AMERICAN FREE TRADE AGREEMENT (MAY 1997) - ALTERNATE I (MAY 1997)
52.236-28	PREPARATION OF PROPOSALS--CONSTRUCTION (OCT 1997)
52.252-1	SOLICITATION PROVISIONS INCORPORATED BY REFERENCE (FEB 1998)
52.252-5	AUTHORIZED DEVIATIONS IN PROVISIONS (APR 1984)

***BASIS OF AWARD***

*Below is sample wording, explaining the "Basis of Award" for a design-build contract. This sample describes the Best Value Trade-Off Approach. This information may also be included in Section 00120, "PROPOSAL EVALUATION CRITERIA."*

*If other than Best Value Trade-Off approach is utilized, the PDT contract specialist shall provide appropriate clauses to be included within the contract. PDT members shall closely coordinate the selection methodology utilized to be sure that all technical, proposal, and evaluation criteria are suitably formulated to suit the selected methodology. Two other possible methods for award are "Lowest Cost Technically Acceptable" or "Best Technical Solution". Design Districts are cautioned from using "Best Technical Solution" methodologies due to the extreme cost impact.*

---

**BASIS OF AWARD :**

XX.1. The Government will award a firm fixed-price contract to that responsible Offeror whose proposal, conforming to the solicitation, is fair and reasonable, and has been determined to be most advantageous to the Government, quality (comprised of technical approach and performance capability factors), price and other factors considered. The rated technical evaluation criteria and price are considered approximately equal. As technical scores and relative advantages and disadvantages become less distinct, differences in price between proposals are of increased importance in determining the most advantageous proposal. Conversely, as differences in price become less distinct, differences in scoring and relative advantages and disadvantages between proposals are of increased importance to the determination.

XX.2. The Government reserves the right to accept other than the lowest priced offer. The right is also reserved to reject any and all offers. The basis of award will be a conforming offer, the price or cost of which may or may not be the lowest. If other than the lowest priced offer is accepted, that offer must be sufficiently more advantageous than the lowest priced offer to justify the payment of additional amounts.

XX.3. Offerors are reminded to include their best technical and price terms in their initial offer and not to automatically assume that they will have an opportunity to participate in discussions or be asked to submit a revised offer. The Government may make award of a conforming proposal without discussions, if deemed to be within the best interests of the Government."

---

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**SECTION 00110**  
**PROPOSAL SUBMISSION REQUIREMENTS AND INSTRUCTIONS**

**SECTION 00110**  
**PROPOSAL SUBMISSION REQUIREMENTS AND INSTRUCTIONS**

**1.00 GENERAL PROPOSAL INFORMATION.**

a. General. Inasmuch as the proposal will describe the capability of the offeror to perform any resultant contract, as well as describe the understanding of the requirement of the Statement of Work, it should be specific and complete in every detail. The proposal should be prepared simply and economically, providing straight-forward, concise delineation of capabilities to perform satisfactorily the contract being sought. The proposal should therefore be practical, legible, clear and coherent.

b. Proposal Submissions and the Two (2) Phase Design-Build Process. This process requires potential contractors to submit their performance and capability information initially for review and consideration by the Government. Following the review, evaluation, and rating of these proposals, the Government will select up to five of the highest rated contractors to receive the technical requirements package and provide a technical and cost proposal for consideration by the Government. For these five (5) selected contractors, their technical and cost proposals will be reviewed by the Government. The technical information contained in this Phase 2 proposal will be review, evaluated, and scored by Government staff in direct response to the evaluation criteria set forth in Section 00120 – PROPOSAL EVALUATION CRITERIA. The final evaluation rating used for comparison, selection, and award will reflect both the rating received in Phase 1 and the evaluation rating received in Phase 2. Cost information will not be rated in either phase but will be evaluated in response to the funding limitations set forth in Section 00010 – PRICE PROPOSAL SCHEDULE. The proposal process for this two (2) phase procurement consists of the following individual pieces:

PHASE 1 PROPOSAL

- Pro Forma Information
- Offeror Relevant Experience (Example Projects)
- Offeror Past Performance Information (Completed Projects Customer Surveys)
- Offeror Project Key Personnel
- Technical Approach Narrative
- Other Information (Any additional information – background provided by the proposer)

PHASE 2 PROPOSAL

- Pro Forma Information
- Completed Price Proposal Information
- Technical Proposal Information
- Project Management Plans and Schedules
- Other Information (Any additional information – background provided by the proposer)

NOTE: FOR ALL THOSE CONTRACTORS WHO COMPETE IN BOTH PHASE 1 AND PHASE 2, THE CONTRACTOR'S PROPOSAL SHALL BE DEFINED AS: ALL INFORMATION WHICH WAS SUBMITTED IN RESPONSE TO THE REQUIREMENTS OF BOTH PHASES OF THE SOLICITATION.

**2.00 PHASE 1 PROPOSAL SUBMISSION INSTRUCTIONS****a. Who May Submit.**

(1) Proposals may be submitted by: firms formally organized as design/build entities, or by design firms and construction contractors that have associated specifically for this project. In the latter case, a single design firm or construction contractor may offer more than one proposal by entering into more than one such association. For the purpose of this solicitation, no distinction is made between formally organized

design/build entities and project-specific design/build associations. Both are referred to as the design/build offeror, (or simply "offeror"), or the design/build contractor, (or simply "Contractor"), after award of a contract.

(2) Any legally organized offeror may submit a proposal, provided that the offeror, or offeror's subcontractor, has on its permanent staff professional architects and engineers registered in the appropriate technical disciplines and provided that the requirements specified in the solicitation are met. All designs must be accomplished under the direct supervision of appropriately licensed professionals.

b. General Requirements.

(1) In order to effectively and equitably evaluate all proposals, the Contracting Officer must receive information sufficiently detailed to allow review and evaluation by the Government.

(2) \1\ Proposals shall be submitted as an "original" and four copies to address indicated. /1/

(3) Proposals must contain a sample project management and quality control plan, background information regarding the offerors' qualifications, example projects, and any required representations and certifications. Specific requirements are described below.

c. Size of Printed Matter Submissions.

(1) Written materials: Size A4 [or 8-1/2" x 11"] format.

(2) The proposals shall contain a detailed table of contents. If more than one binder is used, the complete table of contents shall be included in each. Any materials submitted but not required by this solicitation, (such as company brochures), shall be relegated to appendices.

d. Where to Submit. Offerors shall submit their proposal packages to the [USACE Design District] at the address shown in Block 8 of Standard Form 1442.

e. Submission Deadline. Proposals shall be received by the [USACE Design District] no later than the time and date specified in Block 13 of Standard Form 1442.

f. Phase 1 Proposal Requirements and Submission Format. The proposals sought by this solicitation shall contain the categories of submittal information as follows:

(1) Offeror Relative Experience. Provide examples (at least three) of projects for which the offeror has been responsible. The examples should be as similar as possible to this solicitation in project type and scope. \1\ /1/ Example projects must have been completed not later than three years from the date of the solicitation.

\1\

(a) The list of projects shall include the following information:

- a. Project name and location
- b. Type of facility
- c. Nature of firm's responsibility (design, construction or both)
- d. Identify type of contract (design, design/build, or construction)
- e. Project owner's name and address and project manager's (point of contact) name, telephone number, fax number, and email address (if known)
- f. If a government contract, include the contracting agency and contracting officer's name, telephone number, fax number, and email address (if known)
- g. Date started
- h. Original scheduled completion date
- i. Actual completion date
- j. Overall size of facility (in square feet or square meters)
- k. Construction cost (excluding design costs)
- l. Duration of construction (excluding design time)
- m. Problems encountered and corrective actions taken
- n. Identify which proposed team members and/or firms were involved in the project; their specific roles and responsibilities on the project; and the extent of time they were involved with the project
- o. Relevance of experience to the solicitation project

(b). Joint Ventures: If offeror represents the combining of two or more companies for the purpose of this RFP, the proposal shall indicate whether the firms have experience working together in design/build ventures and for how long and how many projects. In addition, each company of this joint venture shall list their Government contract experiences.

/1/

(2) Offeror Past Performance Information. At the end of this paragraph is included the sample Past Performance Evaluation Questionnaire. The offeror shall identify the three in-progress or completed projects to be used for reference and evaluation purposes. Provide a questionnaire to the Point of Contact for each project listed for completion. When completed, these forms shall be [mailed] [faxed] [e-mailed] to the [USACE Design District] Contract Specialist identified in the sample transmittal letter provided. Failure of a reference verification to arrive at the [USACE Design District] within the identified time period shall adversely affect the overall rating received in Phase 1 of this project. It is the contractor's responsibility to ensure that the reference documentation is provided, the Government WILL NOT make additional requests for past performance information or references. Copies of the evaluation form SHALL NOT be provided to the Offeror from the reference. Projects from which questionnaires are received shall have been completed within three years of the date of the solicitation.

(3) Project Key Personnel. Provide the names, resumes, and levels of responsibility of the principal managers and technical personnel who will be directly responsible for the day-to-day design and construction activities. Include, as a minimum, the project manager; the project architect; the engineers responsible for civil, \1\ fire protection, /1/ electrical, mechanical and structural design; the quality control manager; and the construction manager. Indicate whether each individual has had a significant part in any of the project examples cited. If reassignment of personnel is considered possible, provide the names and resumes of the alternative professionals in each assignment. Project key personnel shall include the key construction subcontractors and the extent of their role with respect to the design phases of this project. Key subcontractors shall include, but are not limited to: Structural Ironworkers, Masonry Works, Electrical, Mechanical, and Site Development subcontractors.

\1\

(a) Information to be provided includes:

Name  
Project assignment  
Name of firm with which associated  
Years experience: with this firm, with other firms  
Education: degrees(s)/year/specialization

Active registration: state and year first registered

Experience and qualifications relevant to proposed project: for each project listed, provide project description, project dates, the individual's project assignment to include specific roles and responsibilities, and its relevance to this solicitation.

(b) Identify the Designer(s)-of-Record for each discipline

(c) Provide letters of commitment for all key personnel on the project team and any proposed alternate personnel. By identifying these personnel, the offeror is making a commitment that, barring unforeseen circumstances, they are the personnel who will be assigned to the project. A letter of commitment from each firm committing specific individuals from the firm may be provided in lieu of separate letters for each individual.

/1/

(4) Technical Approach Narrative. Describe in general terms how the Offeror will approach the design and construction of these facilities. The narrative should include considerations of "Fast Track" construction whereby preliminary site construction activities can begin prior to 100% completion of the design documents. The roles and responsibilities of the various sub-contractors for both design and construction shall also be addressed. Include in the narrative the offeror's proposed processes for handling field problems and assuring Designer of Record involvement throughout the construction period. Technical Approach Narrative shall be limited to a maximum of five (15) typewritten pages.

11\

(a). Provide an organizational chart and supporting narrative describing how the team will be structured. Include all key design and construction personnel and firms on the organizational chart. Discuss the specific roles and responsibilities of each key individual and firm.

(b). Describe the proposed management structure for the team. Discuss how the design and construction process will be managed, to include a discussion on delegation of authority within the team.

(c). Describe interactions within the team and with the Corps of Engineers during design. Discuss how design changes will be handled and the roles that various team members will play when dealing with design changes. Discuss the role of construction team members during design phase.

(d). Describe interactions within the team and with the Corps of Engineers during construction. Discuss how changes will be handled during construction and the roles that various team members will play when dealing with changes during construction. Discuss the role of design team members during construction. Specifically address design team's role in construction Quality Control program; RFI's; shop drawing/submittal review and approval; attending progress meetings; site visits; inspections; contract completion and closeout.

(e). Describe the time control systems to be utilized. Discuss the use of the project schedule for managing the design and construction. Describe internal procedures for handling delays to minimize time growth.

(f). Identify the items of work to be self-performed by offeror and the percentage of the overall contract value that this work represents.

(g). Describe the team's computer-aided drafting and design (CADD) capabilities. Identify the CADD software to be used in the design of this project; if all disciplines are not using the same CADD software, identify the software that each discipline is using. Discuss compatibility with the Government's target CADD. Explain how compatibility will be achieved if the design, or portion of the design, is prepared using a CADD system other than the Government's target CADD system. (Refer to Section 01012 for information on the Government's target CADD system and compatibility requirements.)

/1/

(5) No cost information shall be included in the Phase 1 proposal package.

**SAMPLE TRANSMITTAL LETTER  
AND  
PAST PERFORMANCE EVALUATION QUESTIONNAIRE**

Date: \_\_\_\_\_

To: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

We have listed your firm as a reference for work we have performed for you as listed below. Our firm has submitted a proposal under a project advertised by the U.S. Army Corps of Engineers, [DESIGN] City District. In accordance with Federal Acquisition Regulations (FAR), an evaluation of our firm's past performance will be completed by the Corps of Engineers. Your candid response to the attached questionnaire will assist the evaluation team in this process.

We understand that you have a busy schedule and your participation in this evaluation is greatly appreciated. Please complete the enclosed questionnaire as thoroughly as possible. Space is provided for comments. Understand that while the responses to this questionnaire may be released to the offeror, FAR 15.306 (e)(4) prohibits the release of the names of the persons providing the responses. Complete confidentiality will be maintained. Furthermore, a questionnaire has also been sent to \_\_\_\_\_ of your organization. Only one response from each office is required. If at all possible, we suggest that you individually answer this questionnaire and then coordinate your responses with that of \_\_\_\_\_, to forge a consensus on one overall response from your organization.

Please send your completed questionnaire to the following address:

U.S. Army Engineer District, { \_\_\_\_\_ }  
ATTN:  
ADDRESS

The questionnaires can also be faxed to [Design District Contract Specialist]  
If you have questions regarding the attached questionnaire, or require assistance, please contact [Design District Contract Specialist] at [Phone Number]. Thank you for your assistance.

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

PAST PERFORMANCE EVALUATION QUESTIONNAIRE

Upon completion of this form, please send directly to the U.S. Army Corps of Engineers in the enclosed addressed envelope or fax [or e-mail] to [FAX NUMBER], ATTN: [Contract Specialist]. Do not return this form to our offices. Thank you.

1. Contractor/Name & Address (City and State):

2. Type of Contract: Fixed Price \_\_\_\_\_ Cost Reimbursement \_\_\_\_\_  
Other (Specify) \_\_\_\_\_

3. Title of Project/Contract Number:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

4. Description of Work: (Attach additional pages as necessary)

5. Complexity of Work: High \_\_\_\_\_ Mid \_\_\_\_\_ Routine \_\_\_\_\_

6. Location of Work: \_\_\_\_\_

7. Date of Award: \_\_\_\_\_

8. Status: Active \_\_\_\_\_ (provide percent complete)  
Complete \_\_\_\_\_ (provide completion date)

9. Name, address and telephone number of Contracting Officer's Technical Representative:

**QUALITY OF PRODUCT/SERVICE:**

**10. Evaluate the contractor's performance in complying with contract requirements, quality achieved and overall technical expertise demonstrated.**

<b>Excellent Quality</b>	
<b>Above Average Quality</b>	
<b>Average Quality</b>	
<b>Below Average Quality</b>	
<b>Unsuccessful or Experienced Significant Quality Problems</b>	

**Remarks:**

---



---



---



---

**11. To what extent were the contractor's reports and documentation accurate, complete and submitted in a timely manner?**

<b>Excellent Quality</b>	
<b>Above Average Quality</b>	
<b>Average Quality</b>	
<b>Below Average Quality</b>	
<b>Unsuccessful or Experienced Significant Quality Problems</b>	

**Remarks:** \_\_\_\_\_

---



---



---

**12. To what extent was the contractor able to solve contract performance problems without extensive guidance from government/owner counterparts?**

<b>Excellent</b>	
<b>Above Average</b>	
<b>Average</b>	
<b>Below Average</b>	
<b>Unsuccessful</b>	

**Remarks:**

---

---

---

---

**13. How well did the contractor manage and coordinate subcontractors, suppliers, and the labor force?**

<b>Excellent</b>	
<b>Above Average</b>	
<b>Average</b>	
<b>Below Average</b>	
<b>Unsuccessful</b>	

**Remarks:**

---

---

---

**CUSTOMER SATISFACTION:**

**14. To what extent were the end users satisfied with:**

	<b>Quality?</b>	<b>Cost?</b>	<b>Schedule?</b>
<b>Exceptionally Satisfied</b>			
<b>Highly Satisfied</b>			
<b>Satisfied</b>			
<b>Somewhat Dissatisfied</b>			
<b>Highly Dissatisfied</b>			

**Remarks:**

---



---



---

**15. If given the opportunity, would you work with this contractor again?**

Yes \_\_\_\_\_ No \_\_\_\_\_ Not Sure \_\_\_\_\_

**TIMELINESS OF PERFORMANCE:**

**16. To what extent did the contractor meet the task order schedules?**

<b>Completed Substantially Ahead of Schedule</b>	
<b>Completed on Schedule with no Time Delays</b>	
<b>Completed on Schedule with Minor Delays Under Extenuating Circumstances</b>	
<b>Experienced Significant Delays without Justification</b>	

**Remarks:**

---



---



---

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**OTHER REMARKS:**

**23. Use the space below to provide other information related to the contractor's performance. This may include the contractor's selection and management of subcontractors, flexibility in dealing with contract challenges, their overall concern for the Government's interest (if applicable), project awards received, etc.**

---

---

---

---

---

---

---

---

### 3.00 PHASE 2 PROPOSAL SUBMISSION INSTRUCTIONS

#### a. Who May Submit.

(1) Proposals may be submitted by the offerors who receive written notification from the [USACE Design District] Contracting Officer that their firm has been selected to participate in Phase 2 of this solicitation. No more than five offerors will compete in Phase 2 under typical circumstances. If more than five (5) offerors are involved in Phase 2 of this solicitation, each offeror will be informed of the total number of offerors invited to participate. No offeror identifications will be made without the written consent of all the offerors to release that information.

#### b. General Requirements.

(1) In order to effectively and equitably evaluate all proposals, the Contracting Officer must receive information sufficiently detailed to clearly indicate the materials, equipment, methods, functions, and schedules proposed.

(2) In addition to the design documents addressed below, proposals must contain financial terms, management information, schedules for design and construction, and the representations and certifications. Specific requirements are described below.

(3) Title Page, including the title of the solicitation, solicitation number, [offeror number (Where used) or name], and date of the submittal.

(4) The proposals shall contain a detailed table of contents. If more than one binder is used, the complete table of contents shall be included in each. Any materials submitted but not required by this solicitation, (such as company brochures), shall be relegated to appendices.

(5) Compliance Statement: The offeror is required to certify that all items submitted in the technical proposal comply with the RFP requirements and any differences, deviations or exceptions must be stated and explained. Offerors are required to complete the statement and submit it with their technical proposal. Even if there are no differences, deviations or exceptions, the offeror must submit the Compliance Statement and state that none exist.

#### Statement of Compliance:

This proposer hereby certifies that all items submitted in this proposal and final design documents (after contract award) comply with the solicitation requirements. The criteria specified in Solicitation No. [Insert Solicitation Number] are binding contract criteria and in case of any conflict after award, between [Insert Solicitation Number] and the contractor's proposal, the solicitation criteria shall govern unless there is a written and signed agreement between the contractor and the Government waiving a specific requirement. Should this proposal result in the award of a contract, this statement will be included on each sheet of drawings and on the cover of the specifications.

c. Exceptions to the contractual terms and conditions of the solicitation (e.g., standard company terms and conditions) must not be included in the proposal.

d. The technical proposal shall not include any cost information. The technical and cost proposals shall be submitted as two separate documents.

#### e. Size of Printed Matter Submissions.

(1) Written materials: Size A4 [or 8-1/2" x 11"] format.

(2) Drawing sheets: Use Size A1 [approximately 24" x 36"] for full size drawings which are not intended for reduction to half-size sets. Half size sheets size A2 [approximately 16" x 23"] are also acceptable.

f. Where to Submit. Offerors shall submit their proposal packages to the [USACE Design District] at the address indicated.

g. Submission Deadline. Proposals shall be received by the [USACE Design District] no later than the time and date specified.

h. Proposal Requirements and Submission Format. The proposals sought by this solicitation shall contain the categories of submittal information as follows:

(1) Pro Forma requirements. This information should be submitted in an envelope labeled "Pro Forma Requirements." This category consists of representations and certifications, subcontracting plan, proposal bonds, and completed Standard Form 1442. Provide original and one (1) copy.

(2) Price Proposal Information. Offeror shall complete all portions of the Price Proposal Schedule and furnish in a separate envelope in original and two copies.

\1\

(a). Subcontracting Plan. (Applies to Large Businesses only.) All large businesses shall submit a subcontracting plan with their technical and price/cost proposals. The plan should be prepared in accordance with FAR 52.219-9. Failure to submit an acceptable subcontracting plan may make the offeror ineligible for award of the contract. The submission of the subcontracting plan is in no way advantageous to large businesses over any small business in the evaluation process. See Section 00100, paragraph SMALL BUSINESS SUBCONTRACTING PLAN for additional information and [Design] District subcontracting floors.

(b). Small Disadvantaged Business (SDB) Utilization Plan. (Applies to all Offerors.) Offerors shall submit a SDB Utilization Plan, to include the following information:

- a. Identification of each SDB concern proposed and the work each is to perform.
- b. Targets expressed in dollars and percentages representing each SDB concern's participation of the total contract value.
- c. Total target value of all SDB participation, expressed in dollars and percentages, of the total contract value.

The offeror is put on notice that any targets represented in submitted proposal will be incorporated into and become part of any resulting contract. All proposed SDB concerns must be certified by the Small Business Administration and listed in the online database PRO-Net. SDB concerns may register in PRO-Net at <http://pronet.sba.gov>.

/1/

(3) Design-Technical. This information shall be submitted in separate three-ring binders labeled "Design-Technical Information." This category consists of design documents, drawings, sketches, outline specifications, design analysis, catalog cuts, and other information. Provide four (4) copies of the drawings (size A1); or four (4) copies of half size drawings (size A2) with a minimum of one full size set; 1 set of color boards; and four (4) copies of catalog cuts and other technical data. The drawings shall be bound.

(4) Project Management Plans and Schedules. The offeror shall provide a Management Plan. This is an overall plan showing how the offeror will control the job. The term "management plan" is defined as a plan that includes the following subplans: Subcontracting Plan, Quality Control Plan; integrated Design and Construction Schedule with all "Fast Tracking" areas clearly identified, and Contract Closeout Plan. The offeror shall also submit a rationale explaining how the schedules will be achieved. The schedule for design and construction shall be task oriented, indicating dates by which milestones are to be achieved. The offeror may use a critical path or other method of his/her choice; however, the schedules shall be

graphically represented. A Closeout Plan shall be furnished in a brief structured time scale schedule reflecting the planned activities during the final 90 days of the contract activity. Items to be included are as follows:

CLOSEOUT PLAN

Testing of equipment and systems with schedules and reports.
Equipment instruction and training schedules.
O&M Manuals transfer.
As-built drawings transfer.
Transfer procedures and schedules.
Pre-final inspection procedures and correction of deficiencies.
Warranty data submission and planned implementation.
Cleanup of administrative deficiencies.
Move off site.

(a) Sample Quality Control Plan. The Quality Control Plan is part of the Management Plan. The alliance of the project designer and builder on a project such as this naturally removes one commonly used method of quality control; that is, the usual reliance on the owner or the design consultant for monitoring construction quality. Although the Government will provide an on-site representative during construction, offerors are expected to develop a formal program of monitoring to ensure a high level of construction quality. Offerors shall submit Quality Control Plans that respond to the minimum requirements of Technical Specifications Section 01451 (furnished with this RFP package) entitled "Contractor Quality Control Design/Build." The offeror's program shall include the following characteristics:

CONTRACTOR QUALITY CONTROL REQUIREMENTS

A clear identification of the personnel responsible for quality control and a clear policy establishing their authority. The quality control group shall be separate and apart from (not the same) the people that are doing the construction. This quality control group shall report to the Contractor's management at a level no lower than a vice president of the company.
A specific description of the tasks and functions of the quality control personnel.
A specific policy establishing schedules for the performance of quality control tasks.
A policy for reporting quality control findings to the Contracting Officer.
A procedure whereby the Contracting Officer may resolve disputes that have not received satisfactory responses from the first levels of quality control personnel.
The names of testing laboratories to be used and the procedures for test data reporting.
A plan for material storage and protection.
The plan for review, evaluation, and Offeror Quality Control of the Design Submittals prior to Government receipt.

CONTRACTOR QUALITY CONTROL REQUIREMENTS

The plan for review of submittals and extensions of design. Of particular interest is the role of the Designer of Record in all design and construction progress.
Procedures for involving Key Subcontractors in the design development.
Procedures for successful integration of the Offeror's Quality Control Program with the Government's Quality Assurance Program.

11 /1/

i. Technical Data Requirements for Proposal Submission. The following technical data shall be submitted as part of the formal proposal. Proposals shall include graphic description of the design included in the basic proposal clearly indicated as such. All alternate designs shall be graphically described on separate drawings from the basic proposal. Offerors are advised that the required data listed below will be utilized for technical review and evaluation and used for determination of a "Quality Rating" by a Technical Evaluation Team. Materials indicated in the design/construction criteria, but not indicated in the offeror's specifications, will be assumed to be included and a part of the proposal.

(1) Design drawings. Provide an index of drawings. If required drawings are common for more than one type of building, indicate so on the drawing. Do not provide foundation plans or structural, civil, plumbing, mechanical, or electrical details. The proposal design drawings shall provide the information as indicated in the following tables:

SITE DESIGN

Drawing Type / Scale	Show This Information
Area Site Development Plan 1:1000 [1"=80'] Note <sup>1,2</sup>	Spatial and functional arrangement of all SOW requirements Adjacent land uses and historical or environmental conditions Project Boundaries Existing Contours Proposed contours at 1 m intervals [3]. Drainage and water retention ponds (if utilized) Vehicular and pedestrian circulation
Demolition Plan 1:500 [1"=40']	All site amenities, structures, or features to be removed or retained.
Site Plan 1:500 [1"=40']	Layout for all site requirements.
Typical Landscape Planting Plans 1:250 [1"=20']	Botanical/Common Names of plants used, size, and quantity of trees, shrubs, ground covers, related notes, and planting details.

## SITE DESIGN

Drawing Type / Scale	Show This Information
Utility Plan 1:500 [1"=80']	All site utility requirements. Site lighting. Primary cable routing (new and existing). Pad-mounted transformers and service laterals. Cable television and telephone routing.
Off-Site Electrical Plan 1:5000 [1"=400'] Scale as required (If applicable)	Location of primary supply point of take-off. Existing electrical lines, both overhead and underground, properly identified. New construction tie-in to on-site electrical distribution system.

Note<sup>1</sup>: Drawings shall be dimensioned to show building separations, set back, etc.

Note<sup>2</sup>: Metric Scales are preferred, however, inch pound scales may continue to be used only if they enhance competition.

## BUILDING DESIGN

Drawing Type / Scale	Show This Information
Floor Plans 1:50 [1/4" = 1'-0"] or 1:100 [1/8"=1'-0"] (For each building type)	Overall dimensions. Room description with dimensions and areas. Appliances and built-in features Plumbing fixtures and vanities. Kitchenette layout Door swings. Patio (If Applicable). Service area (Delineate equipment service req. areas) Mechanical/Electrical/Service Spaces Calculated gross and net floor areas.
Floor Plan 1:50 [1/4"=1'-0"] or 1:100 [1/8"=1'-0"] (For each building type)	Life Safety Plan, include the following: <ul style="list-style-type: none"> <li>- Exit Distances</li> <li>- Rated Assemblies</li> <li>- Building Classification</li> <li>- Space Classifications</li> </ul>
Typical Exterior Elevations 1:100 [1/8"=1'-0"] (For each building type)	Show all sides.
Typical Interior Elevations 1:50 [1/4"=1'-0"] (For each building type)	Kitchenettes and Toilet Spaces.

BUILDING DESIGN

Drawing Type / Scale	Show This Information
Transverse and Longitudinal Sections 1:100 [1/8"=1'-0"] (For each building type)	Typical structural system. Building materials. Finishes. Vertical dimensions.
Typical Wall Sections 1:20 [3/4"=1'-0"] (For each building type)	Typical wall, foundation, floor, and roof section. Materials. Cavity wall. Wall fire and STC ratings
Details Scale as required.	Special Features
Finish Schedule	All rooms.

Note: Metric Scales are preferred, however, inch pound scales may continue to be used only if they enhance competition.

BUILDING ENGINEERING

Drawing Type / Scale	Show This Information
Mechanical Floor Plan 1:100 [1/8"=1'-0"]  Note: This information may be shown on the unit electrical plans if it can be shown clearly.	HVAC system layout. Flues. Hot water heater. Equipment Efficiencies Ventilation and Exhaust Systems Other Energy Conservation Features Included in the Proposal  Note: Duct Systems shown single line.
Electrical Floor Plan 1:100 [1/8"=1'-0"]	Lighting fixture locations, properly labeled to show type of fixture. Fixture schedule which indicates general fixture description, number and type of lamps, type of mounting, and any special features. Location of motors or special mechanical equipment. Location of load center panelboards. Location of multi-building service equipment and building service. Multi-building electrical riser diagram. Electrical legend and notes. Room names.

Note: Metric Scales are preferred, however, inch pound scales may continue to be used only if they enhance competition.

(2) Specifications. Provide 11 Outline Specifications 11 indicating the quality of materials, construction, finishes, fixtures, and equipment for the applicable items. Special attention should be given to the identification and specification of energy conservation features included in the proposal, particularly

those which exceed the minimum requirements of the Statement of Work. Submit as part of the Design-Technical Information.

(3) Equipment Schedule. Equipment schedule shall indicate proposed type of equipment, size or capacities, manufacturer, and model number. Furnish manufacturer's catalog data on equipment and fixtures for all features of the facilities, this shall include appliances, electrical equipment and lighting, mechanical heating and cooling equipment, domestic water system equipment, as well as catalog information on the finishes and architectural specialties and exterior finish materials. Originals of manufacturer's catalog should be submitted in lieu of reproducibles to ensure legible data. Submit as part of the Design-Technical Information.

(4) Color Boards. Coordinated interior and exterior color schemes. For proposal evaluation provide one copy of the scheme complete with samples and/or chips of the colors, materials, textures, and finishes.

(5) Life Safety Analysis. The proposal shall include a Life Safety Analysis which clearly demonstrates that the proposal meets or exceeds all requirements of the Statement of Work and reference standards with respect to Life Safety and Fire Protection.

(6) The Offeror's shall include in their proposal a preliminary ranking of the sustainable design considerations included in the proposal. This ranking shall be either a LEED (Leadership in Energy and Environmental Design, by the U.S. Green Building Council) or a SPiRiT (Sustainable Project Rating Tool, by the U.S. Army Corps of Engineers) ranking. The successful proposal shall be required to complete a detailed analysis on the final design which meets or exceeds the preliminary ranking established at proposal level. Proposals must score at least a Bronze SPiRiT Level or a Certified LEED Level. /1/

(7) Evaluation Factors/Proposal Contents Listing. A spreadsheet or table consisting of all the evaluation categories and sub-categories listed in Section 0120 for technical proposal evaluation and specific reference to where in the proposal documents those requirements are addressed or indicated. Submit as part of the Design-Technical Information.

#### 4.0 RESTRICTIONS

a. Incomplete proposals. Failure to submit all the data indicated in this section may be cause for determining a proposal incomplete and, therefore, not considered for technical evaluation in Phase 2, or for subsequent award.

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**SECTION 00120  
PROPOSAL EVALUATION AND CONTRACT AWARD**

**SECTION 00120  
PROPOSAL EVALUATION AND CONTRACT AWARD**

***[Design District must coordinate this section with the preparation and completion of the technical evaluation manual in accordance with the Attachments to Volume 1.]***

**1. TECHNICAL EVALUATION.**

a. PHASE 1 Evaluation Factors:

FACTOR 1-1: OFFEROR PAST PERFORMANCE: This factor is the most important factor in the evaluation of Phase 1 proposals.

FACTOR 1-2: OFFEROR PROJECT KEY PERSONNEL: This factor is slightly less important than Factor 1-1 but represents a significant level of importance in evaluating proposals.

FACTOR 1-3: TECHNICAL APPROACH NARRATIVE: This factor is equal in importance to Factor 1-2.

FACTOR 1-4: OFFEROR RELEVANT EXPERIENCE: This factor is less important than Factor 1-2.

b. PHASE 2 Evaluation Factors:

FACTOR 2-1: BUILDING FUNCTION AND ASTHETICS: This factor is the most important factor in the evaluation of Phase 2 proposals.

FACTOR 2-2: BUILDING SYSTEMS: This factor is slightly less important than Factor 2-1.

FACTOR 2-3: SITE DESIGN: This factor is slightly less important than Factor 2-2.

FACTOR 2-4: SITE ENGINEERING: This factor is significantly less important than Factor 2-3.

FACTOR 2-5: SUSTAINABLE DESIGN CONSIDERATIONS: This factor is approximately equal in importance to Factor 2-4.

FACTOR 2-6: OFFEROR MANAGEMENT PLANS AND SCHEDULES: This factor is equal in weight to Factor 2-5.

c. Overall Proposal Evaluation Consideration

At the completion of both Phase 1 and Phase 2 evaluations the ratings from each of the phases will be tabulated. The Phase 2 evaluation is slightly more important in final selection than the results of the Phase 1 evaluation. At the completion of the evaluation process each proposal that completed both phases of the evaluation process will be assigned a single adjectival rating **1/1** (by consensus decision) **1/1** for comparison and best value analysis as applicable.

**2. EVALUATION PROCESS**

The proposal and evaluation process for this project will take place in two Phases. Each phase will include unique requirements to the potential offerors. The offerors responses to these requirements will be evaluated with respect to the evaluation criteria set forth in this Section.

a. PHASE 1 will concern itself with Offeror's Past Performance, Proposed Project Key Personnel, and Offeror Relevant Experience. All proposals received in response to PHASE 1 will be evaluated and rated. At most, five (5) proposals will move forward into PHASE 2 which will define the technical requirements of the project and request the offeror's technical solutions to the project parameters.

b. PHASE 2: The five (at most) proposals which are determined to present the most advantages to the Government will receive the Phase 2 amendment to the solicitation which will include the Statement of Work, design considerations, and site constraints from the Government. These Offerors will review, evaluate, and propose a creative solution to the design problem presented. Offerors will also include cost information with this technical proposal. Only Offerors who reach PHASE 2 will be provided the opportunity to submit design solutions and cost information.

### 3. BASIS OF AWARD

a. The Government will award a firm fixed-price contract to that responsible Offeror whose complete (Phase 1 and 2 portions) proposal, which was evaluated to be at least conforming to the solicitation, determined to be fair and reasonable, and has been selected as the most advantageous to the Government, quality (comprised of technical approach and performance capability factors), price, and other factors considered. The rated evaluation criteria and price are considered approximately equal. As evaluation ratings and relative advantages and disadvantages become less distinct, differences in price between proposals are of increased importance in determining the most advantageous proposal. Conversely, as differences in price become less distinct, differences in ratings and relative advantages and disadvantages between proposals are of increased importance to the determination.

b. The Government reserves the right to accept other than the lowest priced offer. The right is also reserved to reject any and all offers. The basis of award will be a conforming offer, the price or cost of which may or may not be the lowest. If other than the lowest priced offer is accepted, that offer must be sufficiently more advantageous than the lowest priced offer in order to justify the payment of additional amounts.

c. Offerors are reminded to include their best technical and price terms in their initial offer and not to automatically assume that they will have an opportunity to participate in discussions or be asked to submit a revised offer. The Government may make award of a conforming proposal without discussions, if deemed to be within the best interests of the Government.

### 4. PHASE 1 EVALUATION PROCEDURES AND CRITERIA:

a. All proposal information received as a result of the Phase 1 solicitation shall be reviewed, evaluated, and rated with respect to the following rating scheme:

<b>RATING</b>	<b>EXPLANATION</b>
Unknown Performance Risk	Past performance information provided does not provide sufficient depth and breadth of experience to allow a definitive rating.
Outstanding/Very Low Performance Risk	Based on the offeror's performance record, no doubt exists that the offeror will successfully perform the required effort.
Above Average/Low Performance Risk	Based on the offeror's performance record, little doubt exists that the offeror will successfully perform the required effort.
Satisfactory/Moderate Performance Risk	Based on the offeror's performance record, some doubt exists that the offeror will successfully perform the

required effort. Normal contractor emphasis should preclude any problems.

## Marginal/High Performance Risk

Based on the offeror's performance record, substantial doubt exists that the offeror will successfully perform the required effort.

## Unsatisfactory/Very High Performance Risk

Based on the offeror's performance record, extreme doubt exists that the offeror will successfully perform the required effort.

b. Offeror Past Performance: The Government will evaluate the satisfaction of the customers in the example projects identified by the Offeror and from which Past Performance Evaluation Questionnaires have been received. The Government may contact the points of contact indicated to assure validity of the received questionnaires. The Government may contact sources other than those provided by the Offeror for information with respect to past performance. These other sources may include ACASS (Architect-Engineer Contract Administration Support System), CCASS (Construction Contractor Appraisal Support System), telephone interviews, and Government personnel personal knowledge of contractor performance capability. Offerors will be provided with an opportunity to address any negative past performance information on which the offeror has not previously had such an opportunity. The following areas of major consideration will be determined from evaluation of all sources of past performance information and an overall rating provided:

(1) Quality of the Product Produced. Based on the information provided in the questionnaire and other information the Government will assess the quality of the actual constructions produced and the standards of workmanship exhibited by the Offeror's team.

(2) Adherence to Project Schedule. The Government will evaluate all information available with respect to the Offerors completing past projects within the scheduled completion times.

(3) Management Processes. The Government will evaluate all information available with respect to the Offerors on-site management of construction activities, subcontractors, and any other project management consideration.

c. Offeror Project Key Personnel. The Government will evaluate and rate the Key Personnel identified in the Phase 1 proposal package. The resumes and levels of responsibility of the principal managers and technical personnel who will be directly responsible for the day-to-day design and construction activities will be evaluated. Information should include, as a minimum, the project manager; the project architect; landscape architect; the engineers responsible for civil, electrical, mechanical and structural design; the quality control manager; and the construction manager. Data should indicate whether each individual has had a significant part in any of the project examples cited. If reassignment of personnel is considered possible, the names and resumes of the alternative professionals for each assignment will be evaluated. Additional consideration will be given to individuals who have past experience with Corps of Engineers construction project operations and who have completed the Corps sponsored Quality Control Class.

d. Technical Approach Narrative. The Government will evaluate the overall understanding of the design-build process as well as the Offeror's implementation plans to utilize "fast track" procedures on this project. Particular attention will be paid to the inclusion of the major construction subcontractors during the design process as well as the definition of the roles and responsibilities of the various subcontractors. Offerors are cautioned that this narrative shall not exceed five (5) pages and that the Government review staff will review and evaluate only the information contained on the first five pages in this section. Information beyond the five (5) page limit will be ignored.

e. Relevant Experience. The Government will evaluate the example projects provided by the Offeror to evaluate and rate the recent experience of the Offeror in similar construction and/or design-build

projects. The examples projects which most closely resemble the project identified in this solicitation will receive the highest consideration. If the Offeror cannot provide suitable relevant experience and the Government staff considers the provided information to basically indicate that the Offeror has no relevant experience, this Offeror shall be rated as satisfactory. Lack of relevant experience will not be rated favorably or unfavorably.

f. Evaluation Methodology. The Government evaluation team will consider all information provided in the Phase 1 proposal individually. Once these individual analyses are completed, the team will meet and determine a rating for each of the evaluation factors for Phase 1 by consensus decision. After each of the Factors for each of the proposals are rated, the team will develop, again by consensus, a final overall rating for the Phase 1 proposal. Up to five Offerors will continue into Phase 2 of the project. No proposals which receive an overall rating of Unsatisfactory or Marginal will be forwarded to Phase 2 regardless of the total number of proposals received.

11\

g. Narrative Consensus Comments: The consensus evaluation will identify and document proposal Deficiencies, Strengths, Weaknesses, and Uncertainties.

Definitions:

*Proposal Deficiency:* A material failure of a proposal to meet a Government requirement or a combination of significant weaknesses in a proposal that increases the risk of unsuccessful contract performance to an unacceptable level. Examples of deficiencies include statements by the offeror that it cannot or will not meet a requirement; an approach that clearly does not meet a requirement, or an omission of data required to assess compliance with a Government requirement.

*Proposal Strength:* An aspect of a proposal that appreciably decreases the risk of unsuccessful contract performance or that represents a significant benefit to the Government.

*Proposal Weakness:* A flaw in the proposal that increases the risk of unsuccessful contract performance. A "significant weakness" in the proposal is a flaw that appreciably increases the risk of unsuccessful performance.

*Uncertainty:* Any aspect of the proposal for which the intent of the offeror is unclear because there may be more than one way to interpret the offer or because inconsistencies in the offer indicate that there may be an error, omission, or mistake. Examples include a mistake in calculation or measurement and contradictory statements.

11\

## 5. PHASE 2 EVALUATION PROCEDURES AND CRITERIA:

a. General. The proposals from the Offerors who reach Phase 2 will be evaluated by a team of Government staff to determine compliance with this solicitation (as a minimum), and to evaluate the quality of the proposed materials, methods, and procedures. Each of the evaluation Factors for Phase 2 will be evaluated by the Government and a final overall rating for the proposals shall be determined by consensus of the Government evaluation team. The rating scheme for Phase 2 of the process is as shown below:

**EXCELLENT:** The offeror greatly exceeds the scope of the solicitation requirements in all aspects of the particular factor or sub-factor. The offeror also provides significant advantage(s) and exceeds the solicitation requirements in performance or capability in an advantageous way and has no apparent or significant weaknesses or omissions.

ABOVE AVERAGE: The offeror exceeds the scope of the solicitation in most aspects of the particular factor or sub-factor. The offeror provides an advantage in key areas or exceeds performance or capability requirements, but has some areas of improvement remaining.

11\ /1/

AVERAGE: The offeror matches the scope of the solicitation in most aspects of the particular factor or sub-factor. The offeror meets the performance or capability requirements of the element but not in a way advantageous to the Government. There is room for improvement in this element.

11\ /1/

POOR: The offeror does not meet the minimum scope of the solicitation for the particular factor or sub-factor. The offeror does not include any advantages and does not meet the minimal performance or capability requirements for this element. The offeror contains many apparent weaknesses and requires improvement.

UNACCEPTABLE: The offeror fails to meet the scope of the solicitation in all aspects of the factor or sub-factor or has not submitted any information to address this evaluated item. The offeror does not include any advantages in any areas of the element and does not meet the minimum performance or capability requirements of this factor or sub-factor. The proposal includes large apparent weaknesses and the proposal will require extensive modifications to come into compliance with the minimum requirements of the solicitation.

11\

b. Evaluation Methodology. The Government evaluation team will consider all information provided in the Phase 2 proposals individually. Once these individual analyses are completed, the team will meet and determine a rating for each of the evaluation factors for Phase 2 by consensus decision. After each of the Factors for each of the proposals are rated, the team will develop, again by consensus, a final overall rating for the Phase 2 proposal.

c. Narrative Consensus Comments: The consensus evaluation will identify and document proposal Deficiencies, Strengths, Weaknesses, and Uncertainties.

Definitions:

*Proposal Deficiency:* A material failure of a proposal to meet a Government requirement or a combination of significant weaknesses in a proposal that increases the risk of unsuccessful contract performance to an unacceptable level. Examples of deficiencies include statements by the offeror that it cannot or will not meet a requirement; an approach that clearly does not meet a requirement, or an omission of data required to assess compliance with a Government requirement.

*Proposal Strength:* An aspect of a proposal that appreciably decreases the risk of unsuccessful contract performance or that represents a significant benefit to the Government.

*Proposal Weakness:* A flaw in the proposal that increases the risk of unsuccessful contract performance. A "significant weakness" in the proposal is a flaw that appreciably increases the risk of unsuccessful performance.

*Uncertainty:* Any aspect of the proposal for which the intent of the offeror is unclear because there may be more than one way to interpret the offer or because inconsistencies in the offer indicate that there may be an error, omission, or mistake. Examples include a mistake in calculation or measurement and contradictory statements.

d. Relative Importance of Factors. Refer to paragraph 1 in this section for delineation of factor relative importance.

/1/

## **FACTOR 2-1: BUILDING FUNCTION AND ASTHETICS.**

This factor considers the overall functional layout and interaction of the spaces in the facilities as well as the "appeal" of the facility considering interior as well as exterior considerations. The subfactors to be considered deal with the planning and design of the spaces with respect to soldier living and working conditions and the operations of a UEPH Facility. Closely associated with the functional layout of the spaces and facilities, this factor considers the aesthetics of the interior areas as well as the exterior finishes and design of the facilities, up to and including pedestrian ways and overall environment created by the design proposed. The subfactors described below will be evaluated in the following order of importance:

Subfactor a and b are "GO/NO GO" factors and will be rated as pass/fail without an adjectival component.

Subfactor c is considered the most important subfactor

Subfactor d is slightly less important than subfactor c.

### **a. APPROPRIATE FACILITIES**

From an overall perspective, has the proposal included all the required facilities as described in the Statement of Work?

### **b. MINIMUM SPACE AND FACILITY SIZE**

Has the proposal included all the mandatory spaces in response to the requirements set forth in the Statement of Work? For each of the spaces with a minimum or maximum size limitation, has the proposal complied with these requirements? Insufficient information contained in the proposal to evaluate this item will be considered a "NO GO" and will represent a "FAIL" rating.

**c. FUNCTIONAL ARRANGEMENT** The following items will be considered in the evaluation of the functional arrangement of the various facilities:

[Design District shall edit the following subfactor items to include only those facility types which are included in the project.]

#### **(1A) UEPH (Barracks Buildings)**

- (a) Does the building floor plan provide space arrangement well suited to the mission of the facility?
- (b) Does the building floor plan provide acceptable life safety and fire safety measures? Is the Life Safety Analysis for the facility acceptable and in conformance with the Statement of Work requirements?
- (c) Evaluate the Offeror's floor plan with respect to privacy considerations for the soldiers.
- (d) Does the Offeror's floor plan demonstrate compliance with the mandatory requirements for furnishings while allowing suitable space for circulation and other requirements?

#### **(1B) Company Operations Facilities**

- (a) Does the building floor plan provide space arrangement well suited to the mission of the facility?
- (b) Does the building floor plan provide acceptable life safety and fire safety measures? Is the Life Safety Analysis for the facility acceptable and in conformance with the Statement of Work requirements?
- (c) Evaluate the Offeror's floor plan with respect to the functional and spatial relationship requirements established in the Statement of Work.

- (d) Does the Offeror's floor plan demonstrate compliance with the mandatory requirements for furnishings while allowing suitable space for circulation and other requirements?
- (e) Does the Offeror's floor plan allow for suitable work flow and access necessary to successfully operate this facility in accordance with its mission.

## (1C) Battalion Headquarters Facility

- (a) Does the building floor plan provide space arrangement well suited to the mission of the facility?
- (b) Does the building floor plan provide acceptable life safety and fire safety measures? Is the Life Safety Analysis for the facility acceptable and in conformance with the Statement of Work requirements?
- (c) Evaluate the Offeror's floor plan with respect to the functional and spatial relationship requirements established in the Statement of Work.
- (d) Does the Offeror's floor plan demonstrate compliance with the mandatory requirements for furnishings while allowing suitable space for circulation and other requirements?
- (e) Does the Offeror's floor plan allow for suitable work flow and access necessary to successfully operate this facility in accordance with its mission.

## (1D) Brigade Headquarters Facility

- (a) Does the building floor plan provide space arrangement well suited to the mission of the facility?
- (b) Does the building floor plan provide acceptable life safety and fire safety measures? Is the Life Safety Analysis for the facility acceptable and in conformance with the Statement of Work requirements?
- (c) Evaluate the Offeror's floor plan with respect to the functional and spatial relationship requirements established in the Statement of Work.
- (d) Does the Offeror's floor plan demonstrate compliance with the mandatory requirements for furnishings while allowing suitable space for circulation and other requirements?
- (e) Does the Offeror's floor plan allow for suitable work flow and access necessary to successfully operate this facility in accordance with its mission.

**d. Building Aesthetics.** The following items will be considered, materials will be evaluated in Factor 2-2.

## (1) Exterior Considerations:

- (a) Facades, roof lines, and delineation of entrances.
- (b) Proportions of fenestration in relation to elevations.
- (c) Shadow effects, materials, and textures.
- (d) Proportion and scale within the structure.
- (e) Compliance with Installation Design Guide Recommendations
- (f) Conformance to adjacent structures architectural styles
- (g) Exterior color schemes proposed.
- (h) Other aesthetic considerations.

## (2) Interior Considerations:

- (a) Are the proposed colors and details conducive to the mission of the facility?
- (b) Do the proposed materials and finishes represent a positive working environment?
- (c) Have the ceiling heights, hallway widths, and other space sizes and configurations provided develop a workable solution to the facility mission?
- (d) Does the interior design package provide for an interesting, attractive environment?
- (e) Is the interior system and finishes proposed suitable for use in a facility where the primary occupants are soldiers? Are these systems suitable for a heavy usage environment?

**FACTOR 2-2: BUILDING SYSTEMS.**

This factor considers the materials, layout, maintainability, quality, durability, maintenance considerations, and any aspects of the proposed building systems and materials. Additional consideration will be given to all proposed systems or materials which include betterments or which exceed the minimum requirements of the Statement of Work. Offerors are encouraged to present energy, maintenance, and life cycle cost improvements which will lead to the overall improvement in the final facilities constructed. The following subfactors shall be considered in evaluation this factor. The levels of importance are as follows:

Subfactor a and b are the most important subfactors.

Subfactor c, d, e, f, & g are of equal importance and are each slightly less important than subfactor a.

Subfactor h and .i. are of equal importance and are each less important than subfactor b.

Subfactor j, & k, are of equal importance and are each significantly less important than subfactor i.

Subfactor l is a "GO/NO GO" factor and will be rated as pass/fail without an adjectival component..

**a. Building Heating, Ventilating, and Air Conditioning Systems.** This subfactor evaluates the heating, air conditioning, and ventilating systems proposed for installation. Evaluation will concentrate on the proposed schematic drawing information presented, the design approach narratives, and the equipment and material catalog information included in the proposals. The systems proposed must meet the minimum requirements set forth in the Statement of Work and shall represent systems which are fully integrated into the building structure and are fully capable of environmental control of the spaces. Within this subfactor, the automatic temperature controls shall also be considered. Where addressed in the Statement of Work, the proposed automatic temperature controls systems proposed shall be 100% compatible and integratable into the existing Installation Wide UMCS without translators or third party interface devices. Additional considerations will be given to proposals which incorporate energy recovery systems, high efficiency systems, energy conservation considerations, thermal storage systems, and other systems and features designed to enhance the overall performance of the facility while reducing the operating and maintenance costs expected.

**b. Building Interior Electrical Systems.** This subfactor evaluates the electrical power and lighting systems proposed for installation. Evaluation will concentrate on the proposed schematic drawing information presented, the design approach narratives, and the equipment and material catalog information included in the proposals. The systems proposed must meet the minimum requirements set forth in the Statement of Work and shall represent systems which are fully integrated into the building structure. Additional consideration will be given to proposals which incorporate energy saving materials into the proposals or materials which represent a lower life cycle cost to the Base.

**c. Integration of Interior Support Systems (HVAC, Electrical, Structural, Plumbing, etc).** This subfactor evaluates the integration of the various supporting systems among themselves and within the proposed structural systems. Offeror's proposal shall include a narrative which illustrates the methods and processes whereby the various supporting systems are coordinated to assure a minimum of construction problems which relate the interface between the disciplines.

**d. Force Protection Considerations.** This subfactor evaluates the implementation and considerations of the facility construction related Force Protection Requirements associated with these facilities. A proposal rated "Unacceptable" in this subfactor will be eliminated from consideration.

**e. Building Thermal Performance.** This subfactor evaluates the overall thermal performance of the building structure and includes walls, windows, doors, infiltration, perimeter insulation, and any heat transferring surface within the new constructions. The Statement of Work provides a minimum level of prescriptive requirements which must be included in the proposal. Offerors will receive additional consideration for thermal performance which exceeds the minimum requirements and which reduce the overall energy usage of the facilities.

**f. Building Construction Materials (Other than Structural, HVAC, Electrical).** This subfactor evaluates the quality of the materials proposed for installation in the facility.

**g. Communications and Telephone Systems.** This subfactor evaluates the provision of communications and telephone systems in the facilities as well as the materials proposed for installation.

**h. Security Systems.** This subfactor evaluates the proposed security systems including design and materials.

**i. Fire Protection and Detection Systems.** This subfactor evaluates the proposed fire protection and detection systems. Included in this subfactor is the design as well as the materials proposed for installation.

**j. Cable Television Systems.** This subfactor evaluates the provision of cable television systems in the facilities as well as the materials proposed for installation.

**k. Plumbing Systems.** This subfactor evaluates the provision of plumbing systems in the facilities as well as the materials proposed for installation.

**l. Building Structural Systems.** This subfactor evaluates the structural systems and sub-systems proposed for installation in the facilities. While no detail drawings or calculations are required or desired, this subfactor will evaluate the narrative descriptions of the structural systems proposed.

### **FACTOR 2-3: SITE DESIGN CONSIDERATIONS.**

This factor considers the layout and planning of the site and various specialties which comprise a good site development plan. The goal and direction of the UEPH Complex program is to produce a "campus like" setting and to encourage a positive relationship between the site development and the student needs. All elements of site design will be considered in this factor, with the exception of the design and materials utilized for utility systems which will be evaluated under a different factor. The following subfactors shall be considered in evaluation this factor. The levels of importance are as follows:

Subfactor a is considered the most important subfactor.

Subfactor b is slightly less important than subfactor a.

Subfactor c is slightly less important than subfactor b.

Subfactor d, e, f, g, & h are each equal in importance and are significantly less important than subfactor c.

**a. Area Development Plan.** This subfactor evaluates the overall development concept proposed in the Offeror's plan with respect to the placement and orientation of the facilities, parking areas, pedestrian ways, circulation paths, site lighting, and other aspects which comprise the overall site development. Proposals which reflect the design intent and direction as outlined in the Statement of Work will receive the most consideration during the evaluation process.

**b. Force Protection Considerations.** This subfactor evaluates the inclusion of the site restraints imposed by the Force Protection requirements in the Statement of Work into the Offeror's proposal. The proposal must address this subfactor specifically. If a proposal is rated "unacceptable" in this subfactor the proposal may be eliminated from further consideration.

**c. Pedestrian Circulation.** This subfactor evaluates the design of the pedestrian walkways and sidewalks to facilitate movement of pedestrians from one facility to another. The pedestrian walkways and sidewalks developed in the Offeror's proposal must represent an extension of the existing adjacent systems. Some items for consideration in evaluating this subfactor are as follows:

- (1) Are all parking areas served by sidewalks
- (2) Does the proposed sidewalk system provide direct, convenient access to all facilities from the associated parking areas?
- (3) Has a sidewalk system around and between facilities been provided?
- (4) Is the new sidewalk system an extension of the existing adjacent systems?

**d. Grading.** This subfactor evaluates the proposed grading alterations to the existing site to suit the new development. The Offeror's proposal will be evaluated on the amount and type of site regarding required as well as the provision for positive storm drainage away from the new facilities and parking areas.

**e. Landscaping.** This subfactor evaluates the design, quality, quantity, and location of all planting materials in the proposal. Considerations should include the use of landscaping as screening for exterior equipment and for decorative purposes. The following items shall be considered in evaluating this subfactor.

- (1) Does the proposal include landscaping materials to provide screening for external equipment?
- (2) Does the proposal include decorative plantings to enhance the appearance and environment of the complex?
- (3) Have the plant materials selected reflected those indicated in the Installation Design Guide?
- (4) Have trees (shading and decorative) been included in the proposal?
- (5) Have the parking areas been provided with attractive planting areas to break up the large areas of paving?
- (6) Has the landscaping plan been integrated into the Sustainable Design considerations addressed by the proposer? Does the landscaping provided offer any environmental benefit to the Installation?

**f. Parking Areas.** This subfactor evaluates the provision of parking for the new facilities. In this subfactor the following items should be considered:

- (1) Proximity to new facilities.
- (2) Layout of Parking Areas (with more than 5 spaces)
  - (a) Internal Circulation considerations
  - (b) Clear exit and entrance pathways
  - (c) Ninety (90) degree entrances/exits to primary streets
  - (d) Separation of parking areas entrances/exits from street intersections.

**g. Site Amenities.** This subfactor evaluates the provision of site amenities to enhance the outdoor livability of the UEPH Complex. The requirements shown in Statement of Work are considered minimums and the Offerors are encouraged to include additional items or considerations to enhance the nature of the UEPH Complex and which fosters the development of the areas as "campus like" environments

#### **FACTOR 2-4: SITE ENGINEERING.**

This factor evaluates the technical performance of the proposed site utility and exterior utility distribution systems. The quality of the proposed design as well as the materials selected will be considered in this item. Emphasis will be placed on durability, corrosion resistance, ease of maintenance, and life cycle cost of materials selected. Consideration will be given to the suitability of the chosen materials for the site soil conditions present. Site engineering will consider all aspects of the proposal beyond the 1500-m [5-ft] line from all new facilities. The subfactors listed below will be considered as follows:

Subfactor a, b, c, & d are the most important factors and are all considered equal in importance. Subfactors e, f, & g are all considered of equal importance and each is less important than subfactor a

**a. WATER SYSTEM** Evaluates system design, material quality, and maintainability.

**b. FUEL PIPING AND STORAGE** Evaluates piping sizes, material quality, layout, accessibility, and cutoff isolation.

- c. **ELECTRICAL DISTRIBUTION** Evaluates system design, material quality, and maintainability.
- d. **COMMUNICATIONS (TV, Telephone, etc).** Evaluates system design, material quality, and maintainability.
- e. **SANITARY SEWER** Evaluates system design, material quality, and maintainability.
- f. **STORM SEWER SYSTEM** Evaluates system design, material quality, and maintainability.
- g. **PAVEMENTS** Evaluates pavement design, material quality, and maintainability.

#### **FACTOR 2-5: SUSTAINABLE DESIGN CONSIDERATIONS.**

The Offeror's shall include in their proposal a preliminary ranking of the sustainable design considerations included in the proposal. This ranking shall be either a LEED (Leadership in Energy and Environmental Design, by the U.S. Green Building Council) or a SPiRiT (Sustainable Project Rating Tool, by the U.S. Army Corps of Engineers) ranking. The successful proposal shall be required to complete a detailed analysis on the final design which meets or exceeds the preliminary ranking established at proposal level. Proposals must score at least a Bronze SPiRiT Level or a Certified LEED Level. The evaluation of this factor shall be as follows:

FACTOR RATING	SpiRiT Level	LEED Level
Average	Bronze	Certified
1\ Above Average/1/	Silver	Certified Silver
Above Average	Gold	Certified Gold
Excellent	Platinum	Certified Platinum

#### **FACTOR 2-6: OFFEROR MANAGEMENT PLANS AND SCHEDULES.**

This factor evaluates the Offeror's Project Management Plans as well as the proposed schedule for completion of the entire design-build project. Through this factor the Government will evaluate the Offeror's understanding of the solicitation provisions with respect to an integrated design-build process and the associated quality control, scheduling, coordination, and contract close out provisions. Each of the subfactors below is approximately equal in importance in the evaluation.

**a. Quality Control Plan.** The sample quality control plan provided by the Offeror will be reviewed and evaluated for inclusion of specific quality control practices and requirements necessary for the successful completion of all phases of this project. These phases include design stages as well as construction specialties. Offeror's plan must show the inclusion of the Corps Three Phase Inspection process and address the implications and operations of the Quality Control Plan and it's integration with the Quality Assurance Operations performed by the Government. The personnel and qualifications of the individuals performing in the Quality Control organization will be evaluated under the Phase 1 submission, however, if personnel changes have occurred since the Phase 1 submittal, these individuals must be evaluated as part of the Phase 2 evaluation process.

**b. Schedule Information.** The schedule will be evaluated to assess the inclusion of "fast tracking" and the rational of how the Offeror intends to comply with the submitted schedule. The schedule must reflect a single task oriented structure for both design and construction. The schedule will be reviewed for

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

completeness and the inclusion of required milestones. A schedule which improves on the Government supplied maximum duration will be considered more favorably during the evaluation.

**c. Closeout Plan.** The Offeror's closeout plan will be reviewed and evaluated to determine the Offeror's understanding the close out requirements of the solicitation. Particular emphasis will be placed on O&M Manual production and Installation Staff training methods and processes.

**d. Sub-Contracting Plan.** The Government will evaluate the Offeror's proposed subcontracting plan will be evaluated in terms of achieving the required special emphasis group participations and the completeness and rational for the plan proposed. Offerors who are not required to submit a subcontracting plan (ie Small Business concerns) will be assigned a rating equal to the highest evaluation of any subcontracting plan submitted in response to this solicitation.

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**SECTION 00600**

**Representations & Certifications**

**SECTION 00600**  
**Representations & Certifications**

Note: FAR and DFAR paragraphs are shown only for reference. All contractual information and requirements must be coordinated and produced through the PDT Contract Specialist. This TI is not meant to serve as contracting authority or direction.

<u>PARAGRAPH</u>	<u>DESCRIPTION</u>
52.203-11	CERTIFICATION AND DISCLOSURE REGARDING PAYMENTS TO INFLUENCE CERTAIN FEDERAL TRANSACTIONS (APR 1991)
52.204-5	WOMEN-OWNED BUSINESS (OTHER THAN SMALL BUSINESS) (MAY 1999)
52.204-3	TAXPAYER IDENTIFICATION (OCT 1998)
52.209-5	CERTIFICATION REGARDING DEBARMENT, SUSPENSION, PROPOSED DEBARMENT, AND OTHER RESPONSIBILITY MATTERS (MAR 1996)
52.215-6	PLACE OF PERFORMANCE (OCT 1997)
52.222-22	PREVIOUS CONTRACTS AND COMPLIANCE REPORTS (FEB 1999)
52.223-1	CLEAN AIR AND WATER CERTIFICATION (APR 1984)
52.223-13	CERTIFICATION OF TOXIC CHEMICAL RELEASE REPORTING (OCT 1996)
52.226-2	HISTORICALLY BLACK COLLEGE OR UNIVERSITY AND MINORITY INSTITUTION REPRESENTATION (MAY 1997)
252.227-7028	TECHNICAL DATA OR COMPUTER SOFTWARE PREVIOUSLY DELIVERED TO THE GOVERNMENT (JUN 1995)
252.247-7022	REPRESENTATION OF EXTENT OF TRANSPORTATION BY SEA (AUG 1992)

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**SECTION 00700**

**Contract Clauses**

**SECTION 00700  
Contract Clauses**

Note: FAR and DFAR paragraphs are shown only for reference. All contractual information and requirements must be coordinated and produced through the PDT Contract Specialist. This TI is not meant to serve as contracting authority or direction.

<b><u>PARAGRAPH</u></b>	<b><u>DESCRIPTION</u></b>
52.232-33	PAYMENT BY ELECTRONIC FUNDS TRANSFER—CENTRAL CONTRACTORb REGISTRATION (MAY 1999)
52.202-1	DEFINITIONS (OCT 1995) --ALTERNATE I (APR 1984)
52.203-3	GRATUITIES (APR 1984)
52.203-4	COVENANT AGAINST CONTINGENT FEES (APR 1984)
52.203-7	ANTI-KICKBACK PROCEDURES. (JUL 1995)
52.203-8	CANCELLATION, RESCISSION, AND RECOVERY OF FUNDS FOR ILLEGAL OR IMPROPER ACTIVITY (JAN 1997)
52.203-9	PRICE OR FEE ADJUSTMENT FOR ILLEGAL OR IMPROPER ACTIVITY (JAN 1997)
52.203-12	LIMITATION ON PAYMENTS TO INFLUENCE CERTAIN FEDERAL TRANSACTIONS (JUN 1997)
52.204-3	PRINTING/COPYING DOUBLE-SIDED ON RECYCLED PAPER (JUN 1996)
52.209-5	PROTECTING THE GOVERNMENT'S INTEREST WHEN SUBCONTRACTING WITH CONTRACTORS DEBARRED, SUSPENDED, OR PROPOSED FOR DEBARMENT. (JUL 1995)
52.215-2	AUDIT AND RECORDS--NEGOTIATION (JUN 1999)
52.215-11	PRICE REDUCTION FOR DEFECTIVE COST OR PRICING DATA-- MODIFICATIONS (OCT 1997)
52.215-12	SUBCONTRACTOR COST OR PRICING DATA--MODIFICATIONS (OCT 1997)
52.215-19	NOTIFICATION OF OWNERSHIP CHANGES (OCT 1997)
52.215-20	REQUIREMENTS FOR COST OR PRICING DATA OR INFORMATION OTHER THAN COST OR PRICING DATA--MODIFICATIONS (OCT 1997)
52.215-21	REQUIREMENTS FOR COST OR PRICING DATA OR INFORMATION OTHER THAN COST OR PRICING DATA--MODIFICATIONS (OCT 1997)
52.219-8	UTILIZATION OF SMALL BUSINESS CONCERNS (OCT 1999)
52.219-9	SMALL, SMALL DISADVANTAGED AND WOMEN-OWNED SMALL BUSINESS SUBCONTRACTING PLAN (OCT 1999)--ALTERNATE I (JAN 1999)
52.222-3	CONVICT LABOR (AUG 1996)
52.222-4	CONTRACT WORK HOURS AND SAFETY STANDARDS ACT - OVERTIME COMPENSATION. (JUL 1995)
52.222-6	DAVIS-BACON ACT (FEB 1995)
52.222-7	WITHHOLDING OF FUNDS (FEB 1988)
52.222-8	PAYROLLS AND BASIC RECORDS (FEB 1988)
52.222-9	APPRENTICES AND TRAINEES (FEB 1988)
52.222-10	COMPLIANCE WITH COPELAND ACT REQUIREMENTS (FEB 1988)
52.222-11	SUBCONTRACTS (LABOR STANDARDS (FEB 1988)
52.222-12	CONTRACT TERMINATION--DEBARMENT (FEB 1988)
52.222-13	COMPLIANCE WITH DAVIS-BACON AND RELATED ACT REGULATIONS (FEB 1988)
52.222-14	DISPUTES CONCERNING LABOR STANDARDS (FEB 1988)
52.222-15	CERTIFICATION OF ELIGIBILITY (FEB 1988)
52.222-26	EQUAL OPPORTUNITY (FEB 1999)
52.222-27	AFFIRMATIVE ACTION COMPLIANCE REQUIREMENTS FOR CONSTRUCTION (FEB 1999)
52.222-35	AFFIRMATIVE ACTION FOR DISABLED VETERANS AND VETERANS OF THE

**PARAGRAPH****DESCRIPTION**

	VIETNAM ERA (APR 1998)
52.222-36	AFFIRMATIVE ACTION FOR WORKERS WITH DISABILITIES (JUN 1998)
52.222-37	EMPLOYMENT REPORTS ON DISABLED VETERANS AND VETERANS OF THE VIETNAM ERA (JAN 1999)
52.233-2	CLEAN AIR AND WATER (APR 1984)
52.233-3	PROTEST AFTER AWARD (AUG. 1996)
52.223-6	DRUG-FREE WORKPLACE (JAN 1997)
52.223-14	TOXIC CHEMICAL RELEASE REPORTING (OCT 1996)
52.225-5	BUY AMERICAN ACT--CONSTRUCTION MATERIALS (JUNE 1997)
52.225-11	RESTRICTIONS ON CERTAIN FOREIGN PURCHASES (AUG 1998)
52.226-1	UTILIZATION OF INDIAN ORGANIZATIONS AND INDIAN-OWNED ECONOMIC ENTERPRISES (SEP 1996)
52.227-1	AUTHORIZATION AND CONSENT (JUL 1995)
52.227-2	NOTICE AND ASSISTANCE REGARDING PATENT AND COPYRIGHT INFRINGEMENT (AUG 1996)
52.227-4	PATENT INDEMNITY--CONSTRUCTION CONTRACTS (APR 1984)
52.228-1	BID GUARANTEE (SEP 1996)
52.228-5	INSURANCE--WORK ON A GOVERNMENT INSTALLATION (JAN 1997)
52.228-2	ADDITIONAL BOND SECURITY (OCT 1997)
52.228-11	PLEDGES OF ASSETS (FEB 1992)
52.228-15	PERFORMANCE AND PAYMENT BONDS--CONSTRUCTION (SEP 1996)
52.228-12	PROSPECTIVE SUBCONTRACTOR REQUESTS FOR BONDS. (OCT 1995)
52.228-13	ALTERNATIVE PAYMENT PROTECTIONS (OCT 1997)
52.228-14	IRREVOCABLE LETTER OF CREDIT (DEC 1999)
52.229-3	FEDERAL, STATE, AND LOCAL TAXES (JAN 1991)
52.232-5	PAYMENTS UNDER FIXED-PRICE CONSTRUCTION CONTRACTS (MAY 1997)
52.232-17	INTEREST (JUNE 1996)
52.232-23	ASSIGNMENT OF CLAIMS (JAN 1986) - ALTERNATE I (APR 1984)
52.232-27	PROMPT PAYMENT FOR CONSTRUCTION CONTRACTS (JUN 1997)
52.233-1	DISPUTES. (DEC 1998)
52.236-2	DIFFERING SITE CONDITIONS (APR 1984)
52.236-3	SITE INVESTIGATION AND CONDITIONS AFFECTING THE WORK (APR 1984)
52.236-5	MATERIAL AND WORKMANSHIP (APR 1984)
52.236-6	SUPERINTENDENCE BY THE CONTRACTOR (APR 1984)
52.236-7	PERMITS AND RESPONSIBILITIES (NOV 1991)
52.236-8	OTHER CONTRACTS (APR 1984)
52.236-9	PROTECTION OF EXISTING VEGETATION, STRUCTURES, EQUIPMENT, UTILITIES, AND IMPROVEMENTS (APR 1984)
52.236-10	OPERATIONS AND STORAGE AREAS (APR 1984)
52.236-11	USE AND POSSESSION PRIOR TO COMPLETION (APR 1984)
52.236-12	CLEANING UP (APR 1984)
52.236-13	ACCIDENT PREVENTION (NOV 1991) - ALTERNATE I (NOV 1991)
52.236-15	SCHEDULES FOR CONSTRUCTION CONTRACTS (APR 1984)
52.236-17	LAYOUT OF WORK (APR 1984)
52.236-21	SPECIFICATIONS AND DRAWINGS FOR CONSTRUCTION (FEB 1997)
52.236-23	RESPONSIBILITY OF THE ARCHITECT-ENGINEER CONTRACTOR (APR 1984)
52.236-24	WORK OVERSIGHT IN ARCHITECT-ENGINEER CONTRACTS (APR 1984)
52.236-25	REQUIREMENTS FOR REGISTRATION OF DESIGNERS (APR 1984)
52.236-26	PRECONSTRUCTION CONFERENCE (FEB 1995)
52.242-13	BANKRUPTCY. (JUL 1995)
52.242-14	SUSPENSION OF WORK (APR 1984)
52.243-4	CHANGES (AUG 1987)
52.244-6	SUBCONTRACTS FOR COMMERCIAL ITEMS AND COMMERCIAL COMPONENTS (OCT 1998)
52.246-12	INSPECTION OF CONSTRUCTION (AUG 1996)

<b><u>PARAGRAPH</u></b>	<b><u>DESCRIPTION</u></b>
52.248-3	VALUE ENGINEERING--CONSTRUCTION (MAR 1989)
52.249-2	TERMINATION FOR CONVENIENCE OF THE GOVERNMENT (FIXED-PRICE) (SEP 1996) – ALTERNATE I (SEP 1996)
52.249-10	DEFAULT (FIXED-PRICE CONSTRUCTION) (APR 1984)
52.253-1	COMPUTER GENERATED FORMS (JAN 1991)
252.203-7001	PROHIBITION ON PERSONS CONVICTED OF FRAUD OR OTHER DEFENSE-CONTRACT- RELATED FELONIES (MAR 1999)
252.203-7002	DISPLAY OF DOD HOTLINE POSTER (DEC 1991)
252.204-7003	CONTROL OF GOVERNMENT PERSONNEL WORK PRODUCT (APR 1992)
252.204-7004	REQUIRED CENTRAL CONTRACTOR REGISTRATION.(MAR 1998)
252.205-7000	PROVISION OF INFORMATION TO COOPERATIVE AGREEMENT HOLDERS (DEC 1991)
252.209-7000	ACQUISITION FROM SUBCONTRACTORS SUBJECT TO ONSITE INSPECTION UNDER THE INTERMEDIATE-RANGE NUCLEAR FORCES (INF) TREATY (NOV 1995)
252.209-7003	COMPLIANCE WITH VETERANS' EMPLOYMENT REPORTING REQUIREMENTS (MAR 1998)
252.209-7004	SUBCONTRACTING WITH FIRMS THAT ARE OWNED OR CONTROLLED BY THE GOVERNMENT OF A TERRORIST COUNTRY (MAR 1998)
252.215-7000	PRICING ADJUSTMENTS (DEC 1991)
252.219-7003	SMALL, SMALL DISADVANTAGED AND WOMEN-OWNED SMALL BUSINESS SUBCONTRACTING PLAN (DOD CONTRACTS) (APR. 1996)
252.225-7002	QUALIFYING COUNTRY SOURCES AS SUBCONTRACTORS (DEC 1991)
252.225-7012	PREFERENCE FOR CERTAIN DOMESTIC COMMODITIES. (MAY 1999)
252.225-7031	SECONDARY ARAB BOYCOTT OF ISRAEL (JUN 1992)
252.225-7036	BUY AMERICAN ACT NORTH AMERICAN FREE TRADE AGREEMENT IMPLEMENTATION ACT - BALANCE OF PAYMENTS PROGRAM (MAR 1998)
252.227-7015	TECHNICAL DATA--COMMERCIAL ITEMS. (NOV 1995)
252.227-7022	GOVERNMENT RIGHTS (UNLIMITED) (MAR 1979)
252.227-7027	DEFERRED ORDERING OF TECHNICAL DATA OR COMPUTER SOFTWARE (APR 1988)
252.227-7033	RIGHTS IN SHOP DRAWINGS (APR 1966)
252.227-7037	VALIDATION OF RESTRICTIVE MARKINGS ON TECHNICAL DATA. (SEP 199)
252.236-7000	MODIFICATION PROPOSALS - PRICE BREAKDOWN. (DEC 1991)
252.236-7001	CONTRACT DRAWINGS, MAPS, AND SPECIFICATIONS. (DEC 1991)
252.236-7006	COST LIMITATION (JAN 1997)
252.243-7001	PRICING OF CONTRACT MODIFICATIONS (DEC 1991)
252.243-7002	REQUESTS FOR EQUITABLE ADJUSTMENT (MAR 1998)
252.246-7000	MATERIAL INSPECTION AND RECEIVING REPORT (DEC 1991)
252.247-7023	TRANSPORTATION OF SUPPLIES BY SEA (NOV 1995)
252.247-7024	NOTIFICATION OF TRANSPORTATION OF SUPPLIES BY SEA (NOV 1995)
252.248-7000	PREPARATION OF VALUE ENGINEERING CHANGE PROPOSALS (MAY 1994)

**CONTRACT CLAUSES FOR DESIGN-BUILD CONSTRUCTION CONTRACTS:  
NOTES TO THE DESIGN DISTRICT**

*The applicable contract clauses (Section 00700) for a D-B RFP are generally the same as for a design/bid/build construction RFP solicitation. There are some special considerations to keep in mind for a D-B RFP. Clauses that allow the Government to tailor wording to fit the situation are discussed herein. We have also included some discussion on some standard clauses.*

**Suggested Clauses and Associated DFARS Clauses to be Included in a D/B Contract:**

*Requirements for Registration of Designers  
Performance of Work by the Contractor  
Limitations on Subcontracting  
Commencement, Prosecution, and Completion of the Work  
Governments Rights (Unlimited)  
Drawings and Other Data to Become Property of the Government  
Rights in Shop Drawings  
Nondomestic Construction Materials*

**REQUIREMENTS FOR REGISTRATION OF DESIGNERS**

*It is extremely important to include this standard A-E contract clause in design-build construction contracts. Section 01012, "Design After Award", should specify requirements for the D-B contractor to designate "designers of record" for each design discipline. Section 01330, "Submittals", must specify the role of the DOR(s) to review and approve all submittals for extensions to design and other submittals, requiring coordination with the design. Section 00110, "Proposal Submission Requirements", requires offerors to identify and submit qualifications for the DOR(s). The below Contract Clause establishes minimum standards for registration.*

---

**52.236-0025 REQUIREMENTS FOR REGISTRATION OF DESIGNERS (Apr 1984)**

The design of architectural, structural, mechanical, electrical, civil, or other engineering features of the work shall be accomplished or reviewed and approved by architects or engineers registered to practice in the particular professional field involved in a State or possession of the United States, in Puerto Rico, or in the District of Colombia.

(End of Clause)

---

**PERFORMANCE OF WORK BY THE CONTRACTOR.**

*The following clause is mandatory for construction RFPs, not set-aside for small business or 8(a). The purpose of the clause is to prevent "brokering" of the work (that is where the winning contractor subs out the work to another firm or firms) and to require personal participation and management of the work by the prime contractor.*

---

**52.236-1 PERFORMANCE OF WORK BY THE CONTRACTOR (APR 1984)**

The Contractor shall perform on the site, and with its own organization, work equivalent to at least \_\_\_\_\_ (\*\*) percent of the total amount of work to be performed under the contract, not including design

work. This percentage may be reduced by a supplemental agreement to this contract if, during performing the work, the Contractor requests a reduction and the Contracting Officer determines that the reduction would be to the advantage of the Government.

(End of Clause)

**\*\* NOTE:** *The FAR allows us to edit the required percentage of required self-performed work. Analyze each project on its own merits. Success in design-build construction requires a firm with strong management skills in design and construction. It is recommended specifying a figure within the range of 12-15% of the construction amount, rather than the commonly used figure of "20%" for standard construction contracts. The design fee is normally excluded from the total amount of work. See FAR 36.501 for prescription for use. See also the discussion following this clause for suggested wording to include in Section 00110, "PROPOSAL SUBMISSION REQUIREMENTS", explaining to the offerors what is and what isn't defined as "self performed work." We have also included a standard form for offerors to calculate the amount of work proposed to be self performed and to submit for proposal evaluation.*

---

### **SECTION 0110, "PROPOSAL SUBMISSION REQUIREMENTS", SELF-PERFORMED WORK**

*Below is suggested wording, explaining the requirements of the Contract Clause "Self-Performance of Work." Include this information in Section 01010 "PROPOSAL SUBMISSION REQUIREMENTS. Note that contracts for 8(a) or SDB Set-Aside use a different clause and distinctly different method of calculation of self-performed work.*

---

"XX. Self-Performed Work: Identify what construction parts of the project will be "self-performed" by in-house forces and the related cost for each part, as defined below. If sufficient information is available at the time your offer is prepared, state (within this Organization factor narrative) the percentage of work you will self-perform. If sufficient information is not available during preparation of this narrative, state that the information is in the Pro-Forma requirements (see the following paragraph). The prime contractor must perform [ ] percent of the contract work with its own organization in accordance with Section 00800, "PERFORMANCE OF WORK BY THE CONTRACTOR (APR 1984)."

XX.1 Computation Sheet. Provide and illustrate the calculation for "percent of self-performed work", in accordance with the definitions below. Use the form attached hereinafter.

XX.2 The following are definitions concerning self-performance of work by the Prime Contractor, in accordance with Section 00800, "PERFORMANCE OF WORK BY THE CONTRACTOR."

XX.2.1 "Self-performance of work" generally includes mobilization and utilization of owned or rented plant and equipment to be operated by the prime contractor's own employees; only those materials which will be both purchased and installed by the prime's own forces; labor associated with those aforementioned materials or equipment; only those supplies to directly support work performed by the contractor's own employees; and the contractor's own job overhead costs.

XX.2.2 The following is NOT self-performed work for purposes of the clause: Prime contractor markups for profit, general and administrative overhead, bonds, or other indirect costs on self-performed or subcontracted work; "Owner-operated equipment", rental of plant or equipment for operation by subcontractors; purchase of materials for installation by subcontractors.

XX.2.3 "On the site" includes the construction site(s) as well as off-site fabrication plant or other facilities necessary to manufacture assemblies or provide materials to be incorporated into the construction project.

XX.2.4 "Total amount of work to be performed under the contract" is comprised of all direct (variable, fixed, one-time and semi-variable) costs to the contractor, including jobsite overhead costs, to construct the project. It generally includes all self-performed work, as defined above, and cost of all supplies,

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

materials and subcontracts. It does not include design costs, home or branch office overhead costs or prime contractor markups for bond, profit, etc.”

---

*Shown below is a suggested standard form to include in section 00110, "Proposal Submission Requirements." Use this information to evaluate proposed self-performed work.*

---

**FORMAT FOR CALCULATION OF SELF-PERFORMED WORK**  
**DESIGN/BUILD CONTRACTS**  
**For all Contracts, except 8(a)**

Use a format similar to the following to identify and calculate cost of the work to be self-performed. Refer to the definitions pertaining to "Self-performance of work", "On the site" and "Total amount of work to be performed under the contract". Include this information in the envelope for Pro Forma Requirements) if undetermined until the specified deadline for proposal submission. Otherwise include it in the Performance Capability information:

A. Clearly describe the work to be self-performed:

---

---

---

B. Show Calculation of Self-Performed Work:

B.1 Total Bid Price: \$ \_\_\_\_\_

B.2 Subtract Design Cost: (\$ \_\_\_\_\_)

B.3 Subtract G&A, home office overhead, prime contractor's markups for profit, bond, state use tax, etc. (\$ \_\_\_\_\_)

B.4 Remainder is "Total amount of work to be performed under the Contract" = \$ \_\_\_\_\_

B.5 "Work to be self-performed": = \$ \_\_\_\_\_  
(Includes mobilization and utilization of owned or rented plant and equipment to be operated by the prime contractor's own employees; only those materials which will be both purchased and installed by the prime's own forces; labor associated with those aforementioned materials or equipment; only those supplies to directly support work performed by the contractor's own employees; and the contractor's own job overhead costs.)

B.6 % Self-performed Work = Line B.5/ Line B.4 X 100% = \_\_\_\_\_%

**LIMITATIONS ON SUBCONTRACTING.**

*Note that 8(a) or SDB set-aside contracts do not use the standard FAR Clause "PERFORMANCE OF WORK BY THE CONTRACTOR". Instead, use a Statutorily prescribed clause, entitled "LIMITATIONS ON SUBCONTRACTING." The purpose of the clause is to require personal supervision and control of the contract work by the SDB firm and to require substantial personal work performance (to avoid "brokering the work to non-minority firms). The definitions of self-performed work are substantially different than for non- 8(a) contracts. The clause is shown below, along with information and a form for use in Section 00110 "PROPOSAL SUBMISSION REQUIREMENTS" of the RFP for a competitive 8(a) or competitive SDB set-aside contract.*

**52.219-14 LIMITATIONS ON SUBCONTRACTING (Jan 1991)**

- (a) This clause does not apply to the unrestricted portion of a partial set-aside.
- (b) By submission of an offer and execution of a contract, the Offeror/Contractor agrees that in performance of the contract in the case of a contract for:
- (1) Services (except construction). At least 50 percent of the cost of contract performance incurred for personnel shall be expended for employees of the concern.
  - (2) Supplies (other than procurement from a regular dealer in such supplies). The concern shall perform work for at least 50 percent of the cost of manufacturing the supplies, not including the cost of materials.
  - (3) General construction \*\*. The concern will perform at least 15 percent of the cost of the contract, not including the cost of materials, with its own employees.
  - (4) Construction by special trade contractors \*\*. The concern will perform at least 25 percent of the cost of the contract, not including the cost of materials, with its own employees.
- (End of Clause)

\*\*Specify, in Section 0110, "PROPOSAL SUBMISSION REQUIREMENTS", whether the contract is for general construction or a single trade. This will clarify which sub-paragraph, (b)(3) or (b)(4), applies to the specific project).

**SECTION 0110, "PROPOSAL SUBMISSION REQUIREMENTS", SELF-PERFORMED WORK FOR Competitive 8(a) or SDB Set-aside.**

*The following is suggested wording for inclusion in Section 00110 of the RFP:*

"XX. Identify what parts of the project will be "self-performed" by in-house forces and the related cost for each part, as defined below. Provide and illustrate the calculation for "percent of self-performed work", in accordance with the definitions below.

XX.1 Definitions regarding self-performance of work by the Prime Contractor, in accordance with Contract Clause: "Limitations on Subcontracting" (FAR 52.219-14):

XX1.1 The work in this contract is "general construction" for purposes of Contract Clause "Limitations on Subcontracting."

XX.1.2 "Self-performed work" generally includes costs for: mobilization and utilization of owned or rented plant and equipment to be operated by the contractor's own employees and labor associated with the aforementioned equipment; contractor's own labor to fabricate or to install materials into the finished

construction; performance by the contractor's own employees of design work, land surveys and other engineering or technical specialist services required by the contract; supplies to directly support the aforementioned work to be accomplished by the contractor's own employees; and the contractor's own job overhead costs. Contractor markups for profit, general and administrative overhead, bonds, or other indirect costs on "self-performed" or subcontracted work are not "self-performed work" and are to be excluded from "total cost of the contract" for calculation purposes. Rental of plant or equipment for operation by subcontractors is not "self-performed work" but shall be included in the "total cost of the contract" for calculation purposes. Cost of materials to be incorporated into the work and supplies to support other than construction by the contractor's own employees are excluded from the above definition. Do not include these costs in the calculation.

XX.1.3 "Total cost of the contract" means the total direct (variable, fixed, one-time and semi-variable) costs to the contractor, including jobsite overhead costs but excluding the cost of any materials to be incorporated into the work, to construct the project. It generally includes the cost of all self-performed work, as defined above, and all supplies and subcontract costs. The cost of subcontractor furnished materials will be excluded only to the extent that they can be segregated and identified in the subcontractors' proposals.

XX.1.4 "Percent of self-performed work" is calculated by dividing the above defined cost of "self-performed work" by the "total cost of the contract" and multiplying the result by 100%."

---

### **COMMENCEMENT, PROSECUTION, AND COMPLETION OF WORK**

*Adapt this clause and Specification Section 01320, Project Schedule, as necessary to meet your requirements. You may state separate completion times for the design and the construction; however, this is discouraged. The recommendation is to state one completion time inclusive of both design and construction. If you allow the offerors to propose the contract duration period, add wording to cover acceptance of the selected offeror's proposed performance period – not to exceed a prescribed maximum period.*

---

### **52.211-10 COMMENCEMENT, PROSECUTION, AND COMPLETION OF WORK (Apr 1984)**

(a) The Contractor shall be required to (1) commence work under this contract within 10 calendar days after the date the Contractor receives the notice to proceed, (2) prosecute the work diligently, and (3) design and construct the entire work.....<--If the performance period is to be proposed by the offerors, use wording to this effect: "....ready for use not later than the proposed performance period after receipt of the contract notice to proceed. The maximum proposed performance period cannot exceed \_\_\_\_calendar days after receipt of the notice to proceed."> The times stated for completion shall include final cleanup of the premises.

(b) Provisions stipulated for conducting test on heating and air conditioning systems and planting and maintenance of grass are excluded from the completion time stated above.

(End of Clause)

---

### **GOVERNMENT RIGHTS (UNLIMITED).**

*Use this DFARS clause in all design-build contracts, except those using the DFARS clause: DRAWINGS AND OTHER DATA TO BECOME PROPERTY OF THE GOVERNMENT. The clause grants the Government non-exclusive rights to use the design on other projects.*

---

**52.227-7022 GOVERNMENT RIGHTS (UNLIMITED)(DFARS, Mar 1979)**

The Government shall have unlimited rights in all drawings, designs, specifications, notes and all other works developed in the performance of this contract, including the right to use same on any other Government design or construction without additional compensation to the Contractor. The Contractor hereby grants to the Government a paid-up license throughout the world to all such works to which he may assert or establish any claim under design patent or copyright laws. The Contractor for a period of three (3) years after completion of the project agrees to furnish the original or copies of all such works on the request of the Contracting Officer.

(End of Clause)

---

***DRAWINGS AND OTHER DATA TO BECOME PROPERTY OF THE GOVERNMENT.***

*When the purpose of the Design-Build contract is to obtain a unique architectural design and construction of a building or monument, which for artistic, aesthetic or other special reasons the Government does not want duplicated, use the following DFARS clause to obtain exclusive control of the data pertaining to the design (ref: DFARS 227.7107(b)). In that case, do not use the DFARS clause: 52.227-7022 GOVERNMENT RIGHTS (UNLIMITED)*

---

**52.227-023 DRAWINGS AND OTHER DATA TO BECOME PROPERTY OF THE GOVERNMENT (DFARS, Mar 1979)**

All designs, drawings, specifications, notes, and other works developed in the performance of this contract shall become the sole property of the Government and may be used on any other design without additional compensation to the Contractor. The Government shall be considered the "person for whom the work was prepared" for the purpose of authorship in a copyrightable work under 17 U.S.C. 201(b). With respect thereto, the Contractor agrees not to assert or authorize others to assert any rights or to establish any claim under the design patent or copyright laws. The Contractor for a period of three (3) years after completion of the project agrees to furnish all retained works on the request of the Contracting Officer. Unless otherwise provided in the contract, the Contractor shall have the right to retain copies of all works beyond such period.

(End of Clause)

---

***NONDOMESTIC CONSTRUCTION MATERIALS***

*List all known allowable exceptions to the Buy America Act – Construction in the following clause.*

---

**NONDOMESTIC CONSTRUCTION MATERIALS (Oct 1966) DFARS 52.225-7003**

(a) The requirements of the clause of this contract entitled "Buy American Act" do not apply to the items set forth below:

(LIST)

(End of Clause)

---

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**SECTION 00800**

**Special Contract Requirements**

**SECTION 00800**  
**Special Contract Requirements**

Note: FAR and DFAR paragraphs are shown only for reference. All contractual information and requirements must be coordinated and produced through the PDT Contract Specialist. This TI is not meant to serve as contracting authority or direction.

**PARAGRAPH****DESCRIPTION**

52.211-12	LIQUIDATED DAMAGES--CONSTRUCTION (APR 1984)
52.211-10	COMMENCEMENT, PROSECUTION, AND COMPLETION OF WORK (APR 1984)
52.236-1	PERFORMANCE OF WORK BY THE CONTRACTOR (APR 1984)
52.236-14	AVAILABILITY AND USE OF UTILITY SERVICES (APR 1984)
52.236-4	PHYSICAL DATA (APR 1984)
252.201-7000	CONTRACTING OFFICER'S REPRESENTATIVE (DEC 1991)

**SPECIAL CONTRACT REQUIREMENTS.  
NOTES TO THE DESIGN DISTRICT**

*Special Contract Requirements are contained in Section 0800 of the RFP. Because the D-B RFP includes design services and because the resulting contract includes the selected proposal, additional Special Contract Requirements (SCR's) have been developed to add to the usual set of SCR's used in design/bid/build competitively bid (IFB) construction solicitations.*

*The SCR's, listed below, have been specifically developed to define the non-traditional roles and responsibilities of the various parties in the D-B contract.*

**Suggested SCR's to be Included in Section 0800 of the D/B Contract:**

*Design Build Contract-Order of Precedence  
Proposed Betterments (Optional)  
Key Personnel, Subcontractors, and Outside Associates or Consultants)  
Responsibility of the Contractor for Design  
Warranty of Construction Work  
Sequence of Design/Construction (Can Alternately be Included in Section 01012)  
Sequence of Design/Construction (Fast Track)- (Can Alternately be Included in Section 01012)  
Constructor's Role During Design (Can alternately be included in Section 011012)  
Recommended Insurance Coverage (Optional)  
Training (Can be included in a Technical Section)  
Design Conferences (Can Alternately be Included in Section 01012)  
Value Engineering After Award  
Partnering (Highly Recommended)*

**DESIGN-BUILD CONTRACT-ORDER OF PRECEDENCE:**

*This SCR defines what constitutes the Contract, the order of precedence in the event of inconsistencies and further states that the design documents produced after award are "deliverables", not formally part of the contract, themselves.*

*It is essential that this SCR be included in the D-B contract. DO NOT USE the standard clause "ORDER OF PRECEDENCE-UNIFORM CONTRACT FORMAT" (FAR 52.215-8). This Clause is intended for use in service and supply contracts, using the Uniform Contract Format. The standard clause puts the order of precedence of the proposal above the Section "C", scope of work (SOW), in the event of inconsistencies or conflicts between the two. The SOW in the UCF format is usually more general in nature than the design and construction criteria in a D-B construction contract.*

*In design-build construction, we use the opposite philosophy. The RFP is the minimum standard, except where the Offeror's best value proposal exceeds the minimum RFP requirements. Then, the "betterment" in the proposal becomes the new minimum standard. In a case where the proposal deviates from the RFP minimum, the RFP governs.*

*This benefit to the Government comes at a price. The Government has an inherent legal duty to carefully read and evaluate the proposal for minimum RFP compliance prior to selection and award. Your RFP Section 00110, "PROPOSAL SUBMISSION REQUIREMENTS", should warn offerors not to deviate from the RFP requirements in their proposals. Your description of the basis of award in RFP Section 00120, "PROPOSAL EVALUATION CRITERIA" should state the requirement for successful proposal to be in conformance with the RFP requirements. Proposal deviations and deficiencies must be resolved prior to final proposal submission and award. If a proposal deviates from the RFP but is considered a good idea or approach, the Government must amend the solicitation to allow the feature. This keeps all offerors on a level playing field.*

*The Government cannot simply rely on the language of the D-B Order of Precedence SCR to avoid careful proposal evaluation. The intent of this clause is to establish an order of precedence in cases of not so obvious conflict, discovered after award.*

*The SCR defines the design products as "deliverables" under the contract. With the Government's concurrence, the Contractor may correct design errors and otherwise modify the design, as long as the design still complies with the RFP and accepted proposal. Otherwise, every time a line on a drawing or specification detail changes, a modification would be necessary. The Government can otherwise use "configuration control procedures" in Section 01012 (Design After Award) for requests, approval and tracking of non-contractual changes to the design documents.*

---

**SCR\_\_\_ DESIGN-BUILD CONTRACT-ORDER OF PRECEDENCE - AUG 1997**

(a) The contract includes the standard contract clauses and schedules current at the time of award. It also entails: (1) the solicitation in its entirety, including all drawings, cuts and illustrations, and any amendments during proposal evaluation and selection, and (2) the successful Offeror's accepted proposal. The contract constitutes and defines the entire agreement between the Contractor and the Government. No documentation shall be omitted which in any ways bears upon the terms of that agreement.

(b) In the event of conflict or inconsistency between any of the provisions of the various portions of this contract, precedence shall be given in the following order:

(1.) Betterments: Any portions of the Offeror's proposal which both meet and exceed the provisions of the solicitation

(2.) The provisions of the solicitation. (See also Contract Clause: SPECIFICATIONS AND DRAWINGS FOR CONSTRUCTION.)

(3.) All other provisions of the accepted proposal.

(4.) Any design products, including but not limited to plans, specifications, engineering studies and analyses, shop drawings, equipment installation drawings, etc. These are "deliverables" under the contract and are not part of the contract itself. Design products must conform to all provisions of the contract, in the order of precedence herein.

(End of Clause)

---

**PROPOSED BETTERMENTS (OPTIONAL)**

*This is an optional clause for organizations that wish to use a process to formally list features of the proposal which are considered "betterments", as defined above. Some Districts feel that it is helpful in administering the contract to highlight all betterments in one list. Note that the proposal independently is part of the contract and that the list is merely administrative in nature. A Betterment, which may have been overlooked in the formal list, is nonetheless a contract requirement. A carefully prepared list helps bring betterments to the attention of contract administrators and design reviewers. However, it could also discourage a careful reading of the proposal during contract performance.*

---

**SCR\_\_\_ PROPOSED BETTERMENTS – AUG 1997**

- (a) The minimum requirements of the contract are identified in the Request for Proposal. All betterments offered in the proposal become a requirement of the awarded contract.
- (b) A “Betterment” is defined as any component or system, which exceeds the minimum requirements, stated in the Request for Proposal. This includes all proposed betterments listed in accordance with the “Proposal Submission Requirements” of the Solicitation, and all Government identified betterments.
- (c) “Government identified betterments” include the betterments identified on the “List of Accepted Project Betterments” prepared by the Proposal Evaluation Board and made part of the contract by alteration, and all other betterments identified in the accepted Proposal after award.

(End of Clause)

---

**KEY PERSONNEL, SUBCONTRACTORS AND OUTSIDE ASSOCIATES OR CONSULTANTS.**

*Contract Clause 52.244-4 “Subcontractors and Outside Associates and Consultants”, has been modified by adding the term “Key Personnel”.*

*The successful Offeror’s proposal is part of the contract. This clause is intended to discourage “bid shopping” or “bait and switch” tactics by the Contractor after award of the contract. The Contractor must request permission to substitute those key personnel or key subcontractors it identified in its proposal. The accepted proposal establishes the new minimum standard (assuming that it was in full compliance with the RFP requirements). The Contractor will submit information in the same detail as the original proposal for the Government to evaluate. The Government should not approve any substitute that is not equal in all aspects to the originally proposed person or firm.*

*Since the contract was formulated by negotiation, prices were considered in the selection of the successful Offeror. It can be argued that the Government may demand a credit for a substitution, as consideration for the switch, where it appears that the substitution is the result of “bid shopping” or “bait and switch” tactics. There is no requirement for a price increase, because the Contractor established the minimum level of competency and the price the Government is expected to pay for that competency in its proposal. The proposal is the new required minimum standard, where identified performance surpassed the minimum RFP requirements. Anti-bid shopping clauses are common and enforceable in State, Local and commercial contracting.*

---

**SCR\_\_\_ KEY PERSONNEL, SUBCONTRACTORS AND OUTSIDE ASSOCIATES OR CONSULTANTS - AUG 1997**

In connection with the services covered by this contract, any in-house personnel, subcontractors, and outside associates or consultants will be limited to the individuals or firms that were specifically identified and agreed to during negotiations. The contractor shall obtain the Contracting Officer’s written consent before making any substitution for these designated in-house personnel, subcontractors, associates, or consultants.

(End of Clause)

---

**RESPONSIBILITY OF THE CONTRACTOR FOR DESIGN**

*This SCR is based on FAR Clause 52.236-0023, "Responsibility of the Architect-Engineer Contractor (Apr 1984)". The clause has been re-named for design-build. The words "non-construction services" were added to distinguish design responsibilities from warranty of the construction, which is covered under the "Warranty of Construction Work" SCR. The SCR also requires the D-B to correct the construction resulting from the faulty design.*

**SCR\_\_\_ RESPONSIBILITY OF THE CONTRACTOR FOR DESIGN - FEB 2000**

(a) The Contractor shall be responsible for the professional quality, technical accuracy, and the coordination of all designs, drawings, specifications, and other non-construction services furnished by the Contractor under this contract. The Contractor shall, without additional compensation, correct or revise any errors or deficiency in its designs, drawings, specifications, and other non-construction services and perform any necessary rework or modifications, including any damage to real or personal property, resulting from the design error or omission.

**(b) Neither the Government's review, approval or acceptance of, nor payment for, the services required under this contract shall be construed to operate as a waiver of any rights under this contract or of any cause of action arising out of the performance of this contract. The Contractor shall be and remain liable to the Government in accordance with applicable law for all damages to the Government caused by the Contractor's negligent performance of any of these services furnished under this contract.**

(c) The rights and remedies of the Government provided for under this contract are in addition to any other rights and remedies provided by law.

(d) If the Contractor is comprised of more than one legal entity, each entity shall be jointly and severally liable thereunder.

(End of Clause)

**WARRANTY OF CONSTRUCTION WORK**

*USACE modified the standard "Warranty of Construction" Clause by deleting various references to "design furnished". That wording limited the warranty for design services to one year.*

**SCR\_\_\_ WARRANTY OF CONSTRUCTION WORK – AUG 1997**

(a) In addition to any other warranties in this contract, the Contractor warrants, except as provided in paragraph (1) of this clause, that work performed under this contract conforms to the contract requirements and is free of any defect in equipment, material, or workmanship performed by the Contractor or any subcontractor or supplier at any tier.

(b) This warranty shall continue for a period of 1 year from the date of final acceptance of the work. If the Government takes possession of any part of the work before final acceptance, this warranty shall continue for a period of 1 year from the date the Government takes possession.

(c) The Contractor shall remedy at the Contractor's expense any failure to conform, or any defect. In addition, the Contractor shall remedy at the Contractor's expense any damage to Government-owned or controlled real or personal property, when that damage is the result of--

- (1) The Contractor's failure to conform to contract requirements; or
  - (2) Any defect of equipment, material, or workmanship.
- (d) The Contractor shall restore any work damaged in fulfilling the terms and conditions of this clause. The Contractor's warranty with respect to work repaired or replaced will run for 1 year from the date of repair or replacement.
- (e) The Contracting Officer shall notify the Contractor, in writing, within a reasonable time after the discovery of any failure, defect, or damage.
- (f) If the Contractor fails to remedy any failure, defect, or damage within a reasonable time after receipt of notice, the Government shall have the right to replace, repair, or otherwise remedy the failure, defect, or damage at the Contractor's expense.
- (g) With respect to all warranties, express or implied, from subcontractors, manufacturers, or suppliers for work performed and materials furnished under this contract, the Contractor shall--
- (1) Obtain all warranties that would be given in normal commercial practice:
  - (2) Require all warranties to be executed, in writing, for the benefit of the Government, if directed by the Contracting Officer; and
  - (3) Enforce all warranties for the benefit of the Government, if directed by the Contracting Officer.
- (h) In the event the Contractor's warranty under paragraph (b) of this clause has expired, the Government may bring suit at its expense to enforce a subcontractor's, manufacturer's, or supplier's warranty.
- (i) Unless a defect is caused by the negligence of the Contractor or subcontractor or supplier at any tier, the Contractor shall not be liable for the repair of any defects of material furnished by the Government nor for the repair of any damage that results from any defect in Government-furnished material or design.
- (j) This warranty shall not limit the Government's rights under the Inspection and Acceptance clause of this contract with respect to latent defects, gross mistakes, or fraud.

(End of Clause)

---

### **SEQUENCE OF DESIGN/BUILD CONSTRUCTION**

*This SCR may also be referred to as "Sequence of Work". Two different Special Contract Requirements were developed to address this issue. Use the first SCR when all design or most of the design must be completed prior to allowing construction to begin. Use the second SCR when allowing "fast-track" design-build. Fast track is a term used to describe design and construction sequencing when the D-B incrementally completes and submits portions of the design, in "design packages", for Government review. Once the Government completes its review and all review comments are resolved, the ACO/COR will clear that design package for construction. Thus, in fast track design-build, design and construction can proceed concurrently.*

*The D-B RFP will include only one of the two SCR's. This information can also be alternately be addressed in Section 01012- "DESIGN AFTER AWARD".*

---

**SCR\_\_\_\_\_ SEQUENCE OF DESIGN-CONSTRUCTION – AUG 1997**

(a) After receipt of the Contract Notice to Proceed (NTP) the Contractor shall initiate design, comply with all design submission requirements as covered under Division 01 General Requirements, and obtain Government review of each submission. No construction may be started, <with the exception of...clearing, etc...> until the Government reviews the Final Design submission and determines it satisfactory for purposes of beginning construction. The ACO or COR will notify the Contractor when the design is cleared for construction. The Government will not grant any time extension for any design resubmittal required when, in the opinion of the ACO or COR, the initial submission failed to meet the minimum quality requirements as set forth in the Contract.

(b) If the Government allows the Contractor to proceed with limited construction based on pending minor revisions to the reviewed Final Design submission, no payment will be made for any in-place construction related to the pending revisions until they are completed, resubmitted and are satisfactory to the Government.

(c) No payment will be made for any in-place construction until all required submittals have been made, reviewed and are satisfactory to the Government.

(End of Clause)

---

*Use the following Special Contract Requirement for fast track design-build contracts, in lieu of the above clause. This material can alternately be included in Section 01012-Design After Award.*

---

**SCR\_\_\_\_\_ SEQUENCE OF DESIGN-CONSTRUCTION (FAST TRACK)**

(a) After receipt of the Contract Notice to Proceed (NTP) the Contractor shall initiate design, comply with all design submission requirements as covered under Division 01 General Requirements, and obtain Government review of each submission. The contractor may begin construction on portions of the work for which the Government has reviewed the final design submission and has determined satisfactory for purposes of beginning construction. The ACO or COR will notify the Contractor when the design is cleared for construction. The Government will not grant any time extension for any design resubmittal required when, in the opinion of the ACO or COR, the initial submission failed to meet the minimum quality requirements as set forth in the Contract.

(b) If the Government allows the Contractor to proceed with limited construction based on pending minor revisions to the reviewed Final Design submission, no payment will be made for any in-place construction related to the pending revisions until they are completed, resubmitted and are satisfactory to the Government.

(c) No payment will be made for any in-place construction until all required submittals have been made, reviewed and are satisfactory to the Government.

(End of Clause)

---

**CONSTRUCTOR'S ROLE DURING DESIGN**

*This SCR outlines the role of the Contractor's key construction management staff during the design process.*

---

**SCR\_\_\_ CONSTRUCTOR'S ROLE DURING DESIGN – JUN 1998**

The Contractor's construction management key personnel shall be actively involved during the design process to effectively integrate the design and construction requirements of this contract. In addition to the typical required construction activities, the constructor's involvement includes, but is not limited to actions such as: integrating the design schedule into the Master Schedule to maximize the effectiveness of fast-tracking design and construction (within the limits allowed in the contract), ensuring constructability and economy of the design, integrating the shop drawing and installation drawing process into the design, executing the material and equipment acquisition programs to meet critical schedules, effectively interfacing the construction QC program with the design QC program, and maintaining and providing the design team with accurate, up-to-date redline and as-built documentation. The Contractor shall require and manage the active involvement of key trade subcontractors in the above activities.

(End of Clause)

---

**RECOMMENDED INSURANCE COVERAGE**

*This is an optional SCR to emphasize the D-B's liability for the adequacy of the design in the D-B contract.*

---

**SCR\_\_\_ RECOMMENDED INSURANCE COVERAGE**

The Design-Build Contractor's attention is invited to the contract requirements concerning "RESPONSIBILITY OF THE CONTRACTOR FOR DESIGN" and "WARRANTY OF CONSTRUCTION WORK". These requirements vest in the Contractor complete responsibility for the professional quality, technical accuracy, and coordination of all design, drawings, specifications and other work or materials furnish by his in-house or consultant forces. The Design-Build Contractor must correct and revise any errors or deficiencies in his work, notwithstanding any review, approval, acceptance or payment by the Government. The Contractor must correct and change any work resulting from his defective design at no additional cost to the Government. The requirements further stipulate that the Design-Build Contractor shall be liable to the Government for the damages to the Government caused by negligent performance. Though not a mandatory requirement, this is to recommend that the Design-Build Contractor investigate and obtain appropriate insurance coverage for such liability protection.

(End of Clause)

---

**TRAINING**

*This is suggested wording for a training requirement. This requirement can alternately be included elsewhere in the contract, for example, in Section 01012, "DESIGN AFTER AWARD". It is highly recommended that training be video taped for use by future maintenance personnel.*

---

**SCR\_\_\_ TRAINING – FEB 2000**

The Contractor shall provide operational and maintenance training for all systems furnished under this contract for the operating and maintenance personnel. The system manufacturer shall conduct the training, where feasible. All operation and maintenance manuals shall be submitted and approved prior

to conducting the training and shall be used during training. The Contractor shall video tape the training session on VHS tapes and provide the tapes to the Government.

(End of Clause)

---

### **DESIGN CONFERENCES.**

*This information can be included in the RFP as an SCR or it can be addressed in Section 01012, "Design After Award."*

---

### **SCR\_\_\_\_\_ DESIGN CONFERENCES – JUN 2000**

(a) Pre-Work: As part of the Pre-Work Conference conducted after contract award, key representatives of the Government and the Contractor will review the proposal and the design review procedures specified herein, discuss the preliminary design schedule and provisions for phase completion of the D-B documents with construction activities (fast tracking), as appropriate, meet with key Corps of Engineers Design Review personnel and Using Agency points of contact and any other appropriate pre-design discussion items.

(b) Initial Design Coordination Meeting: After award of the contract, the Contractor shall visit the site and conduct extensive interviews, and problem solving discussions with the individual users, base personnel, Corps of Engineers personnel to acquire all necessary site information, review user options, and discuss user needs. The Contractor shall document all discussions. The design shall be finalized as direct result of these meetings.

(c) Design Review Conferences: Review conferences will be held at <INSERT LOCATION> for each design submittal. The Contractor will bring the personnel that developed the design submittal to the review conference. The conferences will take place the week after the review is complete.

(End of Clause)

---

### **VALUE ENGINEERING AFTER AWARD**

*This SCR is intended to clarify what the Government will and won't consider after award under Contract Clause, 52.248-3, "VALUE ENGINEERING – CONSTRUCTION."*

---

### **SCR\_\_\_\_\_ VALUE ENGINEERING AFTER AWARD – JUNE 1999**

(a) In reference to Contract Clause 52.248-3, "Value Engineering – Construction", the Government may refuse to entertain a "Value Engineering Change Proposal" (VECP) for those "performance oriented" aspects of the Solicitation documents which were addressed in the Contractor's accepted contract proposal and which were evaluated in competition with other offerors for award of this contract.

(b) The Government may consider a VECP for those "prescriptive" aspects of the Solicitation documents, not addressed in the Contractor's accepted contract proposal or addressed but evaluated only for minimum conformance with the Solicitation requirements.

(c) For purposes of this clause, the term "performance oriented" refers to those aspects of the design criteria or other contract requirements which allow the Offeror or Contractor certain latitude, choice of and flexibility to propose in its accepted contract offer a choice of design, technical approach, design solution,

construction approach or other approach to fulfill the contract requirements. Such requirements generally tend to be expressed in terms of functions to be performed, performance required or essential physical characteristics, without dictating a specific process or specific design solution for achieving the desired result.

(d) In contrast, for purposes of this clause, the term “prescriptive” refers to those aspects of the design criteria or other Solicitation requirements wherein the Government expressed the design solution or other requirements in terms of specific materials, approaches, systems and/or processes to be used. Prescriptive aspects typically allow the Offerors little or no freedom in the choice of design approach, materials, fabrication techniques, methods of installation or other approach to fulfill the contract requirements.

(End of Clause)

---

**“PARTNERING” (Optional SCR).**

*Encouraging the Contractor to participate in a partnering process is highly recommended in design-build construction contracts. Why? Because D-B involves non-traditional roles and responsibilities.*

*Design or construction issues affect each other in time and cost and the integrated design and construction schedule is very sensitive to delays – especially when fast tracking is involved. The Government must be more responsive to the information, review, and decision needs of the D-B Contractor.*

*The D-B Contractor should be responsive to the user’s functional needs, often expressed in general terms of “design intent” in the RFP. The D-B Contractor may be flexible with design details, as long as they can be accommodated within the cost and time budgets. Therefore, it is essential that channels of communications and mutual understanding of the other party’s needs be facilitated. Partnering can be very effective toward achieving those goals.*

*Depending upon the size of the job, partnering can be formal or informal. Larger projects can allow for the costs associated with a formal process. Note that there are various formats in use for Partnering, with various cost sharing schemes):*

---

**SCR\_\_\_\_. PARTNERING – APR 2001**

In order to complete this contract most beneficially for both parties, the Government proposes to form a partnering relationship with the contractor. This partnering relationship will draw on the strengths of each party in an effort to achieve a quality project done right the first time, within budget and on schedule. The partnering relationship will be bilateral and participation is encouraged, but voluntary. Any costs associated with partnering will be shared equally with no change in contract price.

(End of Clause)

---

[PROJECT NAME]  
UNACCOMPANIED ENLISTED  
PERSONNEL HOUSING (UEPH)  
COMPLEX

**STATEMENT OF WORK**

**26 November 2001**

U.S. ARMY CORPS OF ENGINEERS (Norfolk District)

**APPROVED FOR PUBLIC RELEASE: DISTRIBUTION UNLIMITED**

Any copyrighted material included in this document is identified at its point of use. Use of the copyrighted material apart from this document must have the permission of the copyright holder.

Record of Changes (changes indicated by \1\ ... /1/ )

<u>Change No.</u>	<u>Date</u>	<u>Location</u>
1	11/1/02	Chapter 2, 4, 12 Attachments 1, 8, and 10

**STATEMENT OF WORK CONTENTS**

			<u>Page</u>
CHAPTER 1 DESIGN OBJECTIVES			
Paragraph	1-1	SCOPE OF WORK .....	1
	1-2	APPLICABLE CRITERIA .....	1
	1-3	DESIGN QUALITY .....	1
	1-4	DESIGN FREEDOM .....	1
	1-5	ENERGY AND RESOURCES CONSERVING FEATURES .....	2
	1-6	INSTALLATION REAL PROPERTY MASTER PLAN .....	2
	1-7	INSTALLATION DESIGN GUIDE .....	2
	1-8	ACCESSIBILITY REQUIREMENTS .....	2
	1-9	ANTI-TERRORISM FORCE PROTECTION REQUIREMENTS .....	2
	1-10	ORGANIZATIONAL STRUCTURE .....	2
CHAPTER 2 FUNCTIONAL AND AREA REQUIREMENTS			
Paragraph	2-1	GENERAL REQUIREMENTS .....	4
	2-2	UEPH FACILITIES FUNCTIONAL AND AREA REQUIREMENTS...	4
	2-3	COMPANY OPERATIONS FACILITIES FUNCTIONAL AND AREA REQUIREMENTS .....	21
	2-4	BATTALION HEADQUARTERS FUNCTIONAL AND AREA REQUIREMENTS .....	39
	2-5	BRIGADE HEADQUARTERS FUNCTIONAL AND AREA REQUIREMENTS .....	58
CHAPTER 3 SITE PLANNING AND DESIGN			
Paragraph	3-1	SCOPE OF WORK .....	76
	3-2	SITE VERIFICATION .....	76
	3-3	EXISTING CONDITIONS .....	76
	3-4	EXCAVATION PERMITS .....	76
	3-5	SITE DEVELOPMENT PLAN .....	77
	3-6	GRADING AND DRAINAGE .....	78
	3-7	GENERAL SITE DESIGN CRITERIA .....	78
	3-8	CIRCULATION AND PARKING .....	79
	3-9	DEFINITIONS .....	79
	3-10	SIDEWALK DESIGN .....	80
	3-11	LANDSCAPE PLANTING PLAN .....	80
	3-12	SPRINKLER AND/OR IRRIGATION SYSTEM .....	83

## CHAPTER 4 SITE ENGINEERING

Paragraph	4-1	SOILS.....	84
	4-2	EROSION AND SEDIMENT CONTROL.....	85
	4-3	DEMOLITION.....	85
	4-4	CLEARING, GRUBBING AND EARTHWORK.....	85
	4-5	WETLANDS.....	85
	4-6	EARTHWORK.....	85
	4-7	BORROW MATERIAL.....	85
	4-8	WATER DISTRIBUTION SYSTEM.....	85
	4-9	SANITARY SEWERAGE SYSTEM.....	87
	4-10	STORMWATER MANAGEMENT, STORM DRAINAGE, AND GRADING.....	89
	4-11	STORM DRAINAGE COLLECTION SYSTEMS AND GRADING.....	89
	4-12	PAVEMENT DESIGN CRITERIA.....	90
	4-13	PERMIT REQUIREMENTS.....	91
	4-14	GAS DISTRIBUTION SYSTEM.....	91
	4-15	HEATING HOT WATER DISTRIBUTION.....	92
	4-16	STEAM DISTRIBUTION.....	94
	4-17	FUEL OIL STORAGE AND DISTRIBUTION.....	98
	4-18	LIQUIFIED PETROLEUM GAS STORAGE AND DISTRIBUTION ...	100
	4-19	ELECTRICAL DISTRIBUTION.....	100
	4-20	TELEPHONE.....	100
	4-21	TELEVISION.....	101
	4-22	CATHODIC PROTECTION.....	101

## CHAPTER 5 ARCHITECTURAL DESIGN

Paragraph	5-1	DESIGN GOALS.....	103
	5-2	APPLICABLE CODES AND STANDARDS.....	103
	5-3	IBC OCCUPANCY AND BUILDING TYPE CLASSIFICATIONS.....	104
	5-4	EXTERIOR DESIGN.....	104
	5-5	INTERIOR DESIGN.....	106
	5-6	PHYSICAL SECURITY REQUIREMENTS.....	109

## CHAPTER 6 STRUCTURAL DESIGN

Paragraph	6-1	GENERAL.....	111
	6-2	STRUCTURAL WORK.....	111
	6-3	DESIGN CRITERIA.....	111
	6-4	SELECTION OF STRUCTURAL SYSTEMS.....	112
	6-5	SPECIAL REQUIREMENTS.....	112

## CHAPTER 7 THERMAL PERFORMANCE

Paragraph	7-1	THERMAL CHARACTERISTICS.....	113
	7-2	THERMAL INSULATION.....	113
	7-3	HUMID AREA DESIGN.....	113
	7-4	INFILTRATION.....	113

**CHAPTER 8 PLUMBING**

Paragraph	8-1	DESIGN STANDARDS AND CODES .....	114
	8-2	DESIGN CALCULATIONS .....	114
	8-3	EQUIPMENT .....	114
	8-4	FIXTURES .....	116
	8-5	PIPING SYSTEMS .....	118
	8-6	MISCELLANEOUS ITEMS .....	119
	8-7	PIPE INSULATION .....	119

**CHAPTER 9 ELECTRICAL SYSTEMS**

Paragraph	9-1	DESIGN STANDARDS AND CODES .....	120
	9-2	DESIGN CALCULATIONS .....	120
	9-3	MATERIALS AND EQUIPMENT .....	120
	9-4	LIGHTING .....	121
	9-5	TELECOMMUNICATIONS .....	122
	9-6	SECURITY SYSTEMS .....	122
	9-7	SPECIAL SYSTEMS .....	122
	9-8	CABLE TELEVISION (CATV) SYSTEM .....	122

**CHAPTER 10 HEATING, VENTILATING, AND AIR CONDITIONING**

Paragraph	10-1	DESIGN STANDARDS AND CODES .....	122
	10-2	DESIGN CALCULATIONS .....	122
	10-3	HUMID AREA DESIGN .....	124
	10-4	MECHANICAL SYSTEMS .....	125
	10-5	INCREMENTAL EQUIPMENT .....	126
	10-6	AIR DISTRIBUTION TERMINAL UNITS .....	128
	10-7	AIR DISTRIBUTION CENTRAL EQUIPMENT .....	131
	10-8	CENTRAL HEATING EQUIPMENT .....	132
	10-9	CENTRAL COOLING EQUIPMENT .....	133
	10-10	AIR DISTRIBUTION SYSTEMS .....	135
	10-11	HYDRONIC DISTRIBUTION SYSTEMS .....	136
	10-12	PIPING SYSTEMS .....	137
	10-13	INSULATION .....	137
	10-14	CONTROLS .....	138
	10-15	TESTING, ADJUSTING AND BALANCING .....	139
	10-16	COMMISSIONING .....	140
	10-17	TRAINING .....	140

**CHAPTER 11 ENERGY CONSERVATION**

Paragraph	11-1	PASSIVE SOLAR APPLICATIONS .....	141
	11-2	PRE-ENGINEERED ACTIVE SOLAR APPLICATIONS .....	141
	11-3	GEOTHERMAL .....	141
	11-4	WIND .....	142
	11-5	CONDENSER HEAT RECOVERY .....	142
	11-6	ENERGY RECOVERY EQUIPMENT .....	142
	11-7	REBATES AND INCENTIVES .....	142

**CHAPTER 12 FIRE PROTECTION**

Paragraph	12-1	DESIGN STANDARDS AND CODES .....	144
	12-2	HYDRANT FLOW DATA.....	144
	12-3	SPRINKLER SYSTEM.....	144
	12-4	FIRE PUMP.....	145
	12-5	STANDPIPE AND HOSE SYSTEM .....	145
	12-6	BUILDING CONSTRUCTION .....	145
	12-7	FIRE ALARM.....	145

**CHAPTER 13 SUSTAINABLE DESIGN**

Paragraph	13-1	SUSTAINABLE DESIGN GOALS .....	147
	13-2	PROJECT REQUIREMENTS .....	147

APPENDIX A	REFERENCES.....	148
------------	-----------------	-----

**TABLES**

<u>Table</u>	<u>Title</u>	<u>Page</u>
2.1	Locker Room Plumbing Fixture and Locker Quantities .....	37
4.1	Soil Compaction .....	84
4.2	Minimum Pipe Insulation Thickness (mm) For Steam (100 to 2.800 kPa (gage)) and High Temperature Hot Water Supply and Return (120 to 230 degrees C)..	96
4.3	Minimum Pipe Insulation Thickness (inches) For Steam (16 to 408 psig) and High Temperature Hot Water Supply and Return (250 to 450 degrees F)	97
4.4	Minimum Pipe Insulation Thickness (mm) For Condensate Return and High Temperature Hot Water Return System	97
4.5	Minimum Pipe Insulation Thickness (inches) For Condensate Return and High Temperature Hot Water Return System .....	98
10.1	Weather Data .....	122
10.2	Internal Loads – UEPH Buildings .....	123
10.3	Internal Loads – Company Operations Facilities.....	123
10.4	Internal Loads – Battalion and Brigade HQ Buildings .....	124

## **CHAPTER 1**

### **DESIGN OBJECTIVES**

1-1 **SCOPE OF WORK.** Design and construction shall comply with the specifications and requirements contained in this Request for Proposals (RFP). The design and technical criteria contained and cited in this RFP establish minimum standards for design and construction quality. The objective of this solicitation is to obtain a campus complex of buildings complete and adequate for assignment as unaccompanied enlisted personnel housing and support facilities. This contract shall consist of the design and construction of barracks, including common support spaces, for [insert number] soldiers, company operations facilities, battalion headquarters, brigade headquarters, site work, and associated facilities on Government-owned land at [installation and location].

1-1.1 **Site Area.** The site[s] is [are] described on the RFP drawings included as part of this solicitation and include[s] approximately [insert] hectares [ \_\_\_ acres].

1-1.2 **Site Work.** Site work includes all design and construction of site features described in the RFP, including but not limited to, site planning, clearing, grading, erosion control, site drainage, utility systems, pavements, pedestrian and vehicular circulation systems, outdoor recreation facilities, landscaping, physical security measures, fencing, and site furnishings.

1-1.3 **Special Utilities and Supplementary Construction.** [Insert special utility items, supplementary construction, on-site or off-site]

1-1.4 **Demolition Considerations and Requirements.** [Insert special items with respect to demolition requirements. Asbestos and lead paint surveys should be included as an attachment to the Statement of Work. It is also recommended to assign responsibility for preparing the asbestos and lead paint abatement guide specs to the industrial hygienist firm that completed the survey. If this is done, attach the edited guide spec to the SOW].

1-1.5 **Environmental Considerations and Mitigation Requirements.** [Insert requirements for remediation of site contamination, wetlands mitigation, etc. Environmental test data, reports and drawings should be included as an attachment to the RFP].

1-2 **APPLICABLE CRITERIA.** Applicable design and construction criteria references are listed in Appendix A to the Statement of Work. Criteria shall be taken from the most current references as of the date of issue of the RFP. Referenced codes and standards are minimum acceptable criteria. Administrative, contractual, and procedural features of the contract shall be as described in other sections of the RFP.

1-3 **DESIGN QUALITY.** The main objectives of this solicitation are to obtain a complex of unaccompanied enlisted personnel housing (UEPH) including support facilities and associated site development within funds available, and to maximize design quality. Design quality is achieved through the optimization of interior planning, integration of buildings with the site, sustainability, selection of building systems for low-cost maintenance and operation, and an overall balance of aesthetics and functionality.

1-4 **DESIGN FREEDOM.** Requirements stated in this RFP are minimums. Innovative, creative, or cost-saving proposals, which meet or exceed these requirements are encouraged

and will be considered more favorably. Designs may incorporate factory fabricated components or modules.

1-5 **ENERGY AND RESOURCES CONSERVING FEATURES.** Public Law 102-486, Executive Order 12902, and Federal Regulations 10 CFR 435, require federal buildings to be designed and constructed to reduce energy consumption in a life-cycle, cost-effective manner using renewable energy sources when economical. Products designed to conserve energy and resources by controlling the amounts of consumed energy or by operating at increased efficiencies should be considered. Minimum requirements for this project are listed in the Statement of Work.

1-6 **INSTALLATION REAL PROPERTY MASTER PLAN.** [Edit as applicable.] The installation real property master plan provides comprehensive documentation of the existing conditions of natural, man-made, and human resources. It also guides future land-use development. Design of this project shall incorporate the design guidance and criteria contained in the [name of installation] Real Property Master Plan, excerpts of which are contained in an attachment to the Statement of Work.

1-7 **INSTALLATION DESIGN GUIDE.** [Edit as applicable.] Design of this project shall incorporate the design guidance and criteria contained in the [name of installation] Installation Design Guide, excerpts of which are contained in an attachment to the Statement of Work.

1-8 **ACCESSIBILITY REQUIREMENTS.** All areas and facilities required to be accessible to physically disabled persons shall conform to the Uniform Federal Accessibility Standards (UFAS) Federal Standard 795, and the Americans With Disabilities Act Accessibility Guidelines (ADAAG). Able-bodied military personnel shall occupy UEPH living units, thus provisions for the disabled are not required within the living units. The following areas shall be accessible:

1-8.1 Areas that may be used by non-military employees or visitors. Specific areas are indicated in the Statement of Work.

1-8.2 Handicap accessible visitor and non-military employee parking spaces near UEPH and other buildings as indicated in Chapter 3 of the Statement of Work.

1-8.3 Minimum of one accessible pedestrian route linking handicap accessible parking areas with accessible building entrances.

1-9 **FORCE PROTECTION & ANTI-TERRORISM CONSIDERATIONS.** Project design and construction shall comply with UFC 4-010-01 Department of Defense Minimum Antiterrorism Standards for Buildings and UFC 4-010-10 Department of Defense Minimum Antiterrorism Standoff Distances for Buildings, excerpts of which are contained in an attachment to the Statement of Work. [Design District shall investigate additional applicable requirements and insert into the Statement of Work as needed. Consider including items such as IDG excerpts in separate folders on the RFP compact disk or website.]

1-10 **ORGANIZATIONAL STRUCTURE.** The housing facilities designed and constructed under this solicitation will be occupied by enlisted soldiers. Each soldier is assigned to a company. Company operations facilities will accommodate the day-to-day functions of the company, including storage of the company's gear and arms, locker/shower facilities for use by soldiers after physical training, and spaces for administration and command of the company. Company operations facilities will be used by enlisted personnel residing in the UEPH facilities,

***Project Name***  
**UEPH Complex**

***Project Number***  
**Statement of Work**  
**26 November 2001**

enlisted personnel living in family housing areas, and non-enlisted personnel.

A number of companies comprise a battalion. Battalion headquarters house the administrative and command functions of the battalion, and provide training and support areas for soldiers. A brigade is composed of a number of battalions. Brigade headquarters house the administrative and command functions of the brigade.

## **CHAPTER 2**

### **FUNCTIONAL AND AREA REQUIREMENTS**

#### **2-1 GENERAL REQUIREMENTS**

**2-1.1 Gross building area definition.** Gross building area is measured to the outside face of exterior enclosure walls. Gross area includes floor areas, penthouses, mezzanines, and other spaces as follows:

**2-1.1.1 Areas calculated as half space.** Gross area includes one-half the area of exterior covered areas such as balconies, entries, loading platforms, breezeways, exterior corridors, and porches. Exterior covered areas are measured from the face of the enclosure wall to the edge of the covered area served. Stairs (enclosed or open) and elevator shafts count as half space for each floor they serve. In UEPH buildings only, interior public corridors will be calculated as half space (circulation spaces *within* the living unit will be calculated as full area).

**2-1.1.2 Excluded space.** The following spaces are excluded from gross area calculations: Attic areas where average clear height does not exceed 2.13m [7 feet]; crawl spaces; exterior uncovered loading platforms; open courtyards; normal roof overhangs and soffits for weather protection; uncovered ramps and steps; utility tunnels; raceways; mechanical equipment platforms and catwalks.

**2-1.2 Gross area limitations.** Maximum authorized gross building areas for each facility are included in this paragraph. Proposals that exceed authorized gross area limitations may be considered non-conforming.

**2-1.3 Net area definition.** Net area is measured to the inside face of the room or space walls.

**2-1.4 Net Area Requirements.** Net area requirements for programmed spaces are included in this chapter. If net area requirements are not specified in the Statement of Work, the space shall be sized to: accommodate the required function, comply with code requirements, comply with overall gross area limitations and other requirements of the RFP (for example, area requirements for corridors, stairs, and mechanical rooms will typically be left to the discretion of the offeror).

**2-1.5 Functionality.** Rooms shall be sized and arranged for efficient use, circulation, and furniture placement.

**2-1.6 Finish Requirements.** Room finishes stated in the following paragraphs are preferred minimums; finish selections are not limited to those listed.

**2-1.7 Furniture Requirements.** [Early in the project programming process, the RFP preparation team must determine the scope of interior furnishings (tables, chairs, beds, etc.) that will be required to be provided by the offerors. Subject to funding requirements, the RFP may be written so that furnishings are not provided by the offeror (the more traditional approach), or the RFP may be written to require offerors to provide a completely furnished, turnkey, building. Functional and area requirements in this model SOW require the offeror to "provide and design the space to accommodate" furnishings that would typically occur in some spaces; furniture requirements for other spaces are to be identified by the RFP preparation

team. In either case, careful coordination with the using activity is necessary prior to issuance of the RFP. If the provision of furniture is to be included in the RFP, specific furniture criteria such as acceptable materials, finishes and quality levels must be added to the SOW.]

**2-2 UEPH FACILITIES FUNCTIONAL AND AREA REQUIREMENTS.** The UEPH building(s) shall consist of living units, common areas, and support spaces. Each living unit shall be designed to be occupied by one or two soldiers. Provide [ ] Two-person living units [and One-person living units] to house a total of [ ]enlisted personnel. Living units and common areas may comprise a single building, or multiple buildings. Total gross building area of UEPH buildings shall not exceed [ ] square meters (m<sup>2</sup>) [ ] square feet (sf) [Maximum gross area is limited to 34 m<sup>2</sup> per soldier (36 m<sup>2</sup> per soldier for high-rise facilities (over three stories) or to meet other site specific requirements); this includes living units, common areas, and support spaces in the UEPH buildings. Maximum gross area shall be as shown on form DD 1391.]. **The successful design scheme will maximize the area of the living units, provide the required support and common areas, and strictly comply with the overall gross building area limitation.** Building spaces and areas shall be as follows:

**2-2.1 Areas Comprising the Two-Person Living Unit (Module).** Each Two-Person living unit, or module, will contain two individual living/sleeping rooms with closets, and some combination of a shared or private service area with kitchenette, and a shared bathroom. Spaces are as follows.

**2-2.1.1 Individual Living/Sleeping Room.** Minimum net area 13 m<sup>2</sup> [140 sf]. Maximum net area 17 m<sup>2</sup> [182 sf]. Provide two per module.

**2-2.1.1.1 Function:** Private bedroom and living space for one enlisted person.

**2-2.1.1.2 Adjacency requirements:** Adjacent to service area and closet. Living/sleeping room shall be entered from service area, or the public interior corridor or breezeway. Provide 750mm [2'-6"] wide door between service area and living/sleeping room. If living/sleeping room is entered directly from interior corridor or breezeway, provide 900mm [3'-0"] wide entry door swinging into room.

**2-2.1.1.3 Furnishings/Fixtures/Equipment:** Provide, and design the room to accommodate, the following furnishings: One twin bed with headboard and footboard 102mm x 2083mm [40" x 85"]; one entertainment center for occupant's television and sound system 864mm wide x 635mm deep x 1930mm high [34" x 25" x 76"]; one chest of drawers 712mm wide x 458mm deep x 661mm high [28" x 18" x 26" high]; one nightstand 485mm wide x 435mm deep x 535mm high [19" x 17" x 21" high]; one desk 1524mm wide x 762 deep (with keyboard tray retracted) x 762mm high [60" wide x 30" deep x 30" high]; and one desk chair 500mm wide x 535mm deep x 851mm high [19-1/2" x 21" x 33-1/2" high]. .

**2-2.1.1.4 Minimum Finishes:**

Floor: vinyl composition tile

Base: wood or resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted underside of precast concrete structural floor planks

**2-2.1.1.5 Other requirements:** Living/sleeping room shall have at least one exterior operable window with insect screen. Window shall meet egress requirements of NFPA 101 and

International Building Code. Window shall not be located adjacent to an exterior corridor or breezeway. Door between service area and living/sleeping room shall have entry function (F82) lockset (living/sleeping room is secure side). If provided, door between public corridor and living/sleeping room shall have mortise dormitory function (F13) lockset. Provide minimum of one combination telephone/data outlet in each Living /Sleeping room. Provide minimum of one cable television outlet in each Living/Sleeping room. Coordinate outlet locations with furniture arrangement. Refer to Chapter 9 Electrical Systems

2-2.1.2 **Closet.** Minimum net area 3 m<sup>2</sup> [32.3 sf]. Provide one per living/sleeping room.

2-2.1.2.1 Function: Private walk-in closet for clothing and storage of boxes and field gear.

2-2.1.2.2 Adjacency requirements: Adjacent to living/sleeping room. Provide minimum 700mm [2'-4"] wide door between living/sleeping room and closet.

2-2.1.2.3 Furnishings/Fixtures/Equipment (FFE): Provide minimum 2 linear meters [6'-7"] of rod and shelf.

2-2.1.2.4 Minimum Finishes:

Floor: vinyl composition tile

Base: wood or resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted underside of precast concrete structural floor planks.

2-2.1.2.5 Other requirements: Door shall have privacy function (F76) lockset, or be equipped with a hasp so the occupant can provide his/her own padlock.

2-2.1.3 **Service Area.** Provide one per module.

2-2.1.3.1 Function: Circulation space, food preparation area, [area for washer and dryer,] and eating area for occupants.

2-2.1.3.2 Adjacency requirements: Adjacent to living/sleeping rooms and bathroom. If service area is entered from public corridor or breezeway, provide 900mm [3'-0"] wide entry door swinging into room

2-2.1.3.3 Furnishings/Fixtures/Equipment: Provide refrigerator-freezer (minimum 9 total cubic feet). Provide microwave oven (min .9 cubic feet, 800 watts) mounted under wall cabinets. Provide minimum 2-burner electric cooktop, or 2-burner electric range with self-cleaning oven. Provide range hood with exterior exhaust. Provide minimum 1500 linear mm [5'-0"] of 600mm [2'-0"] deep kitchen base cabinets and countertop (including cooktop/range width), and 2100 linear mm [7'-0"] of 300mm [12"] deep wall cabinets. Wall cabinets shall be minimum 600mm [2'-0"] high; provide 600 mm [2'-0"] clear between countertop and bottom of wall cabinets at sink. Base cabinets shall have minimum of two 300 mm [12"] wide drawers. Provide plastic laminate countertop with side and backsplashes at walls. Provide single compartment, stainless steel kitchen sink with food strainer/stopper, minimum inside dimensions 400mm x 400mm x 175mm deep [1'-4" x 1'-4" x 7" deep], with chrome-plated, single handle, washerless mixing faucet (refer to Chapter 8). Provide, and design room to accommodate, the following furnishings: one dining table for two persons, 750mm square x 725mm high [30" x 28-1/2" high] with two armless dining chairs. Provide fire extinguisher mounted inside base cabinet.

Providing residential type clothes washer and dryer in each living unit is a HQ approved option. If the design district is considering use for this project, coordination with user and installation facilities engineer (DPW) is essential. Carefully weigh the benefits and drawbacks of providing laundry appliances in each unit. Appliances shall be Energy Star compliant. Note, also, that for optimum performance and minimum maintenance and fire hazard, dryers should exhaust to the exterior with as little ductwork as possible; this puts additional design parameters on the arrangement of the floor plan of the units

2-2.1.3.4 Minimum Finishes:

Floor: vinyl composition tile

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster

Wall area between countertop and wall cabinets: ceramic tile, plastic laminate, or color coordinated back wall shield (if unitized kitchen is used)

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted underside of precast concrete structural floor planks

2-2.1.3.5 Other requirements: At wall areas around dining table provide chair rail or similar wall protection to protect walls from chair and table impact. It is desirable, but not required, to have exterior window in room. Window shall not be located adjacent to an exterior corridor or breezeway. Door between public corridor and service area (entry door into module) shall have mortise dormitory function (F13) lockset.

2-2.1.4 **Bathroom.** Provide minimum of one bathroom per module.

2-2.1.4.1 Function: Bathing and toilet facilities for either occupant; storage for both occupants' bath articles.

2-2.1.4.2 Adjacency requirements: Adjacent to service area or interior hallway. Provide 600mm [2'-0"] wide door between bathroom and service area or hallway.

2-2.1.4.3 Furnishings/Fixtures/Equipment (FFE): Lavatory shall be minimum 475mm x 475mm [19" x 19"] self-rimming vitreous china, or cast-filled acrylic or solid surfacing material integrally molded to countertop. Provide chrome-plated washerless faucet with pop-up drain (refer to Chapter 8). Countertop shall be minimum 900mm [3'-0"] wide cast-filled acrylic, acrylic solid surfacing material, or plastic laminate with integrally molded, 100mm high coved backsplash. Provide 102mm high side splash at side walls. Provide plastic laminate surfaced vanity base cabinet with hinged door(s) and minimum two 225mm [9"] wide drawers. Provide 6mm [1/4"] thick x minimum 1050mm [3'-6"] high mirror glass, full width of vanity countertop, with wall mounted vanity light fixture above mirror (refer to Chapter 9). Provide one recessed medicine cabinet, two soap holders, two toothbrush/tumbler holders. Provide floor mounted toilet with full seat and seat cover (lid). Provide bathtub, chrome-plated brass showerhead, and anti-scald single-handle mixing valve (refer to Chapter 8). Provide two minimum 600mm [2'-0"] long towel bars mounted on walls outside tub/shower enclosure, two wall mounted soap holders in the tub/shower, and one door mounted robe hook with two hooks. Provide wall mounted retractable clothesline across tub/shower. Provide mildew-resistant vinyl shower curtain with stainless steel curtain hooks and chrome-plated brass shower curtain rod. Provide single roll toilet tissue dispenser.

2-2.1.4.4 Minimum Finishes:

Floor: ceramic tile

Base: ceramic tile sanitary cove base

Walls: painted water-resistant gypsum wallboard or painted veneer plaster, or ceramic tile, or ceramic tile wainscot. Walls around shower/tub enclosure shall be full height ceramic tile, or material with equivalent scratch-resistance, water-resistance, and durability.

Ceiling: painted exterior gypsum soffit board, or painted veneer plaster, painted Portland cement plaster, or painted underside of precast concrete structural floor planks.

2-2.1.4.5 Other requirements: HVAC system shall exhaust bathroom air; refer to Chapter 10. Door shall have privacy function (F76) lockset.

2-2.1.5 **Module Mechanical Area.** Mechanical units may be located above ceilings, or in separate mechanical closets; or through-wall packaged units may be used. Refer to Chapter 10. If mechanical closet is provided, the following requirements will apply:

2-2.1.5.1 Function: Houses HVAC unit for the module. Room shall not be used for storage or any purpose not related to the mechanical system. Access will be limited to maintenance personnel.

2-2.1.5.2 Adjacency requirements: Adjacent to and accessible only from exterior or public corridor or breezeway.

2-2.1.5.3 Furnishings/Fixtures/Equipment: Provide mechanical system. Refer to Chapter 10.

2-2.1.5.4 Minimum Finishes:

Floor: sealed concrete

Base: none required

Walls: painted gypsum wallboard, painted veneer plaster, or painted concrete masonry units.

Ceiling: : painted gypsum wallboard, or painted veneer plaster, or painted underside of precast concrete structural floor planks

2-2.1.5.5 Other requirements: Provide swinging door sized to allow maintenance and removal of mechanical unit(s). Door shall have storeroom function (F86) lockset. Room construction shall comply with fire and smoke separation requirements of applicable codes.

2-2.2 **Areas Comprising the One-Person Living Unit (Module).** Each One-Person living unit, or module, will contain a living/sleeping room with closet, a service area with kitchenette, and a bathroom. Spaces are as follows.

2-2.2.1 **Living/Sleeping Room.** Minimum net area 13 m<sup>2</sup> [140 sf]. Maximum net area 17 m<sup>2</sup> [182 sf]. Provide one per module.

2-2.2.1.1 Function: Private bedroom and living space for one senior enlisted person.

2-2.2.1.2 Adjacency requirements: Adjacent to service area and closet. Living/sleeping room shall be entered from service area, or the public interior corridor or breezeway. 750mm [2'-6"] wide door between service area and living/sleeping room may be provided, or room may be arranged like an efficiency apartment without door between kitchenette and living/sleeping area. If living/sleeping room is entered directly from interior corridor or breezeway, provide 900mm [3'-0"] wide entry door swinging into room.

2-2.2.1.3 Furnishings/Fixtures/Equipment: Provide, and design the room to accommodate,

the following furnishings: One twin bed with headboard and footboard 102mm x 2083mm [40" x 85"]; one entertainment center for occupant's television and sound system 864mm wide x 635mm deep x 1930mm high [34" x 25" x 76"]; one chest of drawers 712mm wide x 458mm deep x 661mm high [28" x 18" x 26" high]; one nightstand 485mm wide x 435mm deep x 535mm high [19" x 17" x 21" high]; one desk 1524mm wide x 762 deep (with keyboard tray retracted) x 762mm high [60" wide x 30" deep x 30" high]; and one desk chair 500mm wide x 535mm deep x 851mm high [19-1/2" x 21" x 33-1/2" high].

2-2.2.1.4 Minimum Finishes:

Floor: vinyl composition tile

Base: wood or resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted underside of precast concrete structural floor planks

2-2.2.1.5 Other requirements: Living/sleeping room shall have at least one exterior operable window with insect screen. Window shall meet egress requirements of NFPA 101 and International Building Code. Window shall not be located adjacent to an exterior corridor or breezeway. Door between service area and living/sleeping room shall have passage function (F75) latchset. Door between public corridor and living/sleeping room shall have mortise dormitory function (F13) lockset. Provide minimum of one combination telephone/data outlet on in each Living /Sleeping room. Provide minimum of one cable television outlet in each Living/Sleeping room. Coordinate outlet locations with furniture arrangement. Refer to Chapter 9 Electrical Systems.

2-2.2.2 **Closet.** Minimum net area 3 m<sup>2</sup> [32.3 sf]. Provide one.

2-2.2.2.1 Function: Private walk-in closet for clothing and storage of boxes and field gear.

2-2.2.2.2 Adjacency requirements: Adjacent to Living/sleeping room. Provide minimum 700mm [2'-4"] wide door between living/sleeping room and closet.

2-2.2.2.3 Furnishings/Fixtures/Equipment (FFE): Provide minimum 2 linear meters [6'-7"] of rod and shelf.

2-2.2.2.4 Minimum Finishes:

Floor: vinyl composition tile

Base: wood or resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted underside of precast concrete structural floor planks.

2-2.1.2.5 Other requirements: Door shall have privacy function (F76) lockset, or be equipped with a hasp so the occupant can provide his/her own padlock.

2-2.2.3 **Service Area.** Provide one per module. Service Area may be a separate room, or may be integrated into Living/sleeping room as in an efficiency apartment.

2-2.2.3.1 Function: Circulation space, food preparation area, [area for washer and dryer], and eating area for occupant and visitors.

2-2.2.3.2 Adjacency requirements: Adjacent to Living/sleeping room and bathroom. If Service Area is entered from public corridor or breezeway, provide 900mm [3'-0"] wide entry door swinging into room

2-2.2.3.3 Furnishings/Fixtures/Equipment: Provide refrigerator-freezer (minimum 9 total cubic feet). Provide microwave oven (min .9 cubic feet, 800 watts) mounted under wall cabinets. Provide minimum 2-burner electric cooktop, or 2-burner electric range with self-cleaning oven. Provide range hood with exterior exhaust. Provide minimum 1500 linear mm [5'-0"] of 600mm [2'-0"] deep kitchen base cabinets and countertop (including cooktop/range width), and 2100 linear mm [7'-0"] of 300mm [12"] deep wall cabinets. Wall cabinets shall be minimum 600mm [2'-0"] high; provide 600 mm [2'-0"] clear between countertop and bottom of wall cabinets at sink. Base cabinets shall have minimum of two 300 mm [12"] wide drawers. Provide plastic laminate countertop with side and backsplashes at walls. Provide single compartment, stainless steel kitchen sink with food strainer/stopper, minimum inside dimensions 400mm x 400mm x 175mm deep [1'-4" x 1'-4" x 7" deep], with chrome-plated, single handle, washerless mixing faucet (refer to Chapter 8). Provide, and design room to accommodate, the following furnishings: one dining table for two persons, 750mm square x 725mm high [30" x 28-1/2" high] with two armless dining chairs. Provide fire extinguisher mounted inside base cabinet. [Providing residential type clothes washer and dryer in each living unit is a HQ approved option. If the design district is considering use for this project, coordination with user and installation facilities engineer (DPW) is essential. Carefully weigh the benefits and drawbacks of providing laundry appliances in each unit. Appliances shall be Energy Star compliant. Note, also, that for optimum performance and minimum maintenance and fire hazard, dryers should exhaust to the exterior with as little ductwork as possible; this puts additional design parameters on the arrangement of the floor plan of the units].

2-2.2.3.4 Minimum Finishes:

Floor: vinyl composition tile

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster

Wall area between countertop and wall cabinets: ceramic tile, plastic laminate, or color coordinated back wall shield (if unitized kitchen is used)

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted underside of precast concrete structural floor planks

2-2.2.3.5 Other requirements: At wall areas around dining table provide chair rail or similar wall protection to protect walls from chair and table impact. It is desirable, but not required, to have exterior window in room. Window shall not be located adjacent to an exterior corridor or breezeway. Door between public corridor and service area (entry door into module) shall have mortise dormitory function (F13) lockset.

2-2.2.4 **Bathroom.** Provide one per module.

2-2.2.4.1 Function: Bathing and toilet facilities for occupant; storage for occupants' bath articles.

2-2.2.4.2 Adjacency requirements: Adjacent to service area or interior hallway. Provide 610mm [2'-0"] wide door between bathroom and service area or hallway.

2-2.2.4.3 Furnishings/Fixtures/Equipment (FFE): Lavatory shall be minimum 483mm x 483mm [19" x 19"] self-rimming vitreous china, or cast-filled acrylic or solid surfacing material integrally

molded to countertop. Provide chrome-plated washerless faucet with pop-up drain (refer to Chapter 8). Countertop shall be minimum 914mm [3'-0"] wide cast-filled acrylic, acrylic solid surfacing material, or plastic laminate with integrally molded, 102mm high coved backsplash. Provide 102mm high side splash at side walls. Provide plastic laminate surfaced vanity base cabinet with hinged door(s) and minimum two 229mm [9"] wide drawers. Provide 6mm [1/4"] thick x minimum 1067mm [3'-6"] high mirror glass, full width of vanity countertop, with wall mounted vanity light fixture above mirror (refer to Chapter 9). Provide one recessed medicine cabinet, one soap holder, one toothbrush/tumbler holder. Provide floor mounted toilet with full seat and seat cover (lid). Provide bathtub, chrome-plated brass showerhead, and anti-scald single-handle mixing valve (refer to Chapter 8). Provide two minimum 610mm [2'-0"] long towel bars mounted on walls outside tub/shower enclosure, one wall mounted soap holder in the tub/shower, and one door mounted robe hook with two hooks. Provide wall mounted retractable clothesline across tub/shower. Provide mildew-resistant vinyl shower curtain with stainless steel curtain hooks and chrome-plated brass shower curtain rod. Provide single roll toilet tissue dispenser.

**2-2.2.4.4 Finishes:**

Floor: ceramic tile

Base: ceramic tile sanitary cove base

Walls: painted water-resistant gypsum wallboard or painted veneer plaster, or ceramic tile, or ceramic tile wainscot. Walls around shower/tub enclosure shall be full height ceramic tile, or material with equivalent scratch-resistance, water-resistance, and durability.

Ceiling: painted exterior gypsum soffit board, or painted veneer plaster, painted Portland cement plaster, or painted underside of precast concrete structural floor planks.

**2-2.2.4.5 Other requirements:** HVAC system shall exhaust bathroom air; refer to Chapter 10. Door shall have privacy function (F76) lockset.

**2-2.2.5 Module Mechanical Area.** Mechanical units may be located above ceilings, or in separate mechanical closets; or through-wall packaged units may be used. Refer to Chapter 10. If mechanical closet is provided, the following requirements will apply:

**2-2.2.5.1 Function:** Houses HVAC unit for the module. Room shall not be used for storage or any purpose not related to the mechanical system. Access will be limited to maintenance personnel.

**2-2.2.5.2 Adjacency requirements:** Adjacent to and accessible only from exterior or public corridor or breezeway.

**2-2.2.5.3 Furnishings/Fixtures/Equipment:** Provide mechanical system. Refer to Chapter 10.

**2-2.2.5.4 Finishes:**

Floor: sealed concrete

Base: none required

Walls: painted gypsum wallboard, painted veneer plaster, or painted concrete masonry units.

Ceiling: painted gypsum wallboard, or painted veneer plaster, or painted underside of precast concrete structural floor planks

**2-2.2.5.5 Other requirements:** Provide swinging door sized to allow maintenance and removal of mechanical unit(s). Door shall have storeroom function (F86) lockset. Room construction shall comply with fire and smoke separation requirements of applicable codes.

2-2.3 **UEPH Common Areas.** Common areas may be located within a building containing living units, or in a separate building. [Note: common area sizes and requirements listed below are based on what is required for a 192 to 288-person UEPH facility. It is assumed that the UEPH campus will arrange living units in groups not to exceed 144 units. RFP preparers should review and adjust the quantity and size of common areas to reflect the desired grouping of living units]. Entry lobby, CQ station, toilet room, mail room, and public telephones should be grouped together at the main entrance to the barracks, adjacent to visitor parking area. Spaces are as follows:

2-2.3.1 **Entry Lobby.** Provide one.

2-2.3.1.1 Function: Primary entry point into the UEPH facility; waiting area for visitors.

2-2.3.1.2 Adjacency requirements: Adjacent to main entry to UEPH facility. It is preferable to enter lobby area from two sides of building.

2-2.3.1.3 Furnishings/Fixtures/Equipment: Provide and design space to accommodate minimum of six upholstered modular waiting-area seating units with two modular end table units. Provide ceiling or wall mounted television bracket with locking tray. Arrange seating to allow viewing of television (TV is government furnished, government installed). Provide wall mounted electric water cooler.

2-2.3.1.4 Finishes:

Floor: porcelain tile, or quarry tile.

Base: porcelain tile or quarry tile, or stained wood base.

Walls: painted gypsum wallboard, or painted veneer plaster.

Ceiling: suspended acoustical panel ceiling, painted gypsum wallboard, painted veneer plaster, painted Portland cement plaster, or painted underside of precast concrete structural floor planks.

2-2.3.1.5 Other requirements: Handicap accessible. Provide conduit and junction box for cable television service to wall or ceiling mounted television.

2-2.3.2 **Entry Vestibules.** Provide at each exterior entrance to lobby area. [If climate dictates, revise this sentence to require vestibules at all entrances to the building.]

2-2.3.2.1 Function: Primary entry point into the UEPH facility; weather protection for interior spaces.

2-2.3.2.2 Adjacency requirements: Adjacent to lobby.

2-2.3.2.3 Furnishings/Fixtures/Equipment:

2-2.3.2.4 Finishes:

Floor: Provide recessed entry mat full depth of vestibule x full width of doors; porcelain tile, or quarry tile in remainder of room.

Base: porcelain tile or quarry tile

Walls: Match exterior wall finish material (preferred), or painted gypsum wallboard, or painted veneer plaster

Ceiling: painted gypsum wallboard, painted veneer plaster, painted Portland cement plaster, or painted underside of precast concrete structural floor planks.

2-2.3.2.5 Other requirements: Handicap accessible.

2-2.3.3 **Charge of Quarters (CQ) Station.** Provide one area, approximately 6.5 m<sup>2</sup> [70 sf].

2-2.3.3.1 Function: Reception area for visitors; duty desk for barracks manager.

2-2.3.3.2 Adjacency requirements: Adjacent to lobby and main entry. Locate to allow observation of lobby, main entry, public telephones, and common outdoor areas.

2-2.3.3.3 Furnishings/Fixtures/Equipment: Provide reception desk (built-in casework) minimum 2438 mm [8'-0"] long, to accommodate computer and monitor (not in contract), security system monitor, telephone, writing area. Provide built-in communication and power receptacles. Desk shall have minimum two legal size file drawers and one pencil drawer. All drawers shall have locks. Desk components shall have plastic laminate or stained wood finish. Work surfaces and counters shall be solid surfacing material or plastic laminate.

2-2.3.3.4 Finishes: Match entry lobby.

2-2.3.3.5 Other requirements: Handicap accessible.

2-2.3.4 **Main Stair.** Provide as required to allow circulation from lobby to all upper floors, and to comply with applicable code egress requirements. If allowable by applicable code, it is preferable to provide a main (monumental) stair that is open to the lobby.

2-2.3.4.1 Function: Central vertical circulation for the building. Means of egress if so designed.

2-2.3.4.2 Adjacency requirements: Adjacent to entry lobby. Connects all floors of the building.

2-2.3.4.3 Furnishings/Fixtures/Equipment (FFE): Stairs shall be steel construction with concrete-filled treads, or cast-in-place concrete construction. Open risers are prohibited. Provide decorative trim and detailing to integrate stair into lobby design. Provide metal railing or other guardrail system between open stair and adjacent spaces. Provide mechanical and electrical systems to comply with applicable codes.

2-2.3.4.4 Finishes: Landing floors: carpet (preferred), porcelain tile, quarry tile, or resilient tile. Base: porcelain tile, quarry tile, or resilient cove base.

Treads: carpet (preferred), porcelain tile, quarry tile, or resilient treads. Provide slip-resistant nosing if tile is used.

Risers: carpet (preferred), painted steel, porcelain tile, or quarry tile

Walls: impact resistant gypsum wallboard with vinyl wallcovering or painted finish; Prefinished or painted metal railings.

Ceiling: suspended acoustical panel ceiling, painted gypsum wallboard, painted veneer plaster, painted Portland cement plaster, or painted underside of precast concrete structural floor planks

2-2.3.4.5 Other requirements: Handicap accessible.

2-2.3.5 **Toilet Room.** Provide one.

2-2.3.5.1 Function: Private, handicap accessible toilet for use by visitors and CQ.

2-2.3.5.2 Adjacency requirements: Adjacent to entry lobby and CQ station.

2-2.3.5.3 Furnishings/Fixtures/Equipment: Floor mounted toilet; wall hung lavatory; recessed multifold paper towel dispenser/trash receptacle; two roll toilet tissue dispenser; sanitary napkin disposal; liquid soap dispenser; wall mounted mirror over lavatory; wall mounted grab bars at toilet.

2-2.3.5.4 Finishes:

Floor: Ceramic tile, or porcelain tile

Base: Ceramic tile, or porcelain tile

Walls: Ceramic tile, ceramic tile wainscot, or painted water-resistant gypsum wallboard

Ceiling: painted gypsum wallboard, painted veneer plaster, painted portland cement plaster, or painted underside of precast concrete structural floor planks.

2-2.3.5.5 Other requirements: Handicap accessible. Entry door shall have privacy function (F76) lockset.

2-2.3.6 **Janitor Closet.** Provide one on each floor of building. Minimum area 2.8 m<sup>2</sup> [30 sf] each.

2-2.3.6.1 Function: Sink, and storage of cleaning supplies.

2-2.3.6.2 Adjacency requirements: Near toilet room on first floor; preferred location on upper floors is adjacent to laundry areas.

2-2.3.6.3 Furnishings/Fixtures/Equipment: Provide floor mop sink, mop rack for three mops, and minimum 1829 linear mm of wall mounted stainless steel shelving.

2-2.3.6.4 Finishes:

Floor: ceramic tile, or sealed concrete

Base: resilient cove base, or ceramic tile base

Walls: painted water-resistant gypsum wallboard, or painted concrete masonry units

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted underside of precast concrete structural floor planks.

2-2.2.6.5 Other requirements: door shall have classroom function (f84) lockset.

2-2.3.7 **Vending Area.** Provide minimum one area on ground floor. Additional vending areas with ice machine-dispensers may be provided at upper floors as a proposed betterment over the minimum requirement. [If climate allows, consider the possibility of allowing vending machines and ice machine-dispensers to be located in securable outdoor areas. Ice dispensers may require card key type access control or coin operation if located in an unsupervised area.]

2-2.3.7.1 Function: Space for soft drink and snack vending machines, and ice machine-dispenser.

2-2.3.7.2 Adjacency requirements: Near entry lobby.

2-2.3.7.3 Furnishings/Fixtures/Equipment: Provide one ice cube machine-dispenser designed for hotel ice bucket filling, capable of producing minimum 250 lbs. of regular ice cubes in 24 hours, with 180 lb. storage capacity [Add requirement for room card type access or coin

operation of ice dispenser if desired]. Provide ice machine manufacturer's automatic cleaning system to clean and sanitize the water distribution system of the machine at scheduled intervals. Ice machine shall be Energy Star compliant. Design the space to accommodate four full-size soft drink and snack vending machines (government furnished, government installed). Vending machines will not require plumbing connections.

2-2.3.7.4 Finishes: Match entry lobby or adjacent corridor or breezeway.

2-2.3.7.5 Other requirements: First floor vending areas shall be handicap accessible. Provide floor drain near ice machines; locate drain outside of traffic area. If door is provided, door shall have classroom function (F84) lockset.

2-2.3.8 **Public Telephone Area.** Provide one. [If climate allows, consider the possibility of locating additional pay telephones in outdoor kiosks or phone booths. Require coordination of kiosk design with UEPH building design and the Installation Design Guide. Include applicable requirements of the IDG in this Statement of Work.]

2-2.3.8.1 Function: Pay telephones for barracks occupants and visitors.

2-2.3.8.2 Adjacency requirements: Near lobby and CQ station.

2-2.3.8.3 Furnishings/Fixtures/Equipment: Provide three pay telephones and telephone stations. Offeror shall contract with local telephone company or other telephone service provider to furnish and install pay telephones; rate charged for calls shall not exceed the average prevailing rate in the local off-post community. Each station will have divider panels to enhance acoustical privacy. Provide built-in seating at two stations; third station shall be wheelchair accessible. Provide capability to mount portable TDD at one station. Materials shall be vandal resistant and easily cleaned.

2-2.3.8.4 Finishes: Match entry lobby.

2-2.3.8.5 Other requirements: Handicap accessible.

2-2.3.9 **Mail Room.** Provide one. Room shall be sized to allow access to all rear-loading mailboxes and parcel lockers. Provide minimum 1829 mm [6'-0"] clear between back of mailboxes and any obstructions. To comply with force protection minimum standards, avoid routing key utilities (including communications, fire detection and alarm, water mains, etc.) through or on common walls to mail room.

2-2.3.9.1 Function: Secure area for sorting incoming mail and distributing to rear-loading mailboxes.

2-2.3.9.2 Adjacency requirements: Near CQ station and entry lobby. To comply with force protection minimum standards, locate mailroom on perimeter of building.

2-2.3.9.3 Furnishings/Fixtures/Equipment: Provide plastic laminate-faced sorting counter (built-in casework) 762 mm [2'-6"] deep x minimum 2438 mm [8'-0"] long x 914 mm [3'-0"] high. Provide United States Postal Service approved mailbox for each resident of the facility. Provide minimum of nine parcel lockers, and one outgoing mail collection box.

2-2.3.9.4 Finishes:

Floor: vinyl composition tile, or sealed concrete

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted underside of precast concrete structural floor planks.

2-2.3.9.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have mortise dormitory function (F13) lockset. Room shall be handicap accessible. Design shall comply with United States Postal Service regulations.

2-2.3.10 **Mailbox Access Area.** Provide an area from which residents may access mailboxes to pick up their mail. Access may be from a covered exterior area or from an interior lobby. Mailboxes will be loaded from the interior mail room.

2-2.3.10.1 Function: Mail pickup area for residents.

2-2.3.10.2 Adjacency requirements: Adjacent to mail room. Located on ground floor, near CQ station and entry lobby.

2-2.3.10.3 Furnishings/Fixtures/Equipment:

2-2.3.10.4 Finishes: Interior: match entry lobby. Exterior: refer to exterior building material requirements.

2-2.3.10.5 Other requirements: For exterior location provide minimum 1829 mm [6'-0"] of covered area in front of mailboxes (recess, building overhang, etc.) for weather protection; it is preferable to provide continuous covered area between mailbox access area and main entry. Provide adequate drainage at exterior areas.

2-2.3.11 **Laundry Area(s).** \1\ [Delete if washer and dryer is provided in each living unit. Garrison Commander has discretion to locate in each module, each floor, or each barracks.] /1/  
Provide one clothes washer per 12 residents, and 1.5 clothes dryers per washer (round fractional numbers to the next highest whole number). Provide minimum of one laundry room on each floor of the UEPH facility. Additional laundry rooms are acceptable; provide minimum four washers and six dryers in each room.

2-2.3.11.1 Function: Self-service washers and dryers and clothes folding areas for residents.

2-2.3.11.2 Adjacency requirements: Locate laundry rooms on exterior walls so dryers can be exhausted directly to exterior. Locate dryer exhaust wall caps away from operable windows. For noise considerations, it is preferable not to locate laundry rooms adjacent to living units (shared walls).

2-2.3.11.3 Furnishings/Fixtures/Equipment: Commercial quality clothes washers and dryers (each minimum 2.5 cubic feet capacity), non-coin operation. Stacked dryers are preferred. Appliances shall be Energy Star compliant. Provide one plastic laminate-faced table with clothes hanging rod (minimum table size: 1219 mm x 610 mm x 914 mm high [48" x 24" x 36" high]) per each four washers. Provide two vandal-resistant waiting chairs per each four washers. Provide space for one wall mounted laundry product vending machine in each laundry room (not in contract).

2-2.3.11.4 Finishes:

Floor: porcelain tile, quarry tile, or sealed concrete

Base: porcelain tile or quarry tile

Walls: painted water resistant gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: painted gypsum wallboard, painted veneer plaster, painted Portland cement plaster, or painted underside of precast concrete structural floor planks

2-2.3.11.5 Other requirements: Provide insulated glass storefront or sidelights at door to allow views into the room from the corridor. Conceal utilities from view, but provide easy maintenance access; locate utility connections 914 mm [36"] above finish floor, unless otherwise recommended by manufacturer. Provide one floor drain for every four washers; locate outside of traffic area. Provide direct straight-run venting of dryer exhaust. Partitions around laundry rooms shall have minimum STC of 45, and shall extend to underside of floor above. Provide 914 mm [3'-0"] wide door(s) into room. Doors shall have classroom function (F84) locksets (or exit devices if required by applicable code).

2-2.4 **UEPH Support Areas.** Support areas include circulation spaces such as stairs and corridors; mechanical, electrical, and communications spaces; boot wash facilities; and outdoor storage buildings. Spaces are as follows:

2-2.4.1 **Interior Corridor.** Provide as required to allow circulation to building spaces, and comply with applicable code egress requirements. Due to security, climate, and force protection concerns, interior corridors are the preferred means of circulation between living units and other building spaces.

2-2.4.1.1 Function: Circulation and means of egress.

2-2.4.1.2 Adjacency requirements: Adjacent to vertical circulation.

2-2.4.1.3 Furnishings/Fixtures/Equipment (FFE): Provide mechanical and electrical systems to comply with applicable codes. Provide fire extinguishers in semi-recessed fire extinguisher cabinets to comply with applicable codes.

2-2.4.1.4 Finishes:

Floor: porcelain tile, quarry tile, vinyl composition tile, or integrally stained concrete.

Base: porcelain tile, quarry tile, or resilient cove base.

Walls: impact resistant gypsum wallboard with vinyl wallcovering or painted finish.

Ceiling: suspended acoustical panel ceiling, painted gypsum wallboard, painted veneer plaster, painted Portland cement plaster, or painted underside of precast concrete structural floor planks.

2-2.4.1.5 Other requirements: Handicap accessible.

2-2.4.2 **Breezeway.** Refers to an unconditioned, covered corridor space that is enclosed on the long sides, but open to the exterior on the ends. Provide as required to allow circulation to building spaces and comply with applicable code egress requirements. Breezeways are an acceptable means of circulation between living units and other building spaces. [Edit as necessary to retain or delete use of breezeways. Breezeways are not recommended for very cold climates, nor where security and force protection are controlling issues.]

2-2.4.2.1 Function: Circulation and means of egress.

2-2.4.2.2 Adjacency requirements: Adjacent to vertical circulation.

2-2.4.2.3 Furnishings/Fixtures/Equipment (FFE): Provide mechanical and electrical systems to comply with applicable codes. Provide fire extinguishers in semi-recessed fire extinguisher cabinets to comply with applicable codes. All fixtures and equipment shall be suitable for exterior locations.

2-2.4.2.4 Finishes:

Floor: sealed concrete

Base: Exterior wall material

Walls: Exterior wall material

Ceiling: painted exterior gypsum soffit board, painted Portland cement plaster, or painted underside of precast concrete structural floor planks.

2-2.4.2.5 Other requirements: Handicap accessible. With the exception of fire sprinkler systems, no piping, conduit or ductwork shall be exposed in breezeway. Provide slip resistant finish texture on concrete floor.

2-2.4.3 **Exterior Corridor.** Refers to an unconditioned, covered circulation space that is enclosed on one long side (adjacent to the building), and has a guardrail on the other side. Provide as required to allow circulation to building spaces and comply with applicable code egress requirements. When breezeways are used to provide access to living units, exterior corridors may be provided to link breezeways with stairs and other circulation components. Exterior corridors shall not be used to provide access to living units [HQ guidance disallows entering a living unit from an exterior corridor (although breezeways are acceptable). Edit as necessary to retain or delete use of exterior corridors. Exterior corridors are not recommended for very cold climates, nor where security and force protection are controlling issues. Metal guardrails can create an additional maintenance concern.]

2-2.4.3.1 Function: Circulation and means of egress.

2-2.4.3.2 Adjacency requirements: Adjacent to vertical circulation.

2-2.4.3.3 Furnishings/Fixtures/Equipment (FFE): Provide mechanical and electrical systems to comply with applicable codes. Provide fire extinguishers in semi-recessed fire extinguisher cabinets to comply with applicable codes. All fixtures and equipment shall be suitable for exterior locations.

2-2.4.3.4 Finishes:

Floor: sealed concrete

Base: Exterior wall material

Walls: Exterior wall material

Ceiling: painted exterior gypsum soffit board, painted Portland cement plaster, or painted underside of concrete structure above

2-2.4.3.5 Other requirements: Handicap accessible. With the exception of fire sprinkler systems, no piping, conduit or ductwork shall be exposed in exterior corridor. Provide slip resistant finish texture on concrete floor. Guardrails shall be painted hot dip galvanized steel, or prefinished aluminum rail system designed in accordance with applicable codes.

2-2.4.4 **Interior Stairs.** Provide as required to allow circulation to upper floors of the building, and to comply with applicable code egress requirements. Due to security, climate, and force protection concerns, interior stairs are preferred over exterior stairs.

2-2.4.4.1 Function: Circulation and means of egress.

2-2.4.4.2 Adjacency requirements: Adjacent to corridors or breezeways. Connects all floors of the building.

2-2.4.4.3 Furnishings/Fixtures/Equipment (FFE): Stairs shall be steel construction with concrete-filled treads, or cast-in-place concrete construction. Open risers are prohibited. Provide mechanical and electrical systems to comply with applicable codes.

2-2.4.4.4 Finishes:

Landing floor: porcelain tile, quarry tile, resilient tile, vinyl composition tile, or sealed concrete.

Base: porcelain tile, quarry tile, or resilient cove base.

Treads: porcelain tile, quarry tile, resilient treads, or sealed concrete. Provide slip-resistant nosing if tile is used.

Risers: painted steel, porcelain tile, quarry tile, or sealed concrete.

Walls: painted impact resistant gypsum wallboard, or painted concrete masonry units.

Ceiling: suspended acoustical panel ceiling, painted gypsum wallboard, painted veneer plaster, painted Portland cement plaster, or painted underside of precast concrete structural floor planks

2-2.4.4.5 Other requirements: Stairs shall comply with handicap accessibility requirements of applicable codes. Railings shall be painted galvanized steel, or prefinished aluminum.

2-2.4.5 **Exterior Stairs.** Provide as required to allow circulation to upper floors of the building, and to comply with applicable code egress requirements. Due to security, climate, and force protection concerns, interior stairs are preferred over exterior stairs. Exterior stairs shall be covered.

2-2.4.5.1 Function: Circulation and means of egress.

2-2.4.5.2 Adjacency requirements: Adjacent to corridors or breezeways. Connects all floors of the building.

2-2.4.5.3 Furnishings/Fixtures/Equipment (FFE): Exterior stairs shall be cast-in-place concrete construction (preferred), or galvanized steel construction with concrete-filled treads. Open risers and metal grating treads are prohibited.

2-2.4.5.4 Finishes: Landing floor: sealed concrete with slip-resistant finish texture.

Base: none

Treads: Sealed concrete with slip-resistant finish texture. Provide slip-resistant nosing.

Risers: painted steel, or sealed concrete.

Walls: exterior wall materials

Ceiling: painted exterior gypsum soffit board, painted Portland cement plaster, or painted underside of concrete structure above

2-2.4.5.5 Other requirements: Stairs shall comply with handicap accessibility requirements of applicable codes. Railings shall be painted galvanized steel, or prefinished aluminum. Refer to Chapter 5 for hardware and security requirements for exterior doors.

2-2.4.6 **Mechanical Areas.** Provide dedicated interior spaces and exterior areas for plumbing, fire protection, and HVAC equipment. Size and locate rooms to allow equipment removal and maintenance Provide floor openings and vertical shaft spaces as necessary.

2-2.4.6.1 Function: Mechanical support spaces for the UEPH building.

2-2.4.6.2 Adjacency requirements: Locate main mechanical room on ground floor with doors opening to exterior. Mechanical support spaces shall not be used for storage or other purposes; access to mechanical spaces will be limited to authorized personnel. Locate exterior mechanical equipment and air intake and openings in exterior walls to comply with force protection standards. Do not locate mechanical equipment rooms adjacent to living units (shared walls).

2-2.4.6.3 Furnishings/Fixtures/Equipment: As required by Statement of Work.

2-2.4.6.4 Finishes:

Floor: sealed concrete

Base: resilient cove base, or none

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: none required

2-2.4.6.5 Other requirements: Locate air intake and exhaust openings to provide optimum indoor air quality. Roof mounted equipment shall not be used. Provide masonry screen walls with lockable metal access gates around outdoor equipment areas (refer to Chapter 3); comply with force protection standards. Doors shall have storeroom function (F86) locksets.

2-2.4.7 **Electrical Rooms.** Provide dedicated interior spaces and exterior areas for electrical equipment. Size and locate rooms to allow equipment removal and maintenance. Provide floor openings and vertical shaft spaces as necessary. Provide minimum of one electrical room per floor.

2-2.4.7.1 Function: Electrical support spaces for the UEPH building.

2-2.4.7.2 Adjacency requirements: Locate main electrical equipment room on ground floor. Electrical rooms on upper floors should be located to allow efficient distribution. Size and locate rooms to allow equipment removal and maintenance. Electrical rooms shall not be used for storage or other purposes; access to electrical rooms will be limited to authorized personnel. Locate exterior electrical equipment to comply with force protection standards.

2-2.4.7.3 Furnishings/Fixtures/Equipment: As required by Statement of Work.

2-2.4.7.4 Finishes:

Floor: sealed concrete

Base: resilient cove base, or none.

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: none required

2-2.4.7.5 Other requirements: Electrical service to the building shall be underground. Provide masonry screen walls with lockable metal access gates around outdoor equipment (refer to Chapter 3); it is preferable to locate transformer within the screened mechanical equipment area. Comply with force protection standards. Door shall have storeroom function (F86) lockset.

2-2.4.8 **Communication Rooms.** Provide dedicated interior rooms for communication

equipment. Size and locate rooms to allow equipment removal and maintenance; room area shall be minimum of 1.1 % of the building area served, however, minimum dimensions for each communication room shall be 2134 mm x 3048 mm [7'-0" x 10'-0"]. Provide minimum of one communication room per floor.

2-2.4.8.1 Function: Telephone and data network support spaces for the UEPH building.

2-2.4.8.2 Adjacency requirements: Locate to allow efficient distribution. Communication rooms on upper floors shall be vertically stacked above each other. Communication rooms shall not be used for storage or other purposes; access will be limited to authorized personnel.

2-2.4.8.3 Furnishings/Fixtures/Equipment: As required by Statement of Work.

2-2.4.8.4 Finishes:

Floor: vinyl composition tile

Base: resilient cove base, or none.

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: painted gypsum wallboard, painted veneer plaster, or suspended acoustical panel ceiling, or painted underside of concrete structure above

2-2.4.8.5 Other requirements: Communication service to the building shall be underground. Provide minimum 914 mm [3'-0"] wide door with storeroom function (F86) lockset. Provide floor openings and vertical shaft spaces as necessary. Provide a minimum of three 102 mm [4"] diameter empty conduits between vertically stacked communication rooms.

2-2.4.9 **Boot Wash Areas.** Provide paved exterior boot wash area at each entrance to the UEPH building. Design area for use by one soldier at a time.

2-2.4.9.1 Function: Exterior area for washing footgear prior to entering building.

2-2.4.9.2 Adjacency requirements: Locate on ground floor, adjacent to each entrance to the UEPH building.

2-2.4.9.3 Furnishings/Fixtures/Equipment: Provide drainage assembly: Removable 914 mm x 914 mm aluminum or stainless steel grating, with non-slip surface, supported by concrete storm drainage inlet box. Box shall be filled with stone and filter material to trap sediment. Filtered runoff shall be piped to storm drainage system. Provide freeze-proof wall hydrant with aerator nozzle mounted approximately 400 mm above grating, control valve mounted at 800 mm above pavement. Provide 3'-0" long metal grab bar above control valve, mounted at 1067 mm above pavement. Top of grating and concrete structure shall align with adjacent concrete sidewalk. Provide concrete sidewalk between boot wash area and entrance sidewalk.

2-2.4.9.4 Finishes: refer to exterior building material requirements.

2-2.4.9.5 Other requirements: Provide adequate drainage away from building.

2-2.4.10 **Outside Storage Building.** Provide one separate, enclosed, weatherproof storage building, minimum 6 m<sup>2</sup> [65 sf]. [If consistent with requirements of IDG, prefabricated storage building may be used in lieu of site-constructed storage building. If this option is added, revise building material requirements below.]

2-2.4.10.1 Function: Storage for the following items (not in contract): lawn mowers, landscape maintenance equipment, snow removal equipment, tools, and one flammable storage cabinet for storing maximum of one five-gallon safety can of gasoline, and twelve one-quart containers of motor oil.

2-2.4.10.2 Adjacency requirements: Locate remote from UEPH and other occupied buildings. It is preferable to locate the storage building adjacent to the trash dumpster area. Comply with building code setback requirements. Provide minimum force protection setback of 24.4 meters [80 feet] to UEPH buildings and any other inhabited buildings.

2-2.4.10.3 Furnishings/Fixtures/Equipment: Provide one interior light fixture with safety cage, controlled by occupancy sensor switch. No electrical receptacles shall be provided.

2-2.4.10.4 Building materials: Floor: sealed concrete slab on grade.

Exterior wall material: Masonry to match materials used on masonry screen walls.

Structure: Non-combustible materials. Fire-retardant wood or plywood shall not be used.

Roofing: match roof of UEPH building.

Interior wall finish: painted impact resistant gypsum wallboard or painted concrete masonry units.

Ceiling: painted exposed structure.

2-2.4.10.5 Other requirements: Provide wall louvers to allow natural cross-ventilation. Roof penetrations are not acceptable. Provide hollow metal door and frame with storeroom function (F86) lockset. Comply with NFPA 30 requirements for storage of flammable materials. Provide minimum 1219 mm [4'-0"] wide sidewalk from entry door to adjacent pavement or sidewalk. Provide bracket-mounted fire extinguisher.

### **2-3 COMPANY OPERATIONS FACILITIES FUNCTIONAL AND AREA**

**REQUIREMENTS.** The company operations facilities (COF) building(s) shall consist of administrative areas and supply areas for each company, support spaces, and common locker/shower facilities. 11-16 personnel will staff each COF. Provide facilities for [ ] large companies, [ ] medium companies, and [ ] small companies. Net areas of administrative spaces are the same for each size company; net areas of supply spaces and locker/shower facilities vary with company size. Total gross area of each size COF shall not exceed the following: Large company 1094 m<sup>2</sup> [11,776 sf]; medium company 857 m<sup>2</sup> [9,227 sf]; small company 722 m<sup>2</sup> [7,770 sf]. Total gross building area of all COF buildings shall not exceed [ ] m<sup>2</sup> [ ] sf [Maximum gross area shall be as shown on form DD 1391]. Facilities may comprise a single building or multiple buildings. Buildings may be one or two stories in height. In a two-story configuration, supply and locker/shower areas shall be located on the first floor; administrative functions may be located on the second floor. An elevator is not required. Grouping multiple COF's in one building is encouraged, however, each company must function independently, and must be secured from other COFs. Provide separate exterior entrances to the administrative and supply areas of each COF. Common mechanical rooms may be used, but mechanical and electrical systems must provide each company with independent operation and control. Locker/shower spaces may be combined and shared by all companies in a building, or combined locker/shower spaces may be located in a separate building. To the greatest extent possible, buildings shall be arranged to allow future reconfiguration of company sizes (for example, changes in mission may require the conversion of a building housing two large companies and one medium company into a building housing four small companies. In this example, an addition would be constructed to house the administrative functions of the fourth company, and supply areas originally designed for three companies could be

reconfigured for four small companies). COF functions and areas shall be as follows:

2-3.1 **COF Administrative Areas.** Provide one group of administrative areas per company. Company leadership will manage the organization, receive visitors, and conduct day-to-day business from the COF administrative areas. Provide an easily identified, covered entrance. Entrance shall be separate and distinct from the entrances to company supply areas and to other COF administrative areas. Exterior wall space above or adjacent to the entrance will be used to display company identification signage. Provide interior circulation to company supply areas. Military personnel will staff the facility; military and non-military personnel will visit the administrative areas to meet with leadership or attend meetings in the conference room. Although only able-bodied military personnel will be on staff, all administrative spaces except private shower rooms shall comply with UFAS and ADA requirements (this requirement applies whether administrative spaces are located on first or second floor). Provide the following areas for each company:

2-3.1.1 **Company Commander (CO).** Provide one; 13.9 m<sup>2</sup> [150 sf]. Room shall be accessed through the Admin Office. Occupants: 1, and occasional visitors.

2-3.1.1.1 Function: Private office for commanding officer.

2-3.1.1.2 Adjacency requirements: Adjacent to Admin Office; near XO, 1<sup>st</sup> SGT, and Training Office.

2-3.1.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one conference table [\_\_\_\_], four side chairs, and one desk chair.

2-3.1.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-3.1.1.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-3.1.2 **Executive Officer (XO).** Provide one; 9.3 m<sup>2</sup> [100 sf]. Room shall be accessed through the Admin Office. Occupants: 1, and occasional visitors.

2-3.1.2.1 Function: Private office for the company executive officer.

2-3.1.2.2 Adjacency requirements: Adjacent to Admin Office; near CO, 1 SGT, and Training Office.

2-3.1.2.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one side chair and one desk chair. Provide a floor anchor for one GFGI security safe, approximate dimensions [\_\_\_\_], weight [\_\_\_\_]. Coordinate anchor location with furniture layout; refer to paragraph 5-6.4.

2-3.1.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-3.1.2.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-3.1.3 **First Sergeant (1 SGT)**. Provide one; 11.25 m<sup>2</sup> [120 sf]. Room shall be accessed through the Admin Office. Occupants: 1, and occasional visitors.

2-3.1.3.1 Function: Private office for the company first sergeant (highest ranking non-commissioned officer).

2-3.1.3.2 Adjacency requirements: Adjacent to Admin Office; near CO, XO, and Training Office.

2-3.1.3.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [ ] with return [ ], one bookcase [ ], two legal-size four-drawer file cabinets, two side chairs and one desk chair. Provide a floor anchor for one GFGI security safe, approximate dimensions [ ], weight [ ]. Coordinate anchor location with furniture layout; refer to paragraph 5-6.4.

2-3.1.3.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-3.1.4 **Training Officer**. Provide one; 9.3 m<sup>2</sup> [100 sf]. Room shall be accessed through the Admin Office. Occupants: 1, and occasional visitors.

2-3.1.4.1 Function: Private office for the company Training Officer.

2-3.1.4.2 Adjacency requirements: Adjacent to Admin Office; near CO, XO, and 1 SGT.

2-3.1.4.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [ ] with return [ ], one bookcase [ ], two legal-size four-drawer file cabinets, two side chairs and one desk chair. Provide a floor anchor for one GFGI security safe, approximate dimensions [ ], weight [ ]. Coordinate anchor location with furniture layout; refer to paragraph 5-6.4.

2-3.1.4.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster  
Ceiling: suspended acoustical panel ceiling

2-3.1.4.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Exterior window is desirable. Partitions shall have minimum STC rating of 55.

2-3.1.5 **Admin Office.** Provide one area; minimum 35.3 m<sup>2</sup> [380 sf], including interior circulation. Room shall be accessed through the Waiting Area. Occupants: 2 clerks, and occasional visitors.

2-3.1.5.1 Function: Office for company administrative clerks, storage of files, access to private offices. Clerks will have visual control of waiting area and conference room door.

2-3.1.5.2 Adjacency requirements: Adjacent to Waiting Area; CO, XO, 1 SGT, and Training Office. Adjacent to or near Conference Room. Near main entrance to Administrative Area.

2-3.1.5.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate [ ] clerk desks [ ] with returns [ ] and desk chairs, [insert info on other required furnishings]. Provide reception desk (built-in casework) minimum 1829 mm [6'-0"] long separating the Admin Office from the Waiting Area. The counter on the Waiting Area side shall be 1016 mm high x 305 mm deep [If user desires a method of securing Admin Office from Waiting Area, add requirement for overhead coiling grille or sliding pass-through window above counter]. Admin side of reception desk shall be at desk height, and shall accommodate computer and monitor (not in contract), and writing area. Provide built-in communication and power receptacles or grommets in desk top to access wall receptacles. Desk shall have knee space and minimum two cabinets with hinged doors, and two drawers. Drawers and cabinets shall have keyed locks. Desk components shall have plastic laminate or stained wood finish. Provide a floor anchor for one GFGI security safe, approximate dimensions [ ], weight [ ]. Coordinate anchor location with furniture layout; refer to paragraph 5-6.4.

2-3.1.5.4 Finishes:

Floor: carpet or vinyl composition tile

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-3.1.5.5 Other requirements: Provide 914 mm [3'-0"] wide entry door into room from Waiting Area; door shall have entry function (F81) lockset. Exterior window is desirable.

2-3.1.6 **Admin Storage.** Provide one; minimum area 3.3 m<sup>2</sup> [35 sf]. Room shall be accessed from the Admin Office.

2-3.1.6.1 Function: Closet for storage of supplies, paper, etc.

2-3.1.6.2 Adjacency requirements: Adjacent to Admin Office.

2-3.1.6.3 Furnishings/Fixtures/Equipment:

2-3.1.6.4 Finishes:

Floor: carpet or vinyl composition tile

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling, painted gypsum wallboard, or painted veneer plaster.

2-3.1.6.5 Other requirements: Door(s) shall have classroom function (F84) lockset.

2-3.1.7 **Administrative Area Corridor.** Provide as required to allow circulation to building spaces, and comply with applicable code egress requirements. Unless otherwise required, minimum corridor width shall be 1829 mm [6'-0"]. Administrative area corridor shall be capable of being secured from exterior entrances and from any adjacent public, unsecure corridors.

2-3.1.7.1 Function: Circulation and means of egress.

2-3.1.7.2 Adjacency requirements: Adjacent to entry vestibule, and vertical circulation (where occurs). Corridor(s) shall provide access to administrative area spaces and shall provide circulation between administrative spaces and supply spaces. Corridor may directly link a company's administrative area to its supply area; or the company's administrative area corridor may provide access to a public, unsecure corridor that provides access to the supply areas of all companies in the building.

2-3.1.7.3 Furnishings/Fixtures/Equipment (FFE): Provide one handicap accessible electric water cooler. Provide fire extinguishers in semi-recessed fire extinguisher cabinets to comply with applicable codes.

2-3.1.7.4 Finishes:

Floor: porcelain tile, quarry tile, or vinyl composition tile.

Base: porcelain tile, quarry tile, or resilient cove base.

Walls: impact resistant gypsum wallboard with painted finish.

Ceiling: suspended acoustical panel ceiling, painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster.

2-3.1.7.5 Other requirements: [Add security and locking requirements for corridor doors].

2-3.1.8 **Waiting Area.** Provide one area, approximately 10.2 m<sup>2</sup> [110 sf] incorporated into the Administrative Area Corridor. Occupants: Two or more visitors; additional visitors (e.g. those waiting to attend a large meeting in the conference room) will wait in the adjacent corridor.

2-3.1.8.1 Function: Waiting and reception area for company soldiers and visitors. Control point for access to admin office and conference room.

2-3.1.8.2 Adjacency requirements: Adjacent to, or very close to, entry vestibule; reception desk should be easily seen by visitors entering the building. Waiting Area is open to Administrative Area Corridor.

2-3.1.8.3 Furnishings/Fixtures/Equipment (FFE): Provide two side chairs [verify seating requirement with user]. Provide one 1219 mm high x 1829 mm wide [4'-0" x 6'-0"] wall mounted bulletin board.

2-3.1.8.4 Finishes: Match Administrative Area Corridor.

2-3.1.8.5 Other requirements:

2-3.1.9 **Entry Vestibule.** Provide at main exterior entrance to Administrative Area Corridor. [If climate dictates, revise this sentence to require vestibules at all entrances to the building.]

2-3.1.9.1 Function: Primary entry point into the COF; weather protection for interior spaces.

2-3.1.9.2 Adjacency requirements: Adjacent to Administrative Area Corridor.

2-3.1.9.3 Furnishings/Fixtures/Equipment:

2-3.1.9.4 Finishes:

Floor: Provide recessed entry mat full depth of vestibule x full width of doors; porcelain tile, or quarry tile in remainder of room.

Base: porcelain tile or quarry tile

Walls: Match exterior wall finish material (preferred), or painted impact resistant gypsum wallboard, or painted veneer plaster

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster.

2-3.1.9.5 Other requirements: Provide aluminum storefront entrance doors on exterior and corridor sides of vestibule. Additional aluminum storefront area (sidelights, transoms) is desirable. Provide minimum 1829 mm [6'-0"] deep exterior covered area (entry porch) full width of storefront. Provide location for company identification signage on exterior wall above or adjacent to entrance.

2-3.1.10 **Platoon Office.** Provide four; each 9.3 m<sup>2</sup> [100 sf]. Offices shall be accessed directly from the Administrative Area Corridor, or through a common space that is accessed from the Administrative Area Corridor. Occupants: 1 in each office, and occasional visitors.

2-3.1.10.1 Function: Private office for platoon leaders or other administrators.

2-3.1.10.2 Adjacency requirements: Adjacent to Administrative Area Corridor. Near Admin Office.

2-3.1.10.3 Furnishings/Fixtures/Equipment: Provide and design each office to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one side chair and one desk chair [Coordinate additional furniture requirements with user].

2-3.1.10.4 Finishes:

Floor: vinyl composition tile

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-3.1.10.5 Other requirements: Exterior window is desirable but not required. Partitions shall have minimum STC rating of 49.

2-3.1.11 **Conference Room.** Provide one; 33.5 m<sup>2</sup> [360 sf]. Room shall be accessed from the Waiting Area (preferable), or through the Admin Office. Admin clerks shall have visual control of Conference Room door. Occupants: up to 22 persons.

2-3.1.11.1 Function: Conference room for company leadership, staff, and visitors. Functions will

include staff meetings, hearings, disciplinary sessions, training.

2-3.1.11.2 Adjacency requirements: Adjacent to Admin Office or Waiting Area.

2-3.1.11.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate Coordinate furniture requirements with user. Provide one marker board (minimum 2438 mm wide x 1219 mm high [8'-0" x 4'-0"]) and one 2438 mm wide [8'-0"] wall mounted pull-down projection screen.

2-3.1.11.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-3.1.11.5 Other requirements: Door shall have classroom function (F84) lockset. Partitions shall have minimum STC rating of 55.

2-3.1.12 **Conference Room Storage.** Provide one; minimum area 3.3 m<sup>2</sup> [35 sf]. Room shall be accessed from the Conference Room.

2-3.1.12.1 Function: Closet for storage of folding tables, display easels, etc.

2-3.1.12.2 Adjacency requirements: Adjacent to Conference Room.

2-3.1.12.3 Furnishings/Fixtures/Equipment:

2-3.1.12.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling, painted gypsum wallboard, or painted veneer plaster

2-3.1.12.5 Other requirements: Door(s) shall have classroom function (F84) lockset.

2-3.1.13 **Men's Toilet.** Provide one private toilet room. Room shall be sized to comply with handicap accessibility requirements. Room shall be accessed from Administrative Area Corridor.

2-3.1.13.1 Function: Men's single-occupant toilet and lavatory, for use by staff and visitors.

2-3.1.13.2 Adjacency requirements: Adjacent to Administrative Area Corridor. Near Shower rooms and Women's Toilet.

2-3.1.13.3 Furnishings/Fixtures/Equipment (FFE): Provide one floor mounted toilet, one wall-hung lavatory, mirror with shelf above lavatory, Paper towel dispenser/waste receptacle, soap dispenser, toilet tissue dispenser, and wall mounted grab bars at toilet.

2-3.1.13.4 Finishes:

Floor: porcelain tile, or ceramic tile.

Base: porcelain tile, or ceramic tile.

Walls: ceramic tile

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster.

2-3.1.13.5 Other requirements: Door shall have privacy function (F76) lockset. Partitions shall have minimum STC rating of 49.

2-3.1.14 **Women's Toilet.** Provide one private toilet room. Room shall be sized to comply with handicap accessibility requirements. Room shall be accessed from Administrative Area Corridor.

2-3.1.14.1 Function: Women's single-occupant toilet and lavatory, for use by staff and visitors.

2-3.1.14.2 Adjacency requirements: Adjacent to Administrative Area Corridor. Near Shower rooms and Men's Toilet.

2-3.1.14.3 Furnishings/Fixtures/Equipment (FFE): Provide one floor mounted toilet, one wall-hung lavatory, mirror with shelf above lavatory, Paper towel dispenser/waste receptacle, soap dispenser, sanitary napkin disposal, toilet tissue dispenser, and wall mounted grab bars at toilet.

2-3.1.14.4 Finishes:

Floor: porcelain tile, or ceramic tile.

Base: porcelain tile, or ceramic tile.

Walls: ceramic tile

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster.

2-3.1.14.5 Other requirements: Door shall have privacy function (F76) lockset. Partitions shall have minimum STC rating of 49.

2-3.1.15 **Shower Room.** Provide two. Rooms shall be used by able-bodied military personnel only. Rooms shall be accessed from Administrative Area Corridor. Shower room shall not be combined with toilet rooms.

2-3.1.15.1 Function: Private shower and dressing room for use by company leadership after physical training.

2-3.1.15.2 Adjacency requirements: Adjacent to Administrative Area Corridor. Near toilets.

2-3.1.15.3 Furnishings/Fixtures/Equipment (FFE): Provide one ceramic tile shower with rod and shower curtain. Shower shall have ceramic soap holder and wall mounted grab bar. Dressing area shall have bench, four towel/robe hooks, and wall mounted full-length mirror. Provide floor drain at dressing area, locate outside of circulation path.

2-3.1.15.4 Finishes:

Floor: ceramic tile.

Base: ceramic tile.

Walls: ceramic tile

Ceiling: painted Portland cement plaster.

2-3.1.15.5 Other requirements: Door shall have privacy function (F76) lockset.

2-3.1.16 **Janitor Closet.** Provide one. Minimum area 2.8 m<sup>2</sup> [30 sf]. Room shall be

accessed from Administrative Area Corridor.

2-3.1.16.1 Function: Sink and storage of cleaning supplies, soap, and paper products.

2-3.1.16.2 Adjacency requirements: Adjacent to Administrative Area Corridor. Near Shower rooms and toilets.

2-3.1.16.3 Furnishings/Fixtures/Equipment (FFE): Provide one floor mounted mop sink, mop rack for three mops, and minimum 1524 linear mm of wall mounted stainless steel shelving.

2-3.1.16.4 Finishes:

Floor: ceramic tile, or sealed concrete

Base: ceramic tile base or resilient cove base

Walls: painted water-resistant gypsum wallboard, or painted concrete masonry units

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster

2-3.1.16.5 Other requirements: Door shall have classroom function (F84) lockset.

2-3.1.17 **Communication Room.** Provide dedicated interior room(s) for communication distribution equipment. Room(s) shall be dedicated to one company, and shall not be combined with mechanical or electrical rooms. Room(s) may be accessed from Administrative Area Corridor, public unsecure corridor (if provided), or Equipment Maintenance Area. Access will be limited to authorized personnel. Provide each company with one main communication room; minimum size 3048 mm [10'-0"] x 3353 mm [11'-0"]. In two-story buildings, the communication room shall be located on the second floor. Provide additional communication rooms as needed; all spaces having telephone or computer data outlets shall be located to allow a maximum cable length of 90 m [295 feet] between outlet and communication room. Minimum dimensions of secondary communication rooms shall be 2134 mm [7'-0"] x 3048 mm [10'-0"]. Provide floor openings and vertical shaft spaces as necessary.

2-3.1.17.1 Function: Telephone and data network support spaces for the COF.

2-3.1.17.2 Adjacency requirements: Locate to allow efficient distribution. Communication rooms shall not be used for storage or other purposes; access will be limited to authorized personnel.

2-3.1.17.3 Furnishings/Fixtures/Equipment: As required by Statement of Work.

2-3.1.17.4 Finishes: Floor: vinyl composition tile

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: painted gypsum wallboard, painted veneer plaster, or suspended acoustical panel ceiling

2-3.1.17.5 Other requirements: Door shall have minimum 914 mm [3'-0"] wide door with storeroom function (F86) lockset.

2-3.3.1 **Boot Wash Areas.** Provide paved exterior boot wash area at each exterior entrance to the COF Administrative Area. Design area for use by one soldier at a time.

2-3.3.1.1 Function: Exterior area for washing footgear prior to entering building.

2-3.3.1.2 Adjacency requirements: Locate on ground floor, adjacent to entrance.

2-3.3.1.3 Furnishings/Fixtures/Equipment: Provide drainage assembly: Removable 914 mm x 914 mm aluminum or stainless steel grating, with non-slip surface, supported by concrete storm drainage inlet box. Box shall be filled with stone and filter material to trap sediment. Filtered runoff shall be piped to storm drainage system. Provide freeze-proof wall hydrant with aerator nozzle mounted approximately 400 mm above grating, control valve mounted at 800 mm above pavement. Provide 3'-0" long metal grab bar above control valve, mounted at 1067 mm above pavement. Top of grating and concrete structure shall align with adjacent concrete sidewalk. Provide concrete sidewalk between boot wash area and entrance sidewalk.

2-3.3.1.4 Finishes: refer to exterior building material requirements.

2-3.1.18 Other requirements: Provide adequate drainage away from building.

2-3.2 **COF Supply Areas.** Provide one group of supply areas per company; locate on the ground floor. COF supply areas will be used to store, clean, and repair company operational equipment and weapons. Individual TA-50 gear lockers shall be provided for approximately 30 percent of the company soldiers. Main entrance to supply areas will be from paved service area; service area will be used for loading company equipment on and off of large trucks. Entrance shall be separate and distinct from the entrances to company administrative areas and to other COF supply areas. Exterior wall space above or adjacent to the entrance will be used to display company identification signage. Provide interior circulation to company administrative areas. Only able-bodied military personnel will occupy COF supply areas; handicapped accessibility is not required. Wire mesh partitions shall be used to separate storage areas from each other and from Equipment Maintenance Area. Provide the following areas for each company:

2-3.2.1 **Equipment Maintenance Area.** Provide one area. Minimum area: Large company 123 m<sup>2</sup> [1,325 sf]; Medium company 102.7 m<sup>2</sup> [1,105 sf]; Small company 54.8 m<sup>2</sup> [590 sf]. Main exterior entry shall open to paved service yard. Provide interior access from COF administrative area via administrative area corridor, stairs, or public unsecure corridor connecting other COFs in the building.

2-3.2.1.1 Function: Equipment cleaning, repair and access to COF storage spaces.

2-3.2.1.2 Adjacency requirements: Adjacent to exterior paved area for loading equipment on large vehicles. Adjacent to Arms Vault, TA-50 Lockers, and storage spaces. Adjacent to, or near Administrative Area.

2-3.2.1.3 Furnishings/Fixtures/Equipment: Provide stainless steel equipment cleaning sinks 711 mm x 711 mm x 172 mm deep [28" x 28" x 6 3/4"], (three sinks for large and medium companies, two sinks for small companies), locate near exterior doors. Provide fire extinguishers in semi-recessed fire extinguisher cabinets to comply with applicable codes. [Add requirements for shelving].

2-3.2.1.4 Finishes:

Floor: sealed concrete

Base: resilient cove base

Walls: painted impact resistant gypsum wallboard or painted concrete masonry units at exterior walls and walls separating COFs. Painted concrete walls will separate Arms Storage from Equipment Maintenance. Wire mesh partitions will separate storage areas from Equipment Maintenance.

Ceiling: painted exposed structure.

2-3.2.1.5 Other requirements: Provide an uncovered mud removal area for equipment cleaning outside of the building at the paved service yard, near the Equipment Maintenance Area. This area will consist of freeze-proof hose bibbs mounted [\_\_\_mm above] a concrete slab with a removable non-slip grate cover. The slab should be designed to allow water to drain to the storm drainage system, and allow easy collection and disposal of mud removed during the cleaning process. Provide the following number of hose bibbs: 16 for large company; 10 for medium company; 6 for small company. Provide a pair of 914 mm wide hollow metal doors opening onto the paved service yard; doors shall have hold open devices. All entry doors into Equipment Maintenance Area shall have entry function (F82) locksets with auxiliary deadlocks (thumb turn inside, keyed cylinder outside), or function F08 exit devices (if exit devices are required by code).

2-3.2.2 **Arms Vault.** Provide one. Area: Large company 44.13 m<sup>2</sup> [475 sf] [edit if large company requires larger vault]; Medium company 33 m<sup>2</sup> [355 sf]; Small company 33 m<sup>2</sup> [355 sf]. Construction of Arms Vault shall comply with paragraph 5-6.2. Room shall be accessed from Equipment Maintenance area. Occupants:[insert number].

2-3.2.2.1 Function: Storage and issue of weapons. **[Important ! Verify the contents of each Arms Vault with users. This model SOW is written based on the assumption that ammunition will not be stored in the vaults. If ammunition or other explosives are to be stored, stringent High-Hazard occupancy Group H-1 requirements of the International Building Code will apply. Coordinate with the authority having jurisdiction prior to issuance of the RFP.]**.

2-3.2.2.2 Adjacency requirements: Adjacent to Equipment Maintenance Area

2-3.2.2.3 Furnishings/Fixtures/Equipment: Provide arms rack anchor rings on all walls inside Arms Vault; refer to paragraph 5-6.2.5. Arms racks are not in contract.

2-3.2.2.4 Finishes:

Floor: sealed concrete

Base: none.

Walls: painted concrete

Ceiling: painted concrete.

2-3.2.2.5 Other requirements: [Add requirement for dehumidifier if necessary]

2-3.2.3 **Unit Storage.** Provide one area. Minimum area: Large company 85 m<sup>2</sup> [915 sf]; Medium company 58.1 m<sup>2</sup> [625 sf]; Small company 25.1 m<sup>2</sup> [270 sf]. Exterior entry shall open to paved service yard. Provide access from Equipment Maintenance Area and from exterior service yard.

2-3.2.3.1 Function: Storage of [insert contents of room]

2-3.2.3.2 Adjacency requirements: Adjacent to exterior paved area for loading equipment on large vehicles. Adjacent to Equipment Maintenance Area.

2-3.2.3.3 Furnishings/Fixtures/Equipment: [add requirements for shelving].

2-3.2.3.4 Finishes:

Floor: sealed concrete

Base: resilient cove base

Walls: Wire mesh partitions will separate Unit Storage area from Equipment Maintenance and adjacent storage areas within the COF. Provide painted impact resistant gypsum wallboard, or painted concrete masonry units at exterior walls and walls separating Unit Storage from adjacent COFs.

Ceiling: painted exposed structure, or wire mesh.

2-3.2.3.5 Other requirements: Provide a pair of 914 mm wide hollow metal doors opening onto the paved service yard; doors shall have hold open devices and entry function (F82) locksets with auxiliary deadlocks (thumb turn inside, keyed cylinder outside), or function F08 exit devices (if exit devices are required by code). Provide 914 mm [3'-0"] wide swinging door with keyed cylinder lock in wire mesh partition at Equipment Storage. Provide wire mesh ceiling or extend wire mesh partitions to underside of structure above.

2-3.2.4 **General Storage.** Provide one area. Minimum area: Large company 33 m<sup>2</sup> [355 sf]; Medium company 26 m<sup>2</sup> [280 sf]; Small company 14.9 m<sup>2</sup> [160 sf]. Provide access from Equipment Maintenance Area.

2-3.2.4.1 Function: Storage of [ ]

2-3.2.4.2 Adjacency requirements: Adjacent to Equipment Maintenance Area.

2-3.2.4.3 Furnishings/Fixtures/Equipment: [add requirements for shelving].

2-3.2.4.4 Finishes:

Floor: sealed concrete

Base: resilient cove base

Walls: Wire mesh partitions will separate General Storage area from Equipment Maintenance and adjacent storage areas within the COF. Provide painted impact resistant gypsum wallboard, or painted concrete masonry units at exterior walls and walls separating General Storage from adjacent COFs.

Ceiling: painted exposed structure, or wire mesh.

2-3.2.4.5 Other requirements: Provide 914 mm [3'-0"] wide swinging door with keyed cylinder lock in wire mesh partition at Equipment Storage. Provide wire mesh ceiling or extend wire mesh partitions to underside of structure above.

2-3.2.5 **Nuclear, Biological and Chemical Equipment (NBC) Storage.** Provide one area. Minimum area: Large company 15.8 m<sup>2</sup> [170 sf]; Medium company 13 m<sup>2</sup> [140 sf]; Small company 11.2 m<sup>2</sup> [120 sf]. Provide access from Equipment Maintenance Area.

2-3.2.5.1 Function: Storage of equipment for use in defense of nuclear, biological or chemical warfare.

2-3.2.5.2 Adjacency requirements: Adjacent to Equipment Maintenance Area.

2-3.2.5.3 Furnishings/Fixtures/Equipment: [add requirements for shelving].

2-3.2.5.4 Finishes:

Floor: sealed concrete

Base: resilient cove base

Walls: Wire mesh partitions will separate NBC Storage area from Equipment Maintenance and adjacent storage areas within the COF. Provide painted impact resistant gypsum wallboard, or painted concrete masonry units at exterior walls and walls separating NBC Storage from adjacent COFs.

Ceiling: painted exposed structure, or wire mesh.

2-3.2.5.5 Other requirements: Provide 914 mm [3'-0"] wide swinging door with keyed cylinder lock in wire mesh partition at Equipment Storage. Provide wire mesh ceiling or extend wire mesh partitions to underside of structure above.

2-3.2.6 **Communications Storage.** Provide one area. Minimum area: Large company 15.8 m<sup>2</sup> [170 sf]; Medium company 14 m<sup>2</sup> [150 sf]; Small company 11.15 m<sup>2</sup> [120 sf]. Provide access from Equipment Maintenance Area.

2-3.2.6.1 Function: Storage of radios and communications field gear.

2-3.2.6.2 Adjacency requirements: Adjacent to Equipment Maintenance Area.

2-3.2.6.3 Furnishings/Fixtures/Equipment: [add requirements for shelving].

2-3.2.6.4 Finishes:

Floor: sealed concrete

Base: resilient cove base

Walls: Wire mesh partitions will separate Communications Storage area from Equipment Maintenance and adjacent storage areas within the COF. Provide painted impact resistant gypsum wallboard, or painted concrete masonry units at exterior walls and walls separating Communications Storage from adjacent COFs.

Ceiling: painted exposed structure, or wire mesh.

2-3.2.6.5 Other requirements: Provide 914 mm [3'-0"] wide swinging door with keyed cylinder lock in wire mesh partition at Equipment Storage. Provide wire mesh ceiling or extend wire mesh partitions to underside of structure above.

2-3.2.7 **TA-50 Storage.** Provide one area. Size and configure area to accommodate the following quantity of TA-50 lockers per company (allow minimum 2438 mm [8'-0"] clearance between parallel rows of lockers; minimum 914 mm [3'-0"] between open locker doors and obstructions): Large company 96 lockers (approximately 136.4 m<sup>2</sup> [1,468 sf]); Medium company 49 lockers (approximately 71.2 m<sup>2</sup> [766 sf]); Small company 30 lockers (approximately 41.3 m<sup>2</sup> [444 sf]). Provide access from Equipment Maintenance Area. Provide additional exit as required by applicable codes.

2-3.2.7.1 Function: Gear lockers for storage of individual soldier's TA-50 field gear.

2-3.2.7.2 Adjacency requirements: Adjacent to Equipment Maintenance Area.

2-3.2.7.3 Furnishings/Fixtures/Equipment: Provide TA-50 gear lockers; refer to paragraph \_\_\_\_\_.

2-3.2.7.4 Finishes:

Floor: sealed concrete

Base: resilient cove base, or none.

Walls: Wire mesh partitions will separate TA-50 Storage area from Equipment Maintenance and

adjacent storage areas within the COF. Provide painted impact resistant gypsum wallboard, or painted concrete masonry units at exterior walls and walls separating TA-50 Storage from adjacent COFs.

Ceiling: painted exposed structure, or wire mesh.

2-3.2.7.5 Other requirements: Provide 914 mm [3'-0"] wide swinging door with keyed cylinder lock in wire mesh partition at TA-50 Storage. Provide wire mesh ceiling or extend wire mesh partitions to underside of structure above.

2-3.3 **COF Support Areas.** Provide the following areas in each COF building. Stairs shall be provide in two-story structures. Only able-bodied personnel will occupy COF support areas; handicapped accessibility is not required, except that stairs and corridors shall comply with handicapped accessibility requirements of applicable codes.

2-3.3.1 **Mechanical Room(s).** Provide dedicated areas for mechanical equipment. Each company shall have independent operation and control of HVAC system for its own spaces, but mechanical equipment may serve more than one company, and mechanical rooms may be combined. Mechanical rooms shall not be used for storage or other purposes. Access will be limited to authorized personnel. Size and locate room(s) to allow equipment removal and maintenance. Provide floor openings and vertical shaft spaces as necessary.

2-3.3.1.1 Function: Spaces for HVAC, water heating, and other plumbing and mechanical equipment.

2-3.3.1.2 Adjacency requirements: Locate to allow efficient distribution. Mechanical rooms located on the ground floor shall have doors opening to the exterior. Mechanical rooms on second floor shall be accessed from corridors.

2-3.3.1.3 Furnishings/Fixtures/Equipment: As required by Statement of Work.

2-3.3.1.4 Finishes: Floor: sealed concrete

Base: resilient cove base, or none.

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: none required

2-3.3.1.5 Other requirements: Doors shall have storeroom function (F86) locksets.

2-3.3.2 **Electrical Room(s).** Provide dedicated areas for electrical equipment. Each company shall have independent metering and control of the electrical system for its own spaces, but electrical equipment may serve more than one company, and electrical rooms may be combined. Electrical rooms shall not be used for storage or other purposes. Access will be limited to authorized personnel. Size and locate room(s) to allow equipment removal and maintenance. Provide floor openings and vertical shaft spaces as necessary.

2-3.3.2.1 Function: Spaces for electrical equipment.

2-3.3.2.2 Adjacency requirements: Locate to allow efficient distribution. Electrical rooms shall be accessed from the exterior or from corridors.

2-3.3.2.3 Furnishings/Fixtures/Equipment: As required by Statement of Work.

2-3.3.2.4 Finishes: Floor: sealed concrete

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: none required

2-3.3.2.5 Other requirements: Electrical service to buildings shall be underground. Doors shall have storeroom function (F86) locksets.

2-3.3.3 **Interior Stairs.** Provide as required to allow circulation to upper floor of the building, and to comply with applicable code egress requirements. At least one stair connecting second and first floors shall be an interior stair. [Revise if exterior stairs are not acceptable due to regional climate.]

2-3.3.3.1 Function: Circulation and means of egress.

2-3.3.3.2 Adjacency requirements: Adjacent to corridors or breezeways. Connects all floors of the building.

2-3.3.3.3 Furnishings/Fixtures/Equipment (FFE): Stairs shall be steel construction with concrete-filled treads, or cast-in-place concrete construction. Open risers are prohibited. Provide mechanical and electrical systems to comply with applicable codes.

2-3.3.3.4 Finishes:

Landing floor: porcelain tile, quarry tile, resilient tile, vinyl composition tile, or sealed concrete.

Base: porcelain tile, quarry tile, or resilient cove base.

Treads: porcelain tile, quarry tile, resilient treads, or sealed concrete. Provide slip-resistant nosing if tile is used.

Risers: painted steel, porcelain tile, quarry tile, or sealed concrete.

Walls: painted impact resistant gypsum wallboard, or painted concrete masonry units.

Ceiling: suspended acoustical panel ceiling, painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster.

2-3.3.3.5 Other requirements: Stairs shall comply with handicap accessibility requirements of applicable codes. Railings shall be painted steel, or prefinished aluminum.

2-3.3.4 **Exterior Stairs.** Provide as required to allow circulation to upper floor of the building. Comply with applicable code egress requirements. Exterior stairs shall be covered. [Delete this paragraph if regional climate precludes the use of exterior stairs.]

2-3.3.4.1 Function: Circulation and means of egress.

2-3.3.4.2 Adjacency requirements: Adjacent to corridors or breezeways. Connects all floors of the building.

2-3.3.4.3 Furnishings/Fixtures/Equipment (FFE): Exterior stairs shall be cast-in-place concrete construction (preferred), or galvanized steel construction with concrete-filled treads. Open risers and metal grating treads are prohibited.

2-3.3.4.4 Finishes: Landing floor: sealed concrete with slip-resistant finish texture.

Base: none required

Treads: Sealed concrete with slip-resistant nosing

Risers: painted steel, or sealed concrete

Walls: exterior wall materials

Ceiling: painted exterior gypsum soffit board, painted Portland cement plaster, or painted underside of concrete structure above

2-3.3.4.5 Other requirements: Stairs shall comply with handicap accessibility requirements of applicable codes. Railings shall be painted galvanized steel, or prefinished aluminum.

2-3.4 **Common Locker/Shower Areas.** Provide one group of men's and one group of women's common locker/shower areas per COF building, or provide one or more separate locker/shower buildings for the entire project. Locate on ground floor. Quantities of lockers and plumbing fixtures for men and women vary by company size. Provide the quantity of lockers and fixtures indicated in the table below. Soldiers will use locker rooms before and after physical training. Handicapped accessibility is not required. Provide exterior entrance(s) with adjacent boot wash area. Additional entrances may be provided from a common public corridor in the COF. Entrances shall be separate and distinct from the entrances to company supply and administrative areas. Exterior entrance vestibules shall be provided. Entrances shall provide visual privacy into the spaces. If locker rooms are provided as a separate building, a covered exterior walkway to the COF building is desirable, but not required. If separate buildings are provided for Locker/Shower Areas, provide additional mechanical rooms, electrical rooms, and other support spaces needed for a complete facility.

**Table 2.1 Locker Room Plumbing Fixture and Locker Quantities**

	LARGE COMPANY		MEDIUM COMPANY		SMALL COMPANY	
	MEN	WOMEN	MEN	WOMEN	MEN	WOMEN
<b>Lockers</b>	70	10	40	8	20	6
<b>Toilets *</b>	2	2	2	1	1	1
<b>Urinals *</b>	2	-	1	-	1	-
<b>Lavatories *</b>	2	1	2	1	1	1
<b>Showers *</b>	8	2	5	1	3	1

\* **NOTE:** When 3 or more company locker room facilities are grouped together, plumbing fixture quantities may be reduced to 85 percent of the number required by the table (round to next lowest whole number). Example: If men from one large and two medium companies will share one locker room, the men's shower requirement will be:  $(8 + 5 + 5) \times .85 = 15.3 = 15$  showers.

2-3.4.1 **Women's Locker Room.** Provide one or more rooms, sized to accommodate the number of lockers and plumbing fixtures required for each company served. Provide exterior entrance(s) with airlock vestibule. Locker room may also be accessed from a common interior public corridor in the COF building. For egress purposes, the occupant load shall be equal to the higher of the following numbers: a) the number of lockers in the room, or b) the code determined number of occupants calculated by multiplying room area x the occupant load factor.

2-3.4.1.1 Function: Toilets, showers and lockers for female soldiers.

2-3.4.1.2 Adjacency requirements: Near Men's Locker Room. Near company operations facilities.

2-3.4.1.3 Furnishings/Fixtures/Equipment (FFE): Provide floor mounted toilets, wall-hung lavatories, and ceramic tile shower enclosures in the quantities indicated in the table above. Provide toilet partitions at each toilet; provide dressing compartment partitions at each shower. Provide the following toilet accessories: one mirror with shelf above each lavatory; one paper towel dispenser/waste receptacle per two lavatories (or fraction thereof); one soap dispenser per lavatory; one sanitary napkin disposal per toilet; one toilet tissue dispenser per toilet; one soap holder per shower; one shower curtain and rod at each shower and at each dressing compartment; two double pin robe hooks at each dressing compartment; one robe hook on each toilet partition door; one sanitary napkin and tampon vending machine. Provide one dressing compartment bench in each dressing compartment; provide 305 mm [1'-0"] of locker room bench per 5 lockers provided. Provide two wall mounted electric hair dryers per each two lavatories (or fraction thereof); mount adjacent to mirrors. Provide fire extinguishers in semi-recessed fire extinguisher cabinets to comply with applicable codes

2-3.4.1.4 Finishes:

Floor: porcelain tile, or ceramic tile.

Base: porcelain tile, or ceramic tile.

Walls: ceramic tile, or 1829 mm high ceramic tile wainscot with painted impact resistant gypsum wallboard or painted concrete masonry units above.

Ceiling: painted Portland cement plaster, or suspended cement board with synthetic finish system.

2-3.4.1.5 Other requirements:

2-3.4.2 **Men's Locker Room.** Provide one or more rooms, sized to accommodate the number of lockers and plumbing fixtures required for each company served. Provide exterior entrance(s) with airlock vestibule. Locker room may also be accessed from a common interior public corridor in the COF building. For egress purposes, the occupant load shall be equal to the higher of the following numbers: a) the number of lockers in the room, or b) the code determined number of occupants calculated by multiplying room area x the occupant load factor.

2-3.4.2.1 Function: Toilets, showers and lockers for male soldiers.

2-3.4.2.2 Adjacency requirements: Near Women's Locker Room. Near company operations facilities.

2-3.4.2.3 Furnishings/Fixtures/Equipment (FFE): Provide floor mounted toilets, wall-hung lavatories, and ceramic tile shower enclosures in the quantities indicated in the table above. Provide toilet partitions at each toilet. Provide the following toilet accessories: one mirror with shelf above each lavatory; one paper towel dispenser/waste receptacle per two lavatories (or fraction thereof); one soap dispenser per lavatory; one toilet tissue dispenser per toilet; one soap holder per shower; one shower curtain and rod at each shower; one double pin robe hook outside each shower; one robe hook on each toilet partition door. Provide 305 mm [1'-0"] of locker room bench per 5 lockers provided. Provide two wall mounted hand-held electric hair dryers per each two lavatories (or fraction thereof); mount adjacent to mirrors. Provide fire extinguishers in semi-recessed fire extinguisher cabinets to comply with applicable codes

2-3.4.2.4 Finishes:

Floor: porcelain tile, or ceramic tile.

Base: porcelain tile, or ceramic tile.

Walls: ceramic tile, or 1829 mm high ceramic tile wainscot with painted impact resistant gypsum wallboard or painted concrete masonry units above.

Ceiling: painted Portland cement plaster, or suspended cement board with synthetic finish system.

2-3.4.2.5 Other requirements:

2-3.4.3 **Janitor Closet.** Provide one at each group of Locker Rooms. Minimum area: 6.5 m<sup>2</sup> [70 sf]. Room shall be accessed from the exterior or from a common interior space (corridor or vestibule); access directly from Men's or Women's Locker Room is not acceptable. If exterior door to Janitor's Closet is provided, provide a covered sidewalk between Janitor's Closet and locker rooms.

2-3.4.3.1 Function: Sink and storage of cleaning supplies, soap, paper products.

2-3.4.3.2 Adjacency requirements: Adjacent to Men's and Women's locker rooms.

2-3.4.3.3 Furnishings/Fixtures/Equipment (FFE): Provide one floor mounted mop sink, mop rack for three mops, and minimum 3048 linear mm of wall mounted stainless steel shelving.

2-3.4.3.4 Finishes:

Floor: ceramic tile, or sealed concrete

Base: resilient cove base, or ceramic tile base

Walls: painted water-resistant gypsum wallboard, or painted concrete masonry units

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster

2-3.4.4 Other requirements: Door shall have classroom function (F84) lockset.

#### 2-4 **BATTALION HEADQUARTERS (HQ) FUNCTIONAL AND AREA**

**REQUIREMENTS.** The battalion HQ building(s) shall consist of administrative areas, soldier services (chaplain) areas, classrooms, and support spaces. Provide facilities for [ ] large battalions, [ ] medium battalions, and [ ] small battalions. Net areas of classroom and support spaces are the same for each size battalion; net areas of administrative spaces vary with battalion size. Total gross area of each size battalion HQ shall not exceed the following: Large battalion 1452 m<sup>2</sup> [15,629 sf]; medium battalion \_\_\_ m<sup>2</sup> [\_\_\_ sf]; small battalion \_\_\_ m<sup>2</sup> [\_\_\_ sf]. Total gross building area of all battalion HQ buildings shall not exceed [\_\_\_] m<sup>2</sup> [\_\_\_ sf] [Maximum gross area shall be as shown on form DD 1391]. Each battalion may occupy a separate building, or multiple battalion headquarters may be grouped into one building. Buildings may be one or two stories in height. In a two-story configuration, classroom area, service core, soldier support offices, personnel administration clerk (PAC), and S-4 offices shall be located on the first floor; The command section, service core, S-1, S-2, and S-3 offices may be located on the second floor. One elevator is required. Grouping multiple battalion headquarters in one building is encouraged, however, each battalion must function independently, and each battalion's spaces shall be readily identifiable. A common lobby, stairs, toilets, and elevator may be used; common mechanical rooms may be used, but mechanical and electrical systems must provide each battalion with independent operation and control. To the greatest extent possible, buildings shall be arranged to allow future reconfiguration of battalion sizes, and internal reorganization of office spaces: fixed elements such as toilets, equipment rooms, and core areas shall be located at the perimeter of administrative spaces; partitions separating administrative spaces should not be bearing walls.

Leadership and staff will manage the organization, receive visitors, and conduct the business of the battalion from the administrative areas (Command section, S-1, S-2, S-3, S-4, and PAC). Soldiers will visit the facility to conduct administrative business, attend training classes, or meet with support personnel (Chaplain's office). Military personnel will staff the facility; military and non-military personnel will visit the facility to meet with leadership or attend meetings. Although only able-bodied military personnel will be on staff, all spaces except shower rooms, and utility areas (janitor closets, mechanical, electrical, communication, and elevator machine rooms) shall comply with handicapped accessibility requirements. Functions and areas are as follows:

2-4.1 **Command Section.** Provide one group of offices, with accompanying reception area, coffee area and private toilet. In a two-story building locate Command Section on the second floor. Command section shall be adjacent to, and accessed through, the S-1 Clerical/Central Files area.

2-4.1.1 **Commanding Officer (CO).** Provide one; 20.9 m<sup>2</sup> [225 sf]. Room shall be accessed through the Reception Area. Occupants: 1, and occasional visitors.

2-4.1.1.1 Function: Private office for battalion commanding officer.

2-4.1.1.2 Adjacency requirements: Adjacent to Reception Area, S-1 Clerical /Central Files. Adjacent to or near command section toilet, coffee area, Executive Officer and Command Sergeant Major offices [modify this sentence to require direct access doors from CO to XO and CSM offices only if this is a must-have user requirement; requiring doors between these offices places additional restrictions on design of the floor plan].

2-4.1.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] one credenza [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one conference table [\_\_\_\_], six side chairs, and one desk chair.

2-4.1.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.1.1.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-4.1.2 **Executive Officer (XO)**. Provide one; 8.8 m<sup>2</sup> [95 sf]. Room shall be accessed through the Reception Area. Occupants: 1, and occasional visitors.

2-4.1.2.1 Function: Private office for battalion executive officer.

2-4.1.2.2 Adjacency requirements: Adjacent to Reception Area, S-1 Clerical /Central Files. Adjacent to or near command section toilet, coffee area, CO office and Command Sergeant Major office. [modify this sentence if direct access door from CO to XO is required].

2-4.1.2.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one side chair, and one desk chair.

2-4.1.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.1.2.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-4.1.3 **Command Sergeant Major (CSM)**. Provide one; 8.8 m<sup>2</sup> [95 sf]. Room shall be accessed through the Reception Area. Occupants: 1, and occasional visitors.

2-4.1.3.1 Function: Private office for battalion command sergeant major.

2-4.1.3.2 Adjacency requirements: Adjacent to Reception Area, S-1 Clerical /Central Files. Adjacent to or near command section toilet, coffee area, CO office and Command Sergeant Major office. [modify this sentence if direct access door from CO to XO is required].

2-4.1.3.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one side chair, and one desk chair.

2-4.1.3.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.1.2.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-4.1.4 **Reception Area.** Provide one; 13.9 m<sup>2</sup> [150 sf], to accommodate reception desk and waiting area. Reception area shall be accessed through S-1 Clerical/Central Files.

Occupants: 1, and space for four visitors.

2-4.1.4.1 Function: Receptionist workstation and waiting area for visitors to the CO, XO, CSM offices.

2-4.1.4.2 Adjacency requirements: Adjacent (and open to) S-1 Clerical /Central Files area. Adjacent to command section toilet, coffee area, CO, XO and Command Sergeant Major offices.

2-4.1.4.3 Furnishings/Fixtures/Equipment: Provide and design area to accommodate one reception desk (systems furniture workstation type [\_\_\_\_]), four side chairs and one magazine table.

2-4.1.4.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.1.4.5 Other requirements:

2-4.1.5 **Command Section Toilet.** Provide one private toilet room. Room shall be sized to comply with handicap accessibility requirements. Room shall be accessed from reception area

2-4.1.5.1 Function: single-occupant toilet and lavatory, for use by command staff and visitors.

2-4.1.5.2 Adjacency requirements: Adjacent to reception area. Near CO, XO, and CSM offices.

2-4.1.5.3 Furnishings/Fixtures/Equipment (FFE): Provide one floor mounted toilet, one wall-hung lavatory, mirror with shelf above lavatory, Paper towel dispenser/waste receptacle, soap dispenser, toilet tissue dispenser, and wall mounted grab bars at toilet.

2-4.1.5.4 Finishes:

Floor: porcelain tile, or ceramic tile.

Base: porcelain tile, or ceramic tile.

Walls: ceramic tile

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster.

2-4.1.5.5 Other requirements: Door shall have privacy function (F76) lockset. Arrange space so that door does not open directly into reception area. Partitions shall have minimum STC

rating of 49.

2-4.1.6 **Coffee Area.** Provide one. Area shall have countertop with kitchen sink; comply with handicap accessibility requirements.

2-4.1.6.1 Function: Sink and space for coffee maker and supplies; for use by command section staff and visitors.

2-4.1.6.2 Adjacency requirements: Adjacent to reception area. Near CO, XO, and CSM offices. Locate to avoid conflicts with circulation pattern.

2-4.1.6.3 Furnishings/Fixtures/Equipment (FFE): Provide minimum 1219 mm wide x 610 mm deep [4'-0" x 2'-0"] plastic laminate countertop, with stainless steel kitchen sink. Provide minimum 1219 mm of wall cabinets; mounted to provide 610 mm clearance above countertop [verify with user that proposed coffee maker will fit in this space]. Provide dedicated electrical receptacle for coffee maker (coffee maker not in contract).

2-4.1.6.4 Finishes:

Floor: porcelain tile, or ceramic tile.

Base: porcelain tile, or ceramic tile.

Walls: painted gypsum wallboard or painted veneer plaster.

Ceiling: suspended acoustical panel ceiling.

2-4.1.6.5 Other requirements:

2-4.2 **S-1 Section.** Provide one group of offices. In a two-story building locate S-1 Section on the second floor. Locate S-1 Section adjacent to S-2 and/or S-3 Sections. Command Section shall be accessed through the S-1 Clerical/Central Files area.

2-4.2.1 **S-1 Officer.** Provide one; 8.8 m<sup>2</sup> [95 sf]. Room shall be accessed through the S-1 Clerical/Central Files area. Occupants: 1, and occasional visitors.

2-4.2.1.1 Function: Private office for S-1 officer.

2-4.2.1.2 Adjacency requirements: Adjacent to S-1 Clerical /Central Files. Near Command Section offices.

2-4.2.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [ ] with return [ ], one bookcase [ ], two legal-size four-drawer file cabinets, one side chair, and one desk chair.

2-4.2.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.2.1.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-4.2.2 **S-1 Clerical/Central Files.** Provide one; 62.3 m<sup>2</sup> [670 sf]. S-1 Clerical/Central Files shall be accessed from the lobby or corridor. The area shall have direct access to S-1 and Command Section private offices, and reception area. Occupants: 7 staff and occasional visitors.

2-4.2.2.1 Function: Open office area for S-1 admin staff; access to S-1 and Command offices.

2-4.2.2.2 Adjacency requirements: Adjacent to lobby or corridor. Adjacent to S-1 and Command private offices. Adjacent (and open to) reception area.

2-4.2.2.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate seven type [ ] systems furniture workstations.

2-4.2.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.2.2.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Exterior window is desirable. Partitions shall have minimum STC rating of 49. Minimum ceiling height 2642 mm [8'-8"].

2-4.3 **S-2 Section.** Provide one group of offices. In a two-story building locate S-2 Section on the second floor. Locate S-2 Section adjacent to S-1 and/or S-3 Sections.

2-4.3.1 **S-2 Officer.** Provide one; 8.8 m<sup>2</sup> [95 sf]. Room shall be accessed through the S-2 Clerical/Central Files area. Occupants: 1, and occasional visitors.

2-4.3.1.1 Function: Private office for S-2 officer.

2-4.3.1.2 Adjacency requirements: Adjacent to S-2 Clerical /Central Files.

2-4.3.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [ ] with return [ ], one bookcase [ ], two legal-size four-drawer file cabinets, one side chair, and one desk chair.

2-4.3.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.3.1.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-4.3.2 **Office.** Provide two; each 8.8 m<sup>2</sup> [95 sf]. Area may be a private office or a systems furniture workstation accessed through the S-4 Clerical/Central Files area. Occupants: 1 in each office [verify with user].

2-4.3.2.1 Function: Private office for use by S-2 personnel.

2-4.3.2.2 Adjacency requirements: Adjacent to S-2 Clerical /Central Files.

2-4.3.2.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [ ] with return [ ], one bookcase [ ], two legal-size four-drawer file cabinets, one side chair, and one desk chair. If systems furniture panels are provided in lieu of drywall partitions, provide workstation type \_\_\_\_.

2-4.3.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.3.2.5 Other requirements: Exterior window is desirable. If drywall partitions are used, provide 914 mm [3'-0"] wide door into each room; door shall have entry function (F81) lockset. Drywall partitions shall have minimum STC rating of 49.

2-4.3.3 **S-2 Clerical/Central Files.** Provide one; 76.2 m<sup>2</sup> [820 sf]. S-2 Clerical/Central Files shall be accessed from the lobby or corridor. The area shall have direct access to S-2 private offices, and the Secured Documents Vault. Occupants: 8 staff , and occasional visitors.

2-4.3.3.1 Function: Open office area for S-2 admin staff; access to other S-2 spaces.

2-4.3.3.2 Adjacency requirements: Adjacent to lobby or corridor. Adjacent to S-2 private offices and Secured Documents Vault.

2-4.3.3.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate eight type [ ] systems furniture workstations.

2-4.3.3.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.3.3.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Exterior window is desirable. Partitions shall have minimum STC rating of 49. Minimum ceiling height 2642 mm [8'-8"].

2-4.3.4 **Secured Documents Vault.** Provide one room; 13 m<sup>2</sup> [140 sf]. Vault shall be certified for open storage of secret material. Class M Modular construction is acceptable. Provide Class 5 vault door with day gate verify all vault criteria with user. To allow future flexibility in reconfiguring offices areas, locate vault on the perimeter of the administrative areas. Occupants: 1.

2-4.3.4.1 Function: Storage of documents classified 'secret' and below. Workspace for one clerk.

2-4.3.4.2 Adjacency requirements: Adjacent to and accessed from S-2 Clerical/Central Files.

2-4.3.4.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], [insert shelving or file cabinet requirements], and one desk chair.

2-4.3.4.4 Finishes:

Floor: carpet or vinyl composition tile

Base: resilient base

Walls: painted or pre-finished modular vault panels

Ceiling: painted or pre-finished modular vault panels

2-4.3.4.5 Other requirements:

2-4.4 **S-3 Section.** Provide one group of offices. In a two-story building locate S-3 Section on the second floor. Locate S-3 Section adjacent to S-1 and/or S-2 Sections.

2-4.4.1 **S-3 Officer.** Provide one; 8.8 m<sup>2</sup> [95 sf]. Room shall be accessed through the S-3 Clerical/Central Files area. Occupants: 1, and occasional visitors.

2-4.4.1.1 Function: Private office for S-3 officer.

2-4.4.1.2 Adjacency requirements: Adjacent to S-3 Clerical /Central Files.

2-4.4.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one side chair, and one desk chair.

2-4.4.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.4.1.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-4.4.2 **Office.** Provide two; each 8.8 m<sup>2</sup> [95 sf]. Area may be a private office or a systems furniture workstation accessed through the S-3 Clerical/Central Files area. Occupants: 1 in each office [verify with user].

2-4.4.2.1 Function: Private office or systems furniture workstation for use by S-3 personnel.

2-4.4.2.2 Adjacency requirements: Adjacent to S-3 Clerical /Central Files.

2-4.4.2.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one side chair, and one desk chair. If systems furniture panels are provided in lieu of drywall partitions, provide workstation type \_\_\_\_.

2-4.4.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.4.2.5 Other requirements: Exterior window is desirable. If drywall partitions are used, provide 914 mm [3'-0"] wide door into each room; door shall have entry function (F81) lockset. Drywall partitions shall have minimum STC rating of 49.

2-4.4.3 **S-3 Clerical/Central Files.** Provide one; 76.2 m<sup>2</sup> [820 sf]. S-3 Clerical/Central Files shall be accessed from the lobby or corridor. The area shall have direct access to S-3 private offices. Occupants: 8 staff , and occasional visitors.

2-4.4.3.1 Function: Open office area for S-3 admin staff; access to S-3 offices.

2-4.4.3.2 Adjacency requirements: Adjacent to lobby or corridor. Adjacent to S-3 private offices.

2-4.4.3.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate eight type [ ] systems furniture workstations.

2-4.4.3.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.4.3.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Exterior window is desirable. Partitions shall have minimum STC rating of 49. Minimum ceiling height 2642 mm [8'-8"].

2-4.5 **Conference Room.** Provide one; 36 m<sup>2</sup> [387 sf] Room shall be located to allow direct access from the main corridor/lobby and the Command Section/S-1 Section. In a two-story building, conference room will be located on the second floor. Occupants: up to 26 persons.

2-4.5.1 Function: Conference room for battalion leadership, staff, and visitors. Functions will include staff meetings, hearings, disciplinary sessions, training.

2-4.5.2 Adjacency requirements: Adjacent to lobby or main corridor, S-1 Section, Command Section. Near S-2 and S-3 Sections.

2-4.5.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate Coordinate furniture requirements with user. Provide one marker board (minimum 2438 mm wide x 1219 mm high [8'-0" x 4'-0"]) and one 2438 mm wide [8'-0"] wall mounted pull-down projection screen.

2-4.5.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster  
Ceiling: suspended acoustical panel ceiling

2-4.5.5 Other requirements: Provide 914 mm [3'-0"] wide doors into room; doors shall have classroom function (F84) lockset. Partitions shall have minimum STC rating of 55. Minimum ceiling height 2642 mm [8'-8"].

2-4.6 **S-4 Section.** Provide one group of offices. In a two-story building locate S-4 Section on the first floor. Locate S-4 Section adjacent to PAC Section.

2-4.6.1 **S-4 Officer.** Provide one; 8.8 m<sup>2</sup> [95 sf]. Room shall be accessed through the S-4 Clerical/Central Files area. Occupants: 1, and occasional visitors.

2-4.6.1.1 Function: Private office for S-4 officer.

2-4.6.1.2 Adjacency requirements: Adjacent to S-4 Clerical /Central Files.

2-4.6.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [ ] with return [ ], one bookcase [ ], two legal-size four-drawer file cabinets, one side chair, and one desk chair.

2-4.6.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.6.1.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-4.6.2 **Office.** Provide two; each 8.8 m<sup>2</sup> [95 sf]. Area may be a private office or a systems furniture workstation accessed through the S-4 Clerical/Central Files area. Occupants: 1 in each office [verify with user].

2-4.6.2.1 Function: Private office or systems furniture workstation for use by S-4 personnel.

2-4.6.2.2 Adjacency requirements: Adjacent to S-4 Clerical /Central Files.

2-4.6.2.3 Furnishings/Fixtures/Equipment: Provide and design each area to accommodate one desk [ ] with return [ ], one bookcase [ ], two legal-size four-drawer file cabinets, one side chair, and one desk chair. If systems furniture panels are provided in lieu of drywall partitions, provide workstation type \_\_\_\_.

2-4.6.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.6.2.5 Other requirements: Exterior window is desirable. If drywall partitions are used,

provide 914 mm [3'-0"] wide door into each room; door shall have entry function (F81) lockset. Drywall partitions shall have minimum STC rating of 49.

2-4.6.3 **S-4 Clerical/Central Files.** Provide one; 76.2 m<sup>2</sup> [820 sf]. S-4 Clerical/Central Files shall be accessed from the lobby or corridor. The area shall have direct access to S-4 private offices. Occupants: 8 staff , and occasional visitors.

2-4.6.3.1 Function: Open office area for S-4 admin staff; access to S-4 offices.

2-4.6.3.2 Adjacency requirements: Adjacent to lobby or corridor. Adjacent to S-4 private offices.

2-4.6.3.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate eight type [ ] systems furniture workstations.

2-4.6.3.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.6.3.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Exterior window is desirable. Partitions shall have minimum STC rating of 49. Minimum ceiling height 2642 mm [8'-8"].

2-4.6.4 **S-4 Storage & Supplies.** Provide one; 24.2 m<sup>2</sup> [260sf] of general storage space. Room shall be under control of, and accessed from, S-4/Clerical/Central Files area. Room shall be located on exterior wall, with exterior doors leading to paved sidewalk add requirement for vehicle access if necessary. .

2-4.6.4.1 Function: Storage of identify type of items to be stored for S-4 Section.

2-4.6.4.2 Adjacency requirements: Adjacent to S-4 Clerical/Central Files and building exterior.

2-4.6.4.3 Furnishings/Fixtures/Equipment: insert shelving requirement].

2-4.6.4.4 Finishes: Floor: sealed concrete

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: suspended acoustical panel ceiling

2-4.6.5 Other requirements: Provide 914 mm [3'-0"] wide door into room from S-4/Clerical/Central Files; provide pair of 914 mm [3'-0"] wide outswinging hollow metal exterior doors. Doors shall have storeroom function (F86) locksets; exterior doors shall have hold open devices and auxiliary deadlocks (thumb turn inside, keyed cylinder outside). Provide minimum 2438 mm [8'-0"] wide exterior sidewalk between exterior doors and the main sidewalk leading to main entry area modify if paved vehicle loading area is required].

2-4.7 **Personnel Administration Center (PAC) Section.** Provide one group of offices. In a two-story building locate PAC Section on the first floor. Locate PAC Section adjacent to S-4 Section.

2-4.7.1 **PAC Officer.** Provide one; 8.8 m<sup>2</sup> [95 sf]. Room shall be accessed through the PAC Clerical/Central Files area. Occupants: 1, and occasional visitors.

2-4.7.1.1 Function: Private office for S-4 officer.

2-4.7.1.2 Adjacency requirements: Adjacent to PAC Clerical /Central Files.

2-4.7.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [ ] with return [ ], one bookcase [ ], two legal-size four-drawer file cabinets, one side chair, and one desk chair.

2-4.7.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.7.1.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-4.7.2 **Office.** Provide two; each 8.8 m<sup>2</sup> [95 sf]. Area may be a private office or a systems furniture workstation accessed through the PAC Clerical/Central Files area. Occupants: 1 in each office [verify with user].

2-4.7.2.1 Function: Private office or systems furniture workstation for use by PAC personnel.

2-4.7.2.2 Adjacency requirements: Adjacent to PAC Clerical /Central Files.

2-4.7.2.3 Furnishings/Fixtures/Equipment: Provide and design each area to accommodate one desk [ ] with return [ ], one bookcase [ ], two legal-size four-drawer file cabinets, one side chair, and one desk chair. If systems furniture panels are provided in lieu of drywall partitions, provide workstation type \_\_\_\_.

2-4.7.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.7.2.5 Other requirements: Exterior window is desirable. If drywall partitions are used, provide 914 mm [3'-0"] wide door into each room; door shall have entry function (F81) lockset. Drywall partitions shall have minimum STC rating of 49.

2-4.7.2.6 **PAC Clerical/Central Files.** Provide one; 76.2 m<sup>2</sup> [820 sf]. S-4 Clerical/Central Files shall be accessed from the lobby or corridor. The area shall have direct access to PAC private offices. Occupants: 8 staff , and occasional visitors.

2-4.7.2.7 Function: Open office area for PAC admin staff; access to PAC offices and Message Mail Center.

2-4.7.2.8 Adjacency requirements: Adjacent to lobby or corridor. Adjacent to PAC private offices and Message Mail Center. Near Duty Officer.

2-4.7.2.9 Furnishings/Fixtures/Equipment: Provide and design room to accommodate eight type [ ] systems furniture workstations.

2-4.7.2.10 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.7.3 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Exterior window is desirable. Partitions shall have minimum STC rating of 49. Minimum ceiling height 2642 mm [8'-8"].

2-4.7.4 **Duty Officer.** Provide one; 8.8 m<sup>2</sup> [95 sf]. Room shall be accessed from the main lobby. Occupants: 1.

2-4.7.4.1 Function: Duty Officer will provide physical security of the building, and visual control of the entrances and lobby, as well as functioning as an information source for visitors.

2-4.7.4.2 Adjacency requirements: Adjacent to lobby and main entrance; near PAC Clerical /Central Files.

2-4.7.4.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [ ] with return [ ], one legal-size four-drawer file cabinet, one side chair, and one desk chair.

2-4.7.4.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.7.4.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset and glass vision panel. Provide duty officer counter (built-in casework) minimum 1829 mm [6'-0"] long separating the Duty Officer room from the lobby/corridor. The counter on the corridor side shall be minimum 1524 mm [5'-0"] wide x 1016 mm [3'-4"] high x 305 mm [12"] deep; provide locking overhead coiling shutter to secure the opening when unattended; shutter hood shall not be visible from corridor side. [modify requirement for sliding pass-through window above counter if requested by user].

2-4.7.5 **Message Mail Center.** Provide one; 8.8 m<sup>2</sup> [95 sf]. Room shall be accessed from the PAC Clerical/Central Files area. Occupants: [ ].

2-4.7.5.1 Function: Mail sorting [add to description of function].

2-4.7.5.2 Adjacency requirements: Adjacent to corridor and PAC Clerical /Central Files.

2-4.7.5.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate [insert furniture requirements]

2-4.7.5.4 Finishes:

Floor: vinyl composition tile, or porcelain tile

Base: resilient base, or porcelain tile base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.7.5.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset and glass vision panel. Provide counter (built-in casework) minimum 1829 mm [6'-0"] long separating the Message Mail Center from the corridor. The counter on the corridor side shall be minimum 1524 mm [5'-0"] wide x 1016 mm [3'-4"] high x 305 mm [12"] deep; provide locking overhead coiling shutter to secure the opening when unattended; shutter hood shall not be visible from corridor side [modify requirement for sliding pass-through window above counter if requested by user].

2-4.8 **Soldier Services.** Provide one group of offices. In a two-story building locate soldier services on the first floor. Soldier services are unrelated to other battalion administration functions.

2-4.8.1 **Chaplain's Assistant.** Provide one; 12.1 m<sup>2</sup> [130 sf]. Room shall be accessed from the lobby or main corridor. Occupants: 1, and visitors.

2-4.8.1.1 Function: Private office for Chaplain's Assistant and waiting area for visitors to Chaplain's office.

2-4.8.1.2 Adjacency requirements: Adjacent to lobby or main corridor.

2-4.8.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], four side chairs, and one desk chair.

2-4.8.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.8.1.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Exterior window is desirable. Partitions shall have minimum STC rating of 55.

2-4.8.2 **Chaplain.** Provide one; 12.1 m<sup>2</sup> [130 sf]. Room shall be accessed from the Chaplain's Assistant office. Occupants: 1, and visitors.

2-4.8.2.1 Function: Private office for Chaplain and visitors.

2-4.8.2.2 Adjacency requirements: Adjacent to Chaplain's Assistant. May have additional door to corridor.

2-4.8.2.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one

desk [ ] with return [ ], one bookcase [ ], one desk chair, and [insert furniture requirements].

2-4.8.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.8.2.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-4.9 **Classroom Areas.** Provide one group of classrooms and adjacent Learning Resource Center for each battalion. In a two-story building locate Classroom Area on the first floor. Classrooms and Learning Resource Center will be accessed from the lobby or main corridor. The three classrooms shall be divided by operable panel partitions and provided with appropriate entrances and exits to allow two or three rooms to be combined for use as one large classroom.

2-4.9.1 **Classroom.** Provide three; minimum area 86 m<sup>2</sup> [926 sf] each. Each classroom shall be located to allow direct access from the main corridor/lobby, and direct egress out of the building. In a two-story building, classrooms will be located on the first floor. Occupants: up to 60 persons in each room [verify with user].

2-4.9.1.1 Function: Soldier training and other meetings.

2-4.9.1.2 Adjacency requirements: Adjacent to lobby or main corridor; adjacent to exterior wall. Locate all three classrooms together to allow use as larger room. Near toilets.

2-4.9.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate [Coordinate furniture requirements with user]. Walls separating classrooms shall be operable panel partitions with minimum STC rating of 47. Provide one marker board (minimum 3658 mm wide x 1219 mm high [12'-0" x 4'-0"]) and one 2438 mm wide [8'-0"] wall mounted pull-down projection screen [Coordinate with user and add requirements for cable television outlets, television support brackets, or other equipment; identify whether equipment is to be contractor or government provided].

2-4.9.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling, and painted gypsum wallboard or painted veneer plaster

2-4.9.1.5 Other requirements: Provide 914 mm [3'-0"] wide doors into room; doors shall have classroom function (F84) lockset. Permanent partitions shall have minimum STC rating of 49. Minimum ceiling height 2642 mm [8'-8"] at perimeter, 3048 mm [10'-0"] in main portion of room.

2-4.9.2 **Learning Resource Center.** Provide one; minimum area 31.6 m<sup>2</sup> [340 sf]. Provide direct access from the main corridor/lobby. In a two-story building, Learning Resource Center

will be located on the first floor. Occupants: up to 22 persons [verify with user].

2-4.9.2.1 Function: Soldier training and other meetings.

2-4.9.2.2 Adjacency requirements: Adjacent to lobby or main corridor. Near classrooms and toilets.

2-4.9.2.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate [Coordinate furniture requirements with user]. Partitions shall have minimum STC rating of 49. Provide one marker board (minimum 2438 mm wide x 1219 mm high [8'-0" x 4'-0"]) and one 2438 mm wide [8'-0"] wall mounted pull-down projection screen.

2-4.9.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling, and painted gypsum wallboard or painted veneer plaster

2-4.9.2.5 Other requirements: Provide 914 mm [3'-0"] wide doors into room; doors shall have classroom function (F84) lockset. Permanent partitions shall have minimum STC rating of 49. Minimum ceiling height 2642 mm [8'-8"] at perimeter, 3048 mm [10'-0"] in main portion of room.

2-4.10 **Battalion HQ Common Areas.** Provide the following areas in each building. Handicapped accessibility is required in all common areas except janitor closet and shower rooms.

2-4.10.1 **Lobby and Corridors.** Provide as required to allow access to building spaces. Unless otherwise required, minimum width of main corridors providing access to classroom area shall not be less than 2438 mm [8'-0"]; minimum width of other main corridors shall not be less than 1829 mm [6'-0"]. Corridor width shall comply with applicable egress codes.

2-4.10.1.1 Function: Entry to the facility; egress and circulation through the building.

2-4.10.1.2 Adjacency requirements: Adjacent to main entrances and vertical circulation. It is preferable to enter lobby/main corridor from two sides of the building.

2-4.10.1.3 Furnishings/Fixtures/Equipment: Provide wall mounted electric water cooler. Provide mechanical and electrical systems to comply with applicable codes. Provide fire extinguishers in semi-recessed fire extinguisher cabinets to comply with applicable codes. Provide recessed space for three vending machines per building (machines are not in contract). Provide interior signage to identify major spaces. Provide two recessed trophy cases (minimum size: 2438 mm wide x 1524 high x 406 mm deep) per battalion; provide one recessed building directory near each main entrance; in a two-story building, provide one recessed building directory near second floor elevator doors. Provide one 1219 mm high x 1829 mm wide [4'-0" x 6'-0"] wall mounted bulletin board.

2-4.10.1.4 Finishes:

Floor: porcelain tile, vinyl composition tile, or carpet.

Base: porcelain tile, stained wood base, or resilient cove base.

Walls: painted gypsum wallboard, or painted veneer plaster.

Ceiling: suspended acoustical panel ceiling

2-4.10.1.5 Other requirements: Handicap accessible.

2-4.10.2 **Entry Vestibules.** Provide at each exterior entrance to lobby/main corridor area. [If climate dictates, revise this sentence to require vestibules at all entrances to the building.]

2-4.10.1.1 Function: Primary entry point into the facility; weather protection for interior spaces.

2-4.10.1.2 Adjacency requirements: Adjacent to lobby/main corridor.

2-4.10.1.3 Furnishings/Fixtures/Equipment:

2-4.10.1.4 Finishes:

Floor: Provide recessed entry mat full depth of vestibule x full width of doors; porcelain tile, or quarry tile in remainder of room.

Base: porcelain tile or quarry tile

Walls: Match exterior wall finish material, or painted gypsum wallboard, or painted veneer plaster

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster.

2-4.10.1.5 Other requirements: Handicap accessible.

2-4.10.2 **Interior Stairs.** Provide as required to allow circulation to upper floor of the building, and to comply with applicable code egress requirements.

2-4.10.2.1 Function: Circulation and means of egress.

2-4.10.2.2 Adjacency requirements: Adjacent to corridors. Connects all floors of the building.

2-4.10.2.3 Furnishings/Fixtures/Equipment: Stairs shall be steel construction with concrete-filled treads, or cast-in-place concrete construction. Open risers are prohibited. Provide mechanical and electrical systems to comply with applicable codes.

2-4.10.2.4 Finishes:

Landing floor: porcelain tile, quarry tile, resilient tile, vinyl composition tile, or sealed concrete.

Base: porcelain tile, quarry tile, or resilient cove base.

Treads: porcelain tile, quarry tile, resilient treads, or sealed concrete. Provide slip-resistant nosing if tile is used.

Risers: painted steel, porcelain tile, quarry tile, or sealed concrete.

Walls: painted gypsum wallboard, or painted concrete masonry units.

Ceiling: suspended acoustical panel ceiling, painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster.

2-4.10.2.5 Other requirements: Stairs shall comply with handicap accessibility requirements of applicable codes. Railings shall be painted steel, or prefinished aluminum.

2-4.10.3 **Men's Toilet Room(s).** Provide one or more rooms, sized to accommodate the number of plumbing fixtures required for each battalion served. In a two-story structure, one of the required toilet fixtures and one of the required lavatories shall be provided in a single occupant male toilet room on the second floor. If two battalion headquarters are combined in one building, the required number of fixtures may be combined in one male toilet room on each

floor of the building. Toilet rooms will be accessed from corridors. Arrange entrance to provide visual privacy.

2-4.10.3.1 Function: Restrooms for male occupants.

2-4.10.3.2 Adjacency requirements: Adjacent to corridor.

2-4.10.3.3 Furnishings/Fixtures/Equipment: Provide 3 lavatories, 4 floor mounted toilets, and 2 wall-hung urinals for each battalion. Lavatories in single-occupant toilet rooms shall be wall-hung; lavatories in gang toilets shall be countertop mounted. Countertops shall be plastic laminate or solid surfacing material. Provide toilet partitions at each toilet, and urinal partitions between urinals. Provide the following toilet accessories: one mirror with shelf above each wall-hung lavatory; one continuous mirror full width of countertop at countertop mounted lavatories; one paper towel dispenser/waste receptacle per toilet room; one soap dispenser per lavatory; one toilet tissue dispenser per toilet; one robe hook on each toilet partition door.

2-4.10.3.4 Finishes:

Floor: porcelain tile, or ceramic tile.

Base: porcelain tile, or ceramic tile.

Walls: ceramic tile, or 1829 mm high ceramic tile wainscot with painted impact resistant gypsum wallboard or painted concrete masonry units above.

Ceiling: painted Portland cement plaster, or painted gypsum wallboard or veneer plaster.

2-4.10.3.5 Other requirements:

2-4.10.4 **Women's Toilet Room(s)**. Provide one or more rooms, sized to accommodate the number of plumbing fixtures required for each battalion served. In a two-story structure, one of the required toilet fixtures and one of the required lavatories shall be provided in a single occupant female toilet room on the second floor. If two battalion headquarters are combined in one building, the required number of fixtures may be combined in one female toilet room on each floor of the building. Toilet rooms will be accessed from corridors. Arrange entrance to provide visual privacy.

2-4.10.4.1 Function: Restrooms for female occupants.

2-4.10.4.2 Adjacency requirements: Adjacent to corridor.

2-4.10.4.3 Furnishings/Fixtures/Equipment: Provide 4 lavatories and 4 floor mounted toilets for each battalion. Lavatories in single-occupant toilet rooms shall be wall-hung; lavatories in gang toilets shall be countertop mounted. Countertops shall be plastic laminate or solid surfacing material. Provide toilet partitions at each toilet. Provide the following toilet accessories: one mirror with shelf above each wall-hung lavatory; one continuous mirror full width of countertop at countertop mounted lavatories; one paper towel dispenser/waste receptacle per toilet room; one soap dispenser per lavatory; one toilet tissue dispenser per toilet; one sanitary napkin disposal at each toilet; one robe hook on each toilet partition door.

2-4.10.4.4 Finishes:

Floor: porcelain tile, or ceramic tile.

Base: porcelain tile, or ceramic tile.

Walls: ceramic tile, or 1829 mm high ceramic tile wainscot with painted impact resistant gypsum wallboard or painted concrete masonry units above.

Ceiling: painted Portland cement plaster, or painted gypsum wallboard or veneer plaster.

2-4.10.4.5 Other requirements:

2-4.10.5 **Shower Room.** Provide two. Rooms shall be used by able-bodied military personnel only. Rooms shall be accessed from Administrative Area Corridor. Shower room shall not be combined with toilet rooms. In a two-story building, shower rooms may be located on first or second floor.

2-4.10.5.1 Function: Private shower and dressing room for use by battalion staff.

2-4.10.5.2 Adjacency requirements: Adjacent to corridor. Near toilets.

2-4.10.5.3 Furnishings/Fixtures/Equipment: Provide one ceramic tile shower with rod and shower curtain. Shower shall have ceramic soap holder and wall mounted grab bar. Dressing area shall have bench, four towel/robe hooks, and wall mounted full-length mirror. Provide floor drain at dressing area, locate outside of circulation path.

2-4.10.5.4 Finishes:

Floor: ceramic tile.

Base: ceramic tile.

Walls: ceramic tile

Ceiling: painted Portland cement plaster.

2-4.10.6.5 Other requirements:

2-4.10.6 **Janitor Closet.** Provide one at each group of toilets on each floor of the building. Minimum area: 2.8 m<sup>2</sup> [30 sf]. Room shall be accessed from the corridor.

2-4.10.6.1 Function: Sink and storage of cleaning supplies, soap, paper products.

2-4.10.6.2 Adjacency requirements: Near toilets and shower rooms.

2-4.10.6.3 Furnishings/Fixtures/Equipment: Provide one floor mounted mop sink, mop rack for two mops, and minimum 1829 linear mm of wall mounted stainless steel shelving.

2-4.10.6.4 Finishes:

Floor: ceramic tile, or sealed concrete

Base: resilient cove base, or ceramic tile base

Walls: painted water-resistant gypsum wallboard, or painted concrete masonry units

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster

2-4.10.6.5 Other requirements: Door shall have classroom function (F84) lockset.

2-4.10.7 **Storage.** Provide minimum 9.3 m<sup>2</sup> [100sf] of general storage space. In a two-story building provide half of the area on each floor. Each room shall be dedicated to one battalion. Storage rooms will be accessed from the corridor.

2-4.10.7.1 Function: Storage of [identify type of items to be stored] for the battalion.

2-4.10.7.2 Adjacency requirements: Adjacent to corridor.

2-4.10.7.3 Furnishings/Fixtures/Equipment: [insert shelving requirement].

2-4.10.7.4 Finishes: Floor: sealed concrete

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: suspended acoustical panel ceiling

2-4.10.7.5 Other requirements: Door shall have storeroom function (F86) lockset.

2-4.11 **Battalion HQ Support Areas.** Provide the following areas in each battalion HQ building. Handicapped accessibility is not required in mechanical rooms, electrical and communications closets, and elevator machine room. All other support spaces shall be handicap accessible.

2-4.11.1 **Mechanical Room(s).** Provide dedicated areas for mechanical equipment. Each battalion shall have independent operation and control of HVAC system for its own spaces, but mechanical equipment may serve more than one battalion, and mechanical rooms may be combined. Mechanical rooms shall not be used for storage or other purposes. Access will be limited to authorized personnel. Size and locate room(s) to allow equipment removal and maintenance. Provide floor openings and vertical shaft spaces as necessary.

2-4.11.1.1 Function: Spaces for HVAC, water heating, and other plumbing and mechanical equipment.

2-4.11.1.2 Adjacency requirements: Locate to allow efficient distribution. Mechanical rooms located on the ground floor shall have doors opening to the exterior. Mechanical rooms on second floor shall be accessed from corridors.

2-4.11.1.3 Furnishings/Fixtures/Equipment: As required by Statement of Work.

2-4.11.1.4 Finishes: Floor: sealed concrete

Base: resilient cove base, or none.

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: none required

2-4.11.1.5 Other requirements: Doors shall have storeroom function (F86) locksets.

2-4.11.2 **Electrical Room(s).** Provide dedicated areas for electrical equipment. Each battalion shall have independent metering and control of the electrical system for its own spaces, but electrical equipment may serve more than one battalion, and electrical rooms may be combined. Electrical rooms shall not be used for storage or other purposes. Access will be limited to authorized personnel. Size and locate room(s) to allow equipment removal and maintenance.

2-4.11.2.1 Function: Spaces for electrical equipment.

2-4.11.2.2 Adjacency requirements: Locate to allow efficient distribution. Electrical rooms shall be accessed from the exterior or from corridors.

2-4.11.2.3 Furnishings/Fixtures/Equipment: As required by Statement of Work.

2-4.11.2.4 Finishes: Floor: sealed concrete

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: none required.

2-4.11.2.5 Other requirements: Electrical service to buildings shall be underground. Doors shall have storeroom function (F86) locksets.

2-4.11.3 **Communication Room.** Provide dedicated room(s) for communication distribution equipment. Each room shall be dedicated to a single battalion, and shall not be combined with mechanical or electrical rooms. Provide each battalion with one main communication room; minimum size 3048 mm [10'-0"] x 3353 mm [11'-0"]. In two-story buildings, the communication room shall be located on the second floor. Provide additional communication rooms as needed; all spaces having telephone or computer data outlets shall be located to allow a maximum cable length of 90 m [295 feet] between outlet and communication room. Minimum dimensions of secondary communication rooms shall be 2134 mm [7'-0"] x 3048 mm [10'-0"]. Provide floor openings and vertical shaft spaces as necessary. Rooms shall be accessed from corridors. Access will be limited to authorized personnel.

2-4.11.3.1 Function: Distribution areas for telephone, data network, and cable television.

2-4.11.3.2 Adjacency requirements: Adjacent to corridor. Locate to allow efficient distribution.

2-4.11.3.3 Furnishings/Fixtures/Equipment: As required by Statement of Work.

2-4.11.3.4 Finishes: Floor: vinyl composition tile.

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: painted gypsum wallboard, painted veneer plaster, or suspended acoustical panel ceiling

2-4.11.3.5 Other requirements: Door shall have minimum 914 mm [3'-0"] wide door with storeroom function (F86) lockset. Provide three 102 mm [4"] empty conduits connecting vertically stacked communication rooms.

2-4.11.4 **Elevator Machine Room.** Provide one in each two-story battalion HQ building. Size to comply with equipment and code requirements.

2-4.11.4.1 Function: Space for hydraulic elevator equipment.

2-4.11.4.2 Adjacency requirements: Adjacent to elevator and corridor.

2-4.11.4.3 Furnishings/Fixtures/Equipment: As required by Statement of Work

2-4.11.4.4 Finishes: Floor: sealed concrete

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: none required.

2-4.11.4.5 Other requirements:

2-4.11.5 **Elevator.** Provide one hydraulic passenger elevator in each two-story battalion HQ.

2-4.11.5.1 Function: Vertical conveyance of people and furniture.

2-4.11.5.2 Adjacency requirements: Adjacent to lobby or main corridor.

2-4.11.5.3 Furnishings/Fixtures/Equipment: Passenger elevator: 2,500 lb. capacity, minimum 75 feet per minute speed; center opening doors. Refer to Chapter 5 for additional requirements.

2-4.11.5.4 Cab finishes: Floor: carpet

Walls: plastic laminate

Ceiling: suspended aluminum egg crate

Car door and front: satin finish stainless steel

Hoistway entrance doors and frame: satin finish stainless steel

2-4.11.5.5 Other requirements: Handicapped accessible.

## 2-5 **BRIGADE HEADQUARTERS FACILITY FUNCTIONAL AND AREA**

**REQUIREMENTS.** The brigade headquarters (HQ) building shall consist of administrative areas, soldier services areas, and support spaces. Provide one single-story brigade HQ building. Total gross building area shall not exceed 972.9 square meters (m<sup>2</sup>) [10,473 square feet (sf)] [Maximum gross area shall be as shown on form DD 1391]. To the greatest extent possible, the building shall be arranged to allow future reconfiguration of administrative office spaces: fixed elements such as toilets, equipment rooms, and core areas shall be located at the perimeter of administrative spaces; partitions separating administrative spaces should not be bearing walls.

Leadership and staff will manage the organization, receive visitors, and conduct the business of the brigade from the administrative areas (Command section, S-1/PAC, S-2, S-3, and S-4). Military personnel will staff the facility; military and non-military personnel will visit the facility to meet with leadership or soldier services staff (Chaplain, Surgeon, re-enlistment office). All spaces except shower rooms, and utility areas (janitor closets, mechanical, electrical, communication rooms) shall comply with handicapped accessibility requirements. Building spaces and areas shall be as follows:

2-5.1 **Command Section.** Provide one group of offices, with accompanying reception area, coffee area and private toilet. Command section shall be adjacent to the S-1/PAC Clerical/Central Files area. Reception area shall have direct access to corridor/lobby.

2-5.1.1 **Commanding Officer (CO).** Provide one; 21 m<sup>2</sup> [226 sf]. Room shall be accessed through the Reception Area. Occupants: 1, and occasional visitors.

2-5.1.1.1 Function: Private office for battalion commanding officer.

2-5.1.1.2 Adjacency requirements: Adjacent to Reception Area, S-1 Clerical /Central Files. Adjacent to or near command section toilet, coffee area, Executive Officer and Command Sergeant Major offices [modify this sentence to require direct access doors from CO to XO and CSM offices only if this is a *must-have* user requirement; requiring doors between these offices places additional restrictions on design of the floor plan]. Adjacent to Conference Room; provide door from CO office into Conference Room.

2-5.1.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [ ] one credenza [ ], one bookcase [ ], two legal-size four-drawer file cabinets, one conference table [ ], six side chairs, and one desk chair.

2-5.1.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.1.1.5 Other requirements: Provide 914 mm [3'-0"] wide doors into room from reception area and from Conference Room; doors shall have entry function (F81) lockset (CO office is secure side). Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-5.1.2 **Executive Officer (XO)**. Provide one; 13.9 m<sup>2</sup> [150 sf]. Room shall be accessed through the Reception Area. Occupants: 1, and occasional visitors.

2-5.1.2.1 Function: Private office for brigade executive officer.

2-5.1.2.2 Adjacency requirements: Adjacent to Reception Area, S-1/PAC Clerical /Central Files. Adjacent to or near command section toilet, coffee area, CO office and Command Sergeant Major office. modify this sentence if direct access door from CO to XO is required.

2-5.1.2.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [ ] with return [ ], one bookcase [ ], two legal-size four-drawer file cabinets, three side chairs, and one desk chair.

2-5.1.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.1.2.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-5.1.3 **Command Sergeant Major (CSM)**. Provide one; 13.9 m<sup>2</sup> [150 sf]. Room shall be accessed through the Reception Area. Occupants: 1, and occasional visitors.

2-5.1.3.1 Function: Private office for brigade command sergeant major.

2-5.1.3.2 Adjacency requirements: Adjacent to Reception Area, S-1 Clerical /Central Files. Adjacent to or near command section toilet, coffee area, CO office and Command Sergeant Major office. modify this sentence if direct access door from CO to XO is required.

2-5.1.3.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [ ] with return [ ], one bookcase [ ], two legal-size four-drawer file cabinets, three side chairs, and one desk chair.

2-5.1.3.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-4.1.2.6 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-5.1.4 **Reception Area.** Provide one area; 23.2 m<sup>2</sup> [250 sf] for reception desk and waiting area. Reception area shall be accessed directly from corridor/lobby, and also through the S-1/PAC Clerical/Central Files area. Occupants: 1, and space for six visitors.

2-5.1.4.1 Function: Receptionist workstation and waiting area for visitors to CO, XO, CSM offices.

2-5.1.4.2 Adjacency requirements: Adjacent to S-1/PAC Clerical/Central Files; adjacent to lobby or corridor. Adjacent to command section toilet, coffee area, CO, XO and Command Sergeant Major offices.

2-5.1.4.3 Furnishings/Fixtures/Equipment: Provide and design area to accommodate one reception desk (systems furniture workstation type [\_\_\_]), six side chairs and one magazine table.

2-5.1.4.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.1.4.5 Other requirements:

2-5.1.5 **Command Section Toilet.** Provide one private toilet room. Room shall be sized to comply with handicap accessibility requirements. Room shall be accessed from reception area.

2-5.1.5.1 Function: single-occupant toilet and lavatory, for use by command staff and visitors.

2-5.1.5.2 Adjacency requirements: Adjacent to reception area. Near CO, XO, and CSM offices.

2-5.1.5.3 Furnishings/Fixtures/Equipment (FFE): Provide one floor mounted toilet, one wall-hung lavatory, mirror with shelf above lavatory, Paper towel dispenser/waste receptacle, soap dispenser, toilet tissue dispenser, and wall mounted grab bars at toilet.

2-5.1.5.4 Finishes:

Floor: porcelain tile, or ceramic tile.

Base: porcelain tile, or ceramic tile.

Walls: ceramic tile

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster.

2-5.1.5.5 Other requirements: Door shall have privacy function (F76) lockset. Arrange space

so that door does not open directly into reception area. Partitions shall have minimum STC rating of 49.

2-5.1.6 **Coffee Area.** Provide one. Area shall have countertop with kitchen sink; comply with handicap accessibility requirements.

2-5.1.6.1 Function: Sink and space for coffee maker and supplies; for use by command section staff and visitors.

2-5.1.6.2 Adjacency requirements: Adjacent to Reception Area. Near CO, XO, and CSM offices. Locate to avoid conflicts with circulation pattern.

2-5.1.6.3 Furnishings/Fixtures/Equipment (FFE): Provide minimum 1219 mm wide x 610 mm deep [4'-0" x 2'-0"] plastic laminate countertop, with stainless steel kitchen sink. Provide minimum 1219 mm of wall cabinets; mounted to provide 610 mm clearance above countertop [verify with user that proposed coffee maker will fit in this space]. Provide dedicated electrical receptacle for coffee maker (coffee maker not in contract).

2-5.1.6.4 Finishes:

Floor: porcelain tile, or ceramic tile.

Base: porcelain tile, or ceramic tile.

Walls: painted gypsum wallboard or painted veneer plaster.

Ceiling: suspended acoustical panel ceiling.

2-5.1.6.5 Other requirements:

2-5.2 **S-1/PAC Section.** Provide one group of offices.

2-5.2.1 **S-1 Officer.** Provide one; 8.8 m<sup>2</sup> [95 sf]. Room shall be accessed through the S-1/PAC Clerical/Central Files area. Occupants: 1, and occasional visitors.

2-5.2.1.1 Function: Private office for S-1 officer.

2-5.2.1.2 Adjacency requirements: Adjacent to S-1/PAC Clerical/Central Files. Near Command Section offices.

2-5.2.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one side chair, and one desk chair.

2-5.2.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.2.1.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-5.2.2 **Office.** Provide three; each 8.8 m<sup>2</sup> [95 sf]. Area may be a private office or a

systems furniture workstation accessed through the S-1/PAC Clerical/Central Files area.  
Occupants: 1 in each office [verify with user].

2-5.2.2.1 Function: Private office for use by S-1/PAC personnel.

2-5.2.2.2 Adjacency requirements: Adjacent to S-1/PAC Clerical /Central Files.

2-5.2.2.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one side chair, and one desk chair. If systems furniture panels are provided in lieu of drywall partitions, provide workstation type \_\_\_\_.

2-5.2.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.2.2.5 Other requirements: Exterior window is desirable. If drywall partitions are used, provide 914 mm [3'-0"] wide door into each room; door shall have entry function (F81) lockset. Drywall partitions shall have minimum STC rating of 49.

2-5.2.3 **S-1/PAC Clerical/Central Files.** Provide one; 113 m<sup>2</sup> [1,216 sf]. S-1 Clerical/Central Files shall be accessed from the lobby or corridor. The area shall have direct access to S-1/PAC and Command Section private offices. Occupants: 10 staff and occasional visitors.

2-5.2.3.1 Function: Open office area for S-1/PAC admin staff; access to S-1/PAC and Command offices.

2-5.2.3.2 Adjacency requirements: Adjacent to lobby or corridor. Adjacent to S-1/PAC and Command private offices.

2-5.2.3.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate ten type [\_\_\_\_] systems furniture workstations.

2-5.2.3.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.2.3.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Exterior window is desirable. Partitions shall have minimum STC rating of 49. Minimum ceiling height 2642 mm [8'-8"].

2-5.2.4 **Duty Officer.** Provide one; 8.9 m<sup>2</sup> [96 sf]. Room shall be located to have visual control of the lobby/main corridor. Occupants: 1.

2-5.2.4.1 Function: Duty Officer will provide physical security of the building, and visual control of the entrances and lobby, as well as functioning as an information source for visitors.

2-5.2.4.2 Adjacency requirements: Adjacent to lobby/main corridor; adjacent to, and accessed from, S-1/PAC Clerical /Central Files.

2-5.2.4.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one legal-size four-drawer file cabinet, one side chair, and one desk chair.

2-5.2.4.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.2.4.5 Other requirements: Provide 914 mm [3'-0"] wide door into room from S-1/PAC Clerical Central Files area.; door shall have entry function (F81) lockset and glass vision panel. Provide duty officer counter (built-in casework) minimum 1829 mm [6'-0"] long separating the Duty Officer room from the lobby/corridor. The counter on the corridor side shall be minimum 1524 mm wide x 1016 mm high x 305 mm deep; provide locking overhead coiling shutter to secure the opening when unattended; shutter hood shall not be visible from corridor side. [modify requirement for sliding pass-through window above counter if requested by user].

2-5.2.5 **Message Mail Center.** Provide one; 19 m<sup>2</sup> [205 sf]. Room shall be accessed from the PAC Clerical/Central Files area. Occupants: [\_\_\_\_].

2-5.2.5.1 Function: Mail sorting [add to description of function].

2-5.2.5.2 Adjacency requirements: Adjacent to corridor/lobby; adjacent to, and accessed from, S-1/PAC Clerical/Central Files.

2-5.2.5.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate [insert furniture requirements]

2-5.2.5.4 Finishes:

Floor: vinyl composition tile, or porcelain tile

Base: resilient base, or porcelain tile base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.2.5.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset and glass vision panel. Provide counter (built-in casework) minimum 1829 mm [6'-0"] long separating the Message Mail Center from the corridor. The counter on the corridor side shall be minimum 1524 mm wide x 1016 mm high x 305 mm deep; provide locking overhead coiling shutter to secure the opening when unattended; shutter hood shall not be visible from corridor side [modify requirement for sliding pass-through window above counter if requested by user].

2-5.2.6 **Supply Room.** Provide one; 12 m<sup>2</sup> [130sf]. Room shall be under control of, and located near, S-1/PAC Clerical/Central Files area. Room will be used by all administrative sections; provide access from main corridor.

2-5.2.6.1 Function: Storage of [identify type of items to be stored] for administrative sections.

2-5.2.6.2 Adjacency requirements: Adjacent to main corridor; near S-1 Clerical/Central Files and other admin functions.

2-5.2.6.3 Furnishings/Fixtures/Equipment: [insert shelving requirement].

2-5.2.6.4 Finishes: Floor: sealed concrete, or vinyl composition tile

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: suspended acoustical panel ceiling

2-5.2.6.5 Other requirements: Provide 914 mm [3'-0"] wide door into room from corridor; door shall have storeroom function (F86) lockset;

2-5.3 **S-2 Section.** Provide one group of offices.

2-5.3.1 **S-2 Officer.** Provide one; 8.8 m<sup>2</sup> [95 sf]. Room shall be accessed through the S-2 Clerical/Central Files area. Occupants: 1, and occasional visitors.

2-5.3.1.1 Function: Private office for S-2 officer.

2-5.3.1.2 Adjacency requirements: Adjacent to S-2 Clerical/Central Files.

2-5.3.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one side chair, and one desk chair.

2-5.3.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.3.1.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-5.3.2 **Signal Office.** Provide one; each 14.8 m<sup>2</sup> [160 sf]. Room shall be accessed through the S-2 Clerical/Central Files area. Occupants: 1 [verify with user].

2-5.3.2.1 Function: Private office for Signal Officer [verify function with user].

2-5.3.2.2 Adjacency requirements: Adjacent to S-2 Clerical /Central Files.

2-5.3.2.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one side chair, and one desk chair [verify with user]

2-5.3.2.4 Finishes:

Floor: carpet

**Project Name**  
**UEPH Complex**

**Project Number**  
**Statement of Work**  
**26 November 2001**

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.3.2.5 Other requirements: Room shall have exterior window. Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Partitions shall have minimum STC rating of 49.

2-5.3.3 **Office.** Provide one; each 8.8 m<sup>2</sup> [95 sf]. Area may be a private office or a systems furniture workstation accessed through the S-2 Clerical/Central Files area. Occupants: 1 [verify with user].

2-5.3.3.1 Function: Private office for use by S-2 personnel.

2-5.3.3.2 Adjacency requirements: Adjacent to S-2 Clerical /Central Files.

2-5.3.3.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one side chair, and one desk chair. If systems furniture panels are provided in lieu of drywall partitions, provide workstation type \_\_\_\_.

2-5.3.3.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.3.3.5 Other requirements: Exterior window is desirable. If drywall partitions are used, provide 914 mm [3'-0"] wide door into each room; door shall have entry function (F81) lockset. Drywall partitions shall have minimum STC rating of 49.

2-5.3.4 **S-2 Clerical/Central Files.** Provide one; 36 m<sup>2</sup> [388 sf]. S-2 Clerical/Central Files shall be accessed from the lobby or corridor. The area shall have direct access to S-2 private offices, Secured Documents Vault, and Signal office. Occupants: 4 staff, and occasional visitors.

2-5.3.4.1 Function: Open office area for S-2 admin staff; access to other S-2 spaces.

2-5.3.4.2 Adjacency requirements: Adjacent to lobby or corridor. Adjacent to S-2 private offices, Signal office, and Secured Documents Vault.

2-5.3.4.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate four type [\_\_\_\_] systems furniture workstations.

2-5.3.4.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.3.4.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have

entry function (F81) lockset. Exterior window is desirable. Partitions shall have minimum STC rating of 49. Minimum ceiling height 2642 mm [8'-8"].

2-5.3.5 **Secured Documents Vault.** Provide one room; 14.9 m<sup>2</sup> [160 sf]. Vault shall be certified for open storage of secret material. Class M Modular construction is acceptable. Provide Class 5 vault door with day gate [verify all vault criteria with user]. To allow future flexibility in reconfiguring offices areas, locate vault on the perimeter of the administrative areas. Occupants: 1 [verify with user].

2-5.3.5.1 Function: Storage of documents classified 'secret' and below. Space for crypto equipment. Workspace for one clerk.

2-5.3.5.2 Adjacency requirements: Adjacent to and accessed from S-2 Clerical/Central Files.

2-5.3.5.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], [insert shelving or file cabinet requirements], and one desk chair. [Insert crypto equipment requirements].

2-5.3.5.4 Finishes:

Floor: vinyl composition tile

Base: resilient base

Walls: painted or pre-finished modular vault panels

Ceiling: painted or pre-finished modular vault panels

2-5.3.5.5 Other requirements:

2-5.4 **S-3 Section.** Provide one group of offices.

2-5.4.1 **S-3 Officer.** Provide one; 8.8 m<sup>2</sup> [95 sf]. Room shall be accessed through the S-3 Clerical/Central Files area. Occupants: 1, and occasional visitors.

2-5.4.1.1 Function: Private office for S-3 officer.

2-5.4.1.2 Adjacency requirements: Adjacent to S-3 Clerical /Central Files.

2-5.4.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one side chair, and one desk chair.

2-5.4.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.4.1.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-5.4.2 **Office.** Provide four; each 8.8 m<sup>2</sup> [95 sf]. Area may be a private office or a systems furniture workstation accessed through the S-3 Clerical/Central Files area. Occupants: 1 in

each office [verify with user].

2-5.4.2.1 Function: Private office or systems furniture workstation for use by S-3 personnel.

2-5.4.2.2 Adjacency requirements: Adjacent to S-3 Clerical /Central Files.

2-5.4.2.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two legal-size four-drawer file cabinets, one side chair, and one desk chair. If systems furniture panels are provided in lieu of drywall partitions, provide workstation type \_\_\_\_.

2-5.4.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.4.2.5 Other requirements: Exterior window is desirable. If drywall partitions are used, provide 914 mm [3'-0"] wide door into each room; door shall have entry function (F81) lockset. Drywall partitions shall have minimum STC rating of 49.

2-5.4.3 **S-3 Clerical/Central Files.** Provide one; 94.8 m<sup>2</sup> [1,020 sf]. S-3 Clerical/Central Files shall be accessed from the lobby or corridor. The area shall have direct access to S-3 private offices. Occupants: 8 staff , and occasional visitors.

2-5.4.3.1 Function: Open office area for S-3 admin staff; access to S-3 offices.

2-5.4.3.2 Adjacency requirements: Adjacent to lobby or corridor. Adjacent to S-3 private offices.

2-5.4.3.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate eight type \_\_\_\_ systems furniture workstations.

2-5.4.3.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.4.3.5

Other requirements:

Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset.

Exterior window is desirable. Partitions shall have minimum STC rating of 49. Minimum ceiling height 2642 mm [8'-8"].

2-5.5 **S-4 Section.** Provide one group of offices. In a two-story building locate S-4 Section on the first floor. Locate S-4 Section adjacent to PAC Section.

2-5.5.1 **S-4 Officer.** Provide one; 8.8 m<sup>2</sup> [95 sf]. Room shall be accessed through the S-4 Clerical/Central Files area. Occupants: 1, and occasional visitors.

2-5.5.1.1 Function: Private office for S-4 officer.

2-5.5.1.2 Adjacency requirements: Adjacent to S-4 Clerical /Central Files.

2-5.5.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [ ] with return [ ], one bookcase [ ], two legal-size four-drawer file cabinets, one side chair, and one desk chair.

2-5.5.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.5.1.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-5.5.2 **Office.** Provide two; each 8.8 m<sup>2</sup> [95 sf]. Area may be a private office or a systems furniture workstation accessed through the S-4 Clerical/Central Files area. Occupants: 1 in each office [verify with user].

2-5.5.2.1 Function: Private office or systems furniture workstation for use by S-4 personnel.

2-5.5.2.2 Adjacency requirements: Adjacent to S-4 Clerical /Central Files.

2-5.5.2.3 Furnishings/Fixtures/Equipment: Provide and design each area to accommodate one desk [ ] with return [ ], one bookcase [ ], two legal-size four-drawer file cabinets, one side chair, and one desk chair. If systems furniture panels are provided in lieu of drywall partitions, provide workstation type \_\_\_\_.

2-5.5.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.5.2.5 Other requirements: Exterior window is desirable. If drywall partitions are used, provide 914 mm [3'-0"] wide door into each room; door shall have entry function (F81) lockset. Drywall partitions shall have minimum STC rating of 49.

2-5.5.3 **S-4 Clerical/Central Files.** Provide one; 58 m<sup>2</sup> [625 sf]. S-4 Clerical/Central Files shall be accessed from the lobby or corridor. The area shall have direct access to S-4 private offices. Occupants: 6 staff , and occasional visitors.

2-5.5.3.1 Function: Open office area for S-4 admin staff; access to S-4 offices.

2-5.5.3.2 Adjacency requirements: Adjacent to lobby or corridor. Adjacent to S-4 private offices.

2-5.5.3.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate six type \_\_\_\_ systems furniture workstations.

2-5.5.3.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.5.3.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Exterior window is desirable. Partitions shall have minimum STC rating of 49. Minimum ceiling height 2642 mm [8'-8"].

2-5.6 **Conference Room.** Provide one; 36 m<sup>2</sup> [455 sf] Room shall be located to allow direct access from the main corridor/lobby and the CO office. Occupants: up to 30 persons.

2-5.6.1 Function: Conference room for brigade leadership, staff, and visitors. Functions will include staff meetings, hearings, disciplinary sessions, training.

2-5.6.2 Adjacency requirements: Adjacent to lobby or corridor; adjacent to CO office. Near other administrative sections.

2-5.6.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate [Coordinate furniture requirements with user]. Provide one marker board (minimum 2438 mm wide x 1219 mm high [8'-0" x 4'-0"]) and one 2438 mm wide [8'-0"] wall mounted pull-down projection screen.

2-5.6.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.6.5 Other requirements: Provide 914 mm [3'-0"] wide doors into room; doors shall have classroom function (F84) lockset. Partitions shall have minimum STC rating of 55. Minimum ceiling height 2642 mm [8'-8"].

2-5.7 **Soldier Services.** Provide one group of offices. Soldier services are unrelated to other battalion administration functions; locate off of main lobby/corridor.

2-5.7.1 **Chaplain's Assistant.** Provide one; 7.9 m<sup>2</sup> [85 sf]. Room shall be accessed from the lobby or main corridor. Occupants: 1, and visitors.

2-5.7.1.1 Function: Private office for Chaplain's Assistant and waiting area for visitors to Chaplain's office.

2-5.7.1.2 Adjacency requirements: Adjacent to lobby or main corridor.

2-5.7.1.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], two side chairs, and one desk chair.

2-5.7.1.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster  
Ceiling: suspended acoustical panel ceiling

2-5.7.1.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Exterior window is desirable. Partitions shall have minimum STC rating of 55.

2-5.7.2 **Chaplain.** Provide one; 9.8 m<sup>2</sup> [105 sf]. Room shall be accessed from the Chaplain's Assistant office, and the corridor. Occupants: 1, and visitors.

2-5.7.2.1 Function: Private office for Chaplain and visitors.

2-5.7.2.2 Adjacency requirements: Adjacent to Chaplain's Assistant, and corridor

2-5.7.2.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], one desk chair, and [insert furniture requirements].

2-5.7.2.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.7.2.5 Other requirements: Provide 914 mm [3'-0"] wide doors into room; doors shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-5.7.3 **Surgeon.** Provide one; 9.8 m<sup>2</sup> [105 sf]. Room shall be accessed from the corridor/lobby. Occupants: 1, and visitors.

2-5.7.3.1 Function: Private office for brigade surgeon (doctor).

2-5.7.3.2 Adjacency requirements: Adjacent to corridor/main lobby.

2-5.7.3.3 Furnishings/Fixtures/Equipment: Provide and design room to accommodate one desk [\_\_\_\_] with return [\_\_\_\_], one bookcase [\_\_\_\_], one side chair, and one desk chair.

2-5.7.3.4 Finishes:

Floor: carpet

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling

2-5.7.3.5 Other requirements: Provide 914 mm [3'-0"] wide door into room; door shall have entry function (F81) lockset. Room shall have exterior window. Partitions shall have minimum STC rating of 55.

2-5.7.4 **Supply Closet.** Provide one; 1.9 m<sup>2</sup> [20 sf]. Room shall be accessed from the corridor. Occupants: none.

2-5.7.4.1 Function: storage closet for supplies used by soldier services functions.

2-5.7.4.2 Adjacency requirements: Adjacent to soldier services spaces and corridor.

2-5.7.4.3 Furnishings/Fixtures/Equipment: Provide [add shelving requirement].

2-5.7.4.4 Finishes:

Floor: carpet or vinyl composition tile

Base: resilient base

Walls: painted gypsum wallboard or painted veneer plaster

Ceiling: suspended acoustical panel ceiling, painted gypsum wallboard, or painted veneer plaster.

2-5.7.4.5 Other requirements:

2-5.8 **Brigade HQ Common Areas.** Provide the following areas in each building. Handicapped accessibility is required in all common areas except janitor closet and shower rooms.

2-5.8.1 **Lobby and Corridors.** Provide as required to allow access to building spaces. Unless otherwise required, minimum width of lobby/main corridor shall not be less than 3048 mm [10'-0"]; minimum width of other major corridors shall not be less than 1829 mm [6'-0"]. Corridor width shall comply with applicable egress codes.

2-5.8.1.1 Function: Entry to the facility; egress and circulation through the building.

2-5.8.1.2 Adjacency requirements: Adjacent to main entrances. It is preferable to enter lobby/main corridor from two sides of the building.

2-5.8.1.3 Furnishings/Fixtures/Equipment: Provide wall mounted electric water cooler. Provide mechanical and electrical systems to comply with applicable codes. Provide fire extinguishers in semi-recessed fire extinguisher cabinets to comply with applicable codes. Provide recessed space for one vending machine (machine is not in contract). Provide interior signage to identify major spaces. Provide two recessed trophy cases (minimum size: 2438 mm wide x 1524 high x 406 mm deep); provide one recessed building directory near each main entrance. Provide one 1219 mm high x 1829 mm wide [4'-0" x 6'-0"] wall mounted bulletin board.

2-5.8.1.4 Finishes:

Floor: porcelain tile, vinyl composition tile, or carpet.

Base: porcelain tile, stained wood base, or resilient cove base.

Walls: painted gypsum wallboard, or painted veneer plaster.

Ceiling: suspended acoustical panel ceiling

2-5.8.1.5 Other requirements: Handicap accessible.

2-5.8.2 **Entry Vestibules.** Provide at each exterior entrance to lobby/main corridor area. [If climate dictates, revise this sentence to require vestibules at all entrances to the building.]

2-5.8.1.1 Function: Primary entry point into the facility; weather protection for interior spaces.

2-5.8.1.2 Adjacency requirements: Adjacent to lobby/main corridor.

2-5.8.1.3 Furnishings/Fixtures/Equipment:

2-5.8.1.4 Finishes:

Floor: Provide recessed entry mat full depth of vestibule x full width of doors; porcelain tile, or quarry tile in remainder of room.

Base: porcelain tile or quarry tile

Walls: Match exterior wall finish material, or painted gypsum wallboard, or painted veneer plaster

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster.

2-5.8.1.5 Other requirements: Handicap accessible.

2-5.8.2 **Men's Toilet Room.** Provide one room, sized to accommodate the number of plumbing fixtures required. Toilet room will be accessed from corridors. Arrange entrance to provide visual privacy.

2-5.8.2.1 Function: Restrooms for male occupants.

2-5.8.2.2 Adjacency requirements: Adjacent to corridor.

2-5.8.2.3 Furnishings/Fixtures/Equipment: Provide 2 lavatories, 3 floor mounted toilets, and 2 wall-hung urinals. Lavatories shall be countertop mounted. Countertops shall be plastic laminate or solid surfacing material. Provide toilet partitions at each toilet, and urinal partitions between urinals. Provide the following toilet accessories: one continuous mirror full width of countertop at countertop mounted lavatories; one paper towel dispenser/waste receptacle per toilet room; one soap dispenser per lavatory; one toilet tissue dispenser per toilet; one robe hook on each toilet partition door.

2-5.8.2.4 Finishes:

Floor: porcelain tile, or ceramic tile.

Base: porcelain tile, or ceramic tile.

Walls: ceramic tile, or 1829 mm high ceramic tile wainscot with painted impact resistant gypsum wallboard or painted concrete masonry units above.

Ceiling: painted Portland cement plaster, or painted gypsum wallboard or veneer plaster.

2-5.8.2.5 Other requirements:

2-5.8.3 **Women's Toilet Room(s).** Provide one room, sized to accommodate the number of plumbing fixtures required. Toilet rooms will be accessed from corridors. Arrange entrance to provide visual privacy.

2-5.8.3.1 Function: Restrooms for female occupants.

2-5.8.3.2 Adjacency requirements: Adjacent to corridor.

2-5.8.3.3 Furnishings/Fixtures/Equipment: Provide 3 lavatories and 3 floor mounted toilets. Lavatories shall be countertop mounted. Countertops shall be plastic laminate or solid surfacing material. Provide toilet partitions at each toilet. Provide the following toilet accessories: one continuous mirror full width of countertop; one paper towel dispenser/waste receptacle per toilet room; one soap dispenser per lavatory; one toilet tissue dispenser per toilet; one sanitary napkin disposal at each toilet; one robe hook on each toilet partition door.

2-5.8.3.4 Finishes:

Floor: porcelain tile, or ceramic tile.

Base: porcelain tile, or ceramic tile.

Walls: ceramic tile, or 1829 mm high ceramic tile wainscot with painted impact resistant gypsum wallboard or painted concrete masonry units above.

Ceiling: painted Portland cement plaster, or painted gypsum wallboard or veneer plaster.

2-5.8.3.5 Other requirements:

2-5.8.4 **Shower Room.** Provide two. Rooms shall be used by able-bodied military personnel only. Rooms shall be accessed from corridor. Showers shall not be combined with toilet rooms.

2-5.8.4.1 Function: Private shower and dressing room for use by brigade staff.

2-5.8.4.2 Adjacency requirements: Adjacent to corridor. Near toilets.

2-5.8.4.3 Furnishings/Fixtures/Equipment: Provide one ceramic tile shower with rod and shower curtain. Shower shall have ceramic soap holder and wall mounted grab bar. Dressing area shall have bench, four towel/robe hooks, and wall mounted full-length mirror. Provide floor drain at dressing area, locate outside of circulation path.

2-5.8.4.4 Finishes:

Floor: ceramic tile.

Base: ceramic tile.

Walls: ceramic tile

Ceiling: painted Portland cement plaster.

2-5.7.5.5 Other requirements:

2-5.8.5 **Janitor Closet.** Provide one. Minimum area: 2.3 m<sup>2</sup> [25 sf]. Room shall be accessed from corridor.

2-5.8.5.1 Function: Sink and storage of cleaning supplies, soap, paper products.

2-5.8.5.2 Adjacency requirements: Near toilets and shower rooms.

2-5.8.5.3 Furnishings/Fixtures/Equipment: Provide one floor mounted mop sink, mop rack for two mops, and minimum 1524 linear mm of wall mounted stainless steel shelving.

2-5.8.5.4 Finishes:

Floor: ceramic tile, or sealed concrete

Base: resilient cove base, or ceramic tile base

Walls: painted water-resistant gypsum wallboard, or painted concrete masonry units

Ceiling: painted gypsum wallboard, painted veneer plaster, or painted Portland cement plaster

2-5.8.5.5 Other requirements: Door shall have classroom function (F84) lockset.

2-5.8.6 **Storage.** Provide minimum 4.6 m<sup>2</sup> [50sf] of general storage space. Storage room will be accessed from the corridor.

2-5.8.6.1 Function: Storage of [identify type of items to be stored] for the brigade.

2-5.8.6.2 Adjacency requirements: Adjacent to corridor/lobby

2-5.8.6.3 Furnishings/Fixtures/Equipment: [insert shelving requirement].

2-5.8.6.4 Finishes: Floor: sealed concrete

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: suspended acoustical panel ceiling

2-5.8.6.5 Other requirements: Door shall have storeroom function (F86) lockset.

2-5.9 **Battalion HQ Support Areas.** Provide the following areas in each battalion HQ building. Handicapped accessibility is not required in mechanical rooms, electrical and communications closets. All other support spaces shall be handicap accessible.

2-5.9.1 **Mechanical Room(s).** Provide dedicated areas for mechanical equipment. Mechanical rooms shall not be used for storage or other purposes. Access will be limited to authorized personnel. Size and locate room(s) to allow equipment removal and maintenance. Provide floor openings and vertical shaft spaces as necessary.

2-5.9.1.1 Function: Spaces for HVAC, water heating, and other plumbing and mechanical equipment.

2-5.9.1.2 Adjacency requirements: Locate to allow efficient distribution. Mechanical rooms shall have doors opening to the exterior.

2-5.9.1.3 Furnishings/Fixtures/Equipment: As required by Statement of Work.

2-5.9.1.4 Finishes: Floor: sealed concrete

Base: resilient cove base, or none.

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: none required

2-5.9.1.5 Other requirements: Doors shall have storeroom function (F86) locksets.

2-5.9.2 **Electrical Room(s).** Provide dedicated areas for electrical equipment. Electrical rooms shall not be used for storage or other purposes. Access will be limited to authorized personnel. Size and locate room(s) to allow equipment removal and maintenance.

2-5.9.2.1 Function: Spaces for electrical equipment.

2-5.9.2.2 Adjacency requirements: Locate to allow efficient distribution. Electrical rooms shall be accessed from the exterior or from corridors.

2-5.9.2.3 Furnishings/Fixtures/Equipment: As required by Statement of Work.

2-5.9.2.4 Finishes: Floor: sealed concrete

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: none required.

2-5.9.2.5 Other requirements: Electrical service to buildings shall be underground. Doors shall have storeroom function (F86) locksets.

2-5.9.3 **Communication Room.** Provide dedicated room(s) for communication distribution equipment. Each room shall be dedicated to communications equipment, and shall not be combined with mechanical or electrical rooms. Provide one main communication room; minimum size 3048 mm [10'-0"] x 3353 mm [11'-0"]. In two-story buildings, the communication room shall be located on the second floor. Provide additional communication rooms as needed; all spaces having telephone or computer data outlets shall be located to allow a maximum cable length of 90 m [295 feet] between outlet and communication room. Minimum dimensions of secondary communication rooms shall be 2134 mm [7'-0"] x 3048 mm [10'-0"]. Provide floor openings and vertical shaft spaces as necessary. Rooms shall be accessed from corridors. Access will be limited to authorized personnel.

2-5.9.3.1 Function: Distribution areas for telephone, data network, and cable television.

2-5.9.3.2 Adjacency requirements: Adjacent to corridor. Locate to allow efficient distribution.

2-5.9.3.3 Furnishings/Fixtures/Equipment: As required by Statement of Work.

2-5.9.3.4 Finishes: Floor: vinyl composition tile

Base: resilient cove base

Walls: painted gypsum wallboard or painted veneer plaster, or painted concrete masonry units

Ceiling: painted gypsum wallboard, painted veneer plaster, or suspended acoustical panel ceiling

2-5.9.3.5 Other requirements: Provide minimum 914 mm [3'-0"] wide door with storeroom function (F86) lockset.

## **CHAPTER 3**

### **SITE PLANNING AND DESIGN**

3-1 **SCOPE OF WORK.** This project consists of constructing [Insert No. Of Units] [Unaccompanied Enlisted Personnel Housing (UEPH) Units] [Company Operations Facilities (COF)] [Battalion and Brigade Headquarters Facilities]. Imaginative site design is encouraged, however, the site boundaries and project composition are fixed. Based on the graphic and narrative description[s] of site opportunities and constraints provided, the offeror shall verify that the site meets the program requirements.

3-2 **SITE VERIFICATION.** Graphic and narrative descriptions of site opportunities and constraints have been provided. [Insert a description of information being provided or made available to the offerors, and the process to obtain the information. Address offeror access to base maps, as-built documents of existing facilities, points of contact with private, public and Government utilities, and related materials.] Each offeror shall verify that the site meets the program requirements. [Obtain the site analysis and the documented site opportunities and constraints to verify that the site meets the [Unaccompanied Enlisted Personnel Housing (UEPH) Units] [Company Operations Facilities (COF)] [Battalion and Brigade Headquarters Facilities] requirements that are provided. The site analysis can be obtained from [insert appropriate individual].] [No site analysis has been provided. The offeror shall perform a detailed site analysis to verify that the site meets the [Unaccompanied Enlisted Personnel Housing (UEPH) Units] [Company Operations Facilities (COF)] [Battalion and Brigade Headquarters Facilities] requirements that are provided.] [The analysis results [are] [shall be] documented in a written and graphic summary of site opportunities and constraints for [Unaccompanied Enlisted Personnel Housing (UEPH) Units] [Company Operations Facilities (COF)] [Battalion and Brigade Headquarters Facilities]]. If the site is found to be unsuitable by an offeror, [insert appropriate action to be taken by offeror (i.e. suggest alternate available site, possible site remediation, etc)].

3-3 **EXISTING CONDITIONS.** The offeror shall be provided with a [digital] [hard copy] topographic survey for this site by the Government. It is the offeror's responsibility to verify the Government-furnished survey and obtain all additional survey information that may be required for a completed design and construction project. Any discrepancies which are found in the Government furnished survey shall be brought to the immediate attention of the Contracting Officer for clarification.

3-3.1 **Station Maps.** Maps of the existing utility distribution systems including commercially owned utilities (i.e.: telephone, cable television, gas, etc.) may be obtained from the [Public Works Department] [Insert appropriate office] at the installation. [Insert other relevant information such as points of contact, restrictions on access to certain areas, hours of operation, phone and fax numbers, etc.] The locations of existing utilities shown on the site survey and utility maps are approximate only. The offeror shall scan the construction site with electromagnetic or sonic equipment and mark the surface of the ground where existing underground utilities are discovered. Immediately contact the [Contracting Officer] if actual conditions vary from the topographic survey.

3-4 **EXCAVATION PERMITS.** The contractor shall obtain approved station excavation permits prior to digging. Request for excavation permits shall be in accordance with installation policies. [List additional requirements for contacting local utility companies prior to performing excavations.] [Delete this wording and insert "Not required." if the activity does not require excavation permits.]

3-5 **SITE DEVELOPMENT PLAN.** Provide a site development plan that shows the spatial and functional arrangement of all [Unaccompanied Enlisted Personnel Housing (UEPH) Units] [Company Operations Facilities (COF)] [Battalion and Brigade Headquarters Facilities] requirements. The plan should ensure an economical, compatible and functional land use development that utilizes the advantages of the site, fosters visual order, [Insert “and provides a sense of community” when constructing UEPH Units]. The site development plan shows consideration for the site opportunities and constraints, program requirements, and specific site design criteria and guidance provided. [The installation shall provide the contractor a copy of the recommendations of the Installation Real Property Master Plan and the Installation Design Guide. These recommendations should be addressed.]

3-5.1 **Land Use.** The plan for the area should reflect an optimum balance of floor area, open space, and pedestrian and vehicular circulation. The plan should show an efficient, organized and economical land use arrangement that is compatible and functional. This plan should show the relationship of the area to adjacent land uses. [Insert specific installation criteria].

[3-5.2 **Noise Mitigation.** Insert specific installation requirements.]

3-5.3 **Buffer Area.** Provide appropriate buffer areas to separate and visually isolate the [Unaccompanied Enlisted Personnel Housing (UEPH) Units]] [Company Operations Facilities (COF)] [Battalion and Brigade Headquarters Facilities] from [Insert specific installation criteria]. [Note that greater emphasis should be used to foster a sense of community within the UEPH Complex, while separating the “work” areas from the “home” areas to the greatest extent possible.]

[3-5.4 **Orientation.** Orient the Unaccompanied Enlisted Personnel Housing (UEPH) to the maximum extent possible within the constraints of the site available to facilitate pedestrian traffic within the complex. Orientation shall be functional, and encourage unit cohesion. [Insert additional orientation requirements that are dependent upon known site constraints.] Additionally, solar orientation should be considered so that the long axis of the building is within 20 degrees east or west of true South, so that a major section of the roof faces within 20 degrees of South. The purpose of solar orientation is to expose a minimum surface area to direct solar gain while allowing the units the potential for passive solar applications. Additional consideration will be given during the quality evaluations with respect to unit orientations and passive solar applications considered and included. For additional passive solar information and considerations, see chapter 11 of this Statement of Work. ] [Edit if necessary where known site constraints preclude compliance with this requirement.] [Insert Installation Criteria.]

[3-5.5 **Orientation.** Orient the Company Operations Facilities (COF) to the maximum extent possible within the constraints of the site available to facilitate pedestrian traffic within the complex. Orientation shall be functional, and encourage unit cohesion. [Insert additional orientation requirements that are dependent upon known site constraints.] Additionally, solar orientation should be considered so that the long axis of the building is within 20 degrees east or west of true South, so that a major section of the roof faces within 20 degrees of South. The purpose of solar orientation is to expose a minimum surface area to direct solar gain while allowing the units the potential for passive solar applications. Additional consideration will be given during the quality evaluations with respect to unit orientations and passive solar applications considered and included. For additional passive solar information and considerations, see chapter 11 of this Statement of Work. ] [Edit if necessary where known site constraints preclude compliance with this requirement.] [Insert Installation Criteria.]

[3-5.6 **Orientation.** Orient the Battalion and Brigade Headquarters Facilities to the maximum

extent possible within the constraints of the site available to facilitate pedestrian traffic within the complex. Orientation shall be functional, and encourage unit cohesion. [Insert additional orientation requirements that are dependent upon known site constraints.] Additionally, solar orientation should be considered so that the long axis of the building is within 20 degrees east or west of true South, so that a major section of the roof faces within 20 degrees of South. The purpose of solar orientation is to expose a minimum surface area to direct solar gain while allowing the units the potential for passive solar applications. Additional consideration will be given during the quality evaluations with respect to unit orientations and passive solar applications considered and included.

For additional passive solar information and considerations, see chapter 11 of this Statement of Work. ] [Edit if necessary where known site constraints preclude compliance with this requirement.] [Insert Installation Criteria.]

3-6 **GRADING AND DRAINAGE.** The grading should maintain existing topography while recognizing standard gradients. There should be a balance of the quantity of cut and fill soils which would create a smooth transition of graded areas into the existing natural site. The plan should reflect selective site clearing that preserves groups of trees. Grading should manage site runoff to maintain rate of flow and quantity to pre-construction levels, or reduce site runoff where possible. The principles of positive drainage should be applied to control the conditions that remove rainfall away from facilities and functions. Site designs should seek to minimize the disturbance of land, and utilize natural drainage paths where possible. Federal, State and local regulations regarding the design of stormwater management systems shall be considered the minimum design criteria. [Insert additional installation requirements for grading and drainage.] [Address [NPDES] permits required for construction activities.] Additionally, minimize the impact of construction activities on drainage and prevent loss of soils by water and wind erosion. Designs which improve on existing water quality by incorporating sustainable design principles are encouraged, consistent with budget constraints and activity requirements.

3-7 **GENERAL SITE DESIGN CRITERIA.** The following are to be used as guidance for site design. Minimum spacing between buildings shall be [Insert Installation Minimum Setback Requirements]. Analyze the existing site conditions (i.e.; land use, community facilities, off-site workplaces, etc.) and incorporate a site design that results in an aesthetically pleasing and functional design. The site design shall address the following: orientation, site organization, spatial balance, character and scale, compatibility, life safety, circulation systems, view of the site, buffer zones, wind and noise control, land forms (i.e.; mounds, swales, ponds, etc.), lawns and shaded areas, vehicular access, a minimum of [Insert the Minimum Spaces Required by the Installation] parking spaces for staff, residents, handicapped, visitors, service, and motorcycles, service entrances, bus routes, connecting walks, utility corridors, fire protection access, site lighting, site furnishings, mechanical enclosures, trash collection dumpsters with trash enclosures, landscaping, and etc. [Dining facilities are to be located within walking distance to the UEPH Complex, and constructed by separate contract.] [Insert exact location and size of existing or future dining facility in the RFP.] [For future expansion, a minimum grass area of [Insert Installation Required Square Footage] square feet located [Insert Location of Future Expansion] shall be provided. No new improvements shall be constructed within the area designated for future expansion.]

[3-7.1 **Site Design Criteria For UEPH Facilities.** In addition to the general site design criteria defined above, UEPH Facilities shall include the following: a grass multi-purpose area having a minimum of [Insert Installation Required Area], a grass playing field area having a minimum of [Insert Installation Required Area], [Insert required number and size of multipurpose courts] paved multipurpose courts, and a grass training area having a minimum of [Insert Installation Required Area]. [Insert additional installation requirements such as baseball diamonds and bleachers, etc.]

[3-7.2 **Site Design Criteria for Company Operations Facilities.** In addition to the general site design criteria defined above, Company Operations Facilities shall include the following: [Insert specific installation requirements with minimum required area].

[3-7.3 **Site Design Criteria for Battalion and Brigade Headquarter Facilities.** In addition to the general site design criteria defined above, Battalion and Brigade Headquarter Facilities shall include the following: a grass parade/viewing ground having a minimum of [Insert Installation Required Area]; [Insert specific installation requirements with minimum required area].

3-8 **CIRCULATION AND PARKING.** The vehicular and pedestrian circulation system shall promote safe, efficient movement of vehicles and pedestrians within the site area. Site design shall facilitate pedestrian traffic between facilities, and minimize the need for vehicular traffic within the complex. Vehicular traffic shall be routed around the outer perimeter of UEPH facility areas to the greatest extent possible. The vehicular and pedestrian circulation system should maintain the maximum separation of vehicles and pedestrians. Safe circulation systems have a clear hierarchy of movement, lead to a clear destination, and do not interrupt other functions. The following criteria shall be considered for designing streets and drives for vehicles and pedestrians:

3-8.1 **Vehicular Circulation.** Vehicular circulation layout is determined by applying the design vehicle templates to the site design. The passenger car class includes passenger cars and light delivery trucks, such as vans and pick-ups. The passenger car template is equivalent to the non-organizational - privately owned vehicle (POV). The truck class template includes single-unit trucks, recreation vehicles, buses, truck tractor-semitrailer combinations, and trucks or truck tractors with semi-trailers in combination with full trailers. Templates showing the turning movements for design vehicles are provided by the American Association of State Highway and Transportation Officials (AASHTO). Obtain templates and utilize them during the design of the facility. Provide the vehicle clearances that are required to meet traffic safety for emergency vehicles, service vehicles, and moving vans. Site entrances and site drive aisles shall include required traffic control signage. Maximize spacing between drives, incorporate right-angle turns, and limit the points of conflicts between traffic.

3-9 **DEFINITIONS.**

3-9.1 **Entrance and Intersection Design.** For site entrances and drive aisle intersections, provide "T" intersection offsets of at least 38.1 m [125 ft]. The preferred angle of intersection is right-angle (90 degrees).

3-9.2 **Drive Aisle Design.** The selected design vehicle templates determine dimensions for drive aisles for parking lots. Separation, corner clearances, and sight distance are established when the design vehicle templates and speed limits are selected. Design pavements for the wheel load associated with the design vehicle. Concrete entrances shall be provided at intersections with installation roads.

3-9.3 **Privately Owned Vehicle (POV) Parking.** POV stalls without vehicle overhang shall be a 2.7 m x 5.5 m [9 ft x 18 ft]. The design vehicle template that is used to design this space shall be described.

3-9.4 **Pedestrian Circulation.** Pedestrian circulation should be safe and separate from vehicle circulation. Provide good sidewalk layout to connect all building entrances with parking and

site facilities and existing walks. Pedestrian circulation should be based on pedestrian desired lines of walking between site facilities and existing walks. Desired lines should be weighted to predict the most traveled routes. These routes would require paving. Topography and vegetation can be used to reinforce a sense of movement. Design pedestrian concentration areas with adequate paved area.

3-10 **SIDEWALK DESIGN.** The network of walks throughout the complex shall be designed to facilitate pedestrian traffic among facilities, and minimize the need to use vehicles. Sidewalks shall be provided on both sides of the street. Walks shall be a minimum of 1.2 m [4 ft] wide exclusive of curb width, and made [non-reinforced][wire mesh reinforced] concrete with a minimum thickness of 100 mm [4 in]. Where walks are adjacent to the curb, the curb width is not to be included as sidewalk. Ramps for handicapped individuals shall be provided at intersections by depressing street curbs and adjacent sidewalk.

3-11 **LANDSCAPE PLANTING PLAN.** [Insert the requirements of the activity department in charge of landscaping criteria]. Landscaping shall be in accordance with [Insert activity criteria governing landscaping]. [A plant list of allowable plants has been attached for the contractor's use]. The offeror shall obtain and use the services of a qualified [State certified] landscape architect, experienced in site planning and planting design. A complete, integrated landscape-planting plan shall be provided for the overall project. The design shall reflect appropriate groupings, foundation plantings, and street tree plantings to define the open spaces to ensure a complete landscaped project. Choose plant materials on the basis of plant hardiness, climate, soil conditions, low maintenance, and quality. Selected plant materials shall be easily maintained and tolerant of the specific site conditions. Incorporate sustainable design principles into the selection of plants. Planting or seeding shall occur only during periods when beneficial results can be obtained.

3-11.1 **Trees, Shrubs, and Ground Cover.** Plant varieties shall be nursery grown or plantation grown stock. They shall be grown under climatic conditions similar to those in the locality of the project.

3-11.1.1 **Quality.** Well-shaped, well-grown, vigorous, healthy plants having healthy and well-branched root systems shall be provided. Plants shall be free from disease, harmful insects and insect eggs, sunscald injury, disfigurement, and abrasion. Plants shall be provided that are typical of the species or variety.

3-11.1.1.1 **Shade and Flowering Trees.** A height relationship to caliper shall be provided. Height of branching should bear a relationship to the size and variety of tree specified, and with the crown in good balance with the trunk. Trees shall not be "poled" or the leader removed.

3-11.1.1.1.1 **Single Stem.** Trunk shall be reasonably straight and symmetrical with crown and have a persistent main leader.

3-11.1.1.1.2 **Multi-Stem.** All countable stems, in aggregate, shall average the size specified. To be considered a stem, there should be no division of the trunk, which branches more than 150 mm [6 in] from the ground level.

3-11.1.1.1.3 **Specimen.** A plant shall be provided that is well branched and pruned naturally according to the species. The form of growth desired, which may not be in accordance with natural growth habit, shall be as indicated.

3-11.1.1.2 **Deciduous Shrub.** Plants shall be provided having the height and number of

primary stems as recommended by the agency having jurisdiction. An acceptable plant shall be well shaped with sufficient well-spaced side branches recognized by the trade as typical for the variety grown in the region.

3-11.1.1.3 **Coniferous Evergreen.** Provide the height-to-spread ratio as recommended by the agency having jurisdiction. Trees shall not be "poled" or the leader removed. An acceptable plant shall be exceptionally heavy, well shaped and trimmed to form a symmetrical and tightly knit plant. The form of growth desired shall be as indicated.

3-11.1.1.4 **Broadleaf Evergreen.** Provide the ratio of height-to-spread as recommended by the agency having jurisdiction. An acceptable plant shall be well shaped and recognized by the trade as typical for the variety grown in the region.

3-11.1.1.5 **Ground Cover.** Plants shall be provided with the minimum number of runners and length of runner as recommended by the agency having jurisdiction. Plants shall be furnished that have heavy, well developed, and balanced top with vigorous well developed root system, and shall be furnished in containers.

3-11.1.2 **Measurement.** Plant measurements shall be in accordance with the agency having jurisdiction.

3-11.1.3 **Percolation Test.** Test for percolation shall be done to determine positive drainage of plant pits and beds. All soil and drainage conditions detrimental to the growth of plant material shall be identified and a proposal correcting the conditions shall be submitted.

3-11.1.4 **Soil Test.** A soil test shall be performed for pH, chemical analysis, and mechanical analysis to establish the quantities and type of soil amendments required to meet local growing conditions for the type and variety of plant material specified.

3-11.1.5 **Installation.** Verify the location of underground utilities. When obstructions below ground or poor drainage affect the planting operation, proposed adjustments to plant location, type of plant, and planting method or drainage correction shall be submitted. The plant material shall be installed during appropriate planting times and conditions recommended by the trade for the type and variety of plant material specified. Plant pits shall be excavated and backfilled as recommended by the agency having jurisdiction. The planting operation shall be performed only during periods when beneficial results can be obtained. When special conditions warrant a variance to the planting operations, proposed planting times should be submitted.

3-11.1.6 **Pruning.** The total amount of foliage shall be pruned by one-fourth to one-third on installed trees and shrubs to compensate for loss of roots and transplanting shock. The typical growth habit of individual plants shall be retained. Trees shall not be poled or the leader removed, nor shall the leader be pruned or "topped off."

3-11.1.7 **Maintenance During Planting Operation.** Installed plants shall be maintained in a healthy growing condition. Maintenance operations shall begin immediately after each plant is installed and shall continue until the plant establishment period commences.

3-11.1.8 **Plant Establishment Period.** On completion of the last day of the planting operation, the plant establishment period for maintaining installed plants in a healthy growing condition shall commence and shall be in effect for the remaining contract time period not to exceed 12 months. When the planting operation extends over more than one season or there is a variance to the

planting times, the plant establishment periods shall be established for the work completed.

3-11.1.9 **Maintenance During Establishment Period.** The maintenance of plants shall include straightening plants, tightening stakes and guying material, repairing tree wrap, protecting plant areas from erosion, maintaining erosion material, supplementing mulch, accomplishing wound dressing, removing dead or broken tip growth by pruning, maintaining edging of beds, checking for girdling of plants and maintaining plant labels, watering, weeding, removing and replacing unhealthy plants.

3-11.1.10 **Unhealthy Plant.** A plant shall be considered unhealthy or dead when the main leader has died back, or 25 percent of the crown is dead. Determine the cause for an unhealthy plant. Unhealthy or dead plants shall be removed immediately and shall be replaced as soon as seasonal conditions permit in accordance with the following warranty paragraph.

3-11.1.11 **Warranty.** Furnished plant material shall be guaranteed to be in a vigorous growing condition for a period of 12 months regardless of the contract time period. A plant shall be replaced one time under this guarantee. Transplanting existing plants requires no guarantee.

3.11.2 **Turf.** Turf consists of seed, sod, and sprigs.

3.11.2.1 **Seed.** State approved seed of the latest season's crop shall be provided in the original sealed packages bearing the producer's guaranteed analysis for percentages of mixture, purity, germination, hard seed, weed seed content, and inert material. Labels shall be in conformance with applicable State seed laws. Seed mixtures shall be proportioned by weight. Weed seed shall not exceed one percent by weight of the total mixture.

3-11.2.2 **Sod.** State approved sod shall be provided as classified by applicable State laws. Each individual sod section shall be of a size to permit rolling and lifting without breaking. The sod shall be relatively free of thatch, diseases, nematodes, soil-borne insects, weeds or undesirable plants, stones larger than 50mm[2 in] in any dimension, woody plant roots, and other material detrimental to a healthy stand of turf. Sod that has become dry, moldy, or yellow from heating, or has irregular shaped pieces of sod and torn or uneven ends shall be rejected. Sod shall be machine cut to a uniform thickness of 32 mm[1-1/4 in] within a tolerance of 6 mm[1/4 inch] excluding top growth and thatch. Measurement for thickness shall exclude top growth and thatch. The limitation of time between harvesting and placing sod shall be 36 hours.

3-11.2.3 **Sprig Quality.** The cultivar shall be provided as healthy living stems, stolons, or rhizomes with attached roots, including two or three nodes, and shall be from 100 to 150 mm[4 to 6 in] long, without adhering soil. Sprigs shall be provided which have been grown under climatic conditions similar to those in the locality of the project. Sprigs shall be obtained from heavy and dense sod, free from weeds or other material detrimental to a healthy stand of turf. Sprigs that have been exposed to heat or excessive drying shall be rejected. The time limitation between harvesting and placing sprigs shall be 24 hours.

3-11.2.4 **Soil Test.** A soil test shall be performed for pH, chemical analysis, and mechanical analysis to establish the quantities and type of soil amendments required to meet local growing conditions for the type and variety of turf specified.

3-11.2.5 **Temporary Turf Cover.** When there are contract delays in the turfing operation or a quick cover is required to prevent erosion, the areas designated for turf shall be seeded with a temporary seed. When no other turfing materials have been applied, the quantity of one-half of the

required soil amendments shall be applied and the area tilled.

3-11.2.6 **Final Turf.** The turf shall be installed during appropriate planting times and conditions recommended by the trade for the type and variety of turf specified. The turf operations shall be performed only during periods when beneficial results can be obtained. Drainage patterns shall be maintained. The turf shall be installed by using the methods as recommended by the trade for the type and variety of turf specified. Immediately after turfing, the area shall be protected against traffic or other use by erecting barricades and providing signage as required. The turf establishment period for establishing a healthy stand of turf shall begin on the first day of work under the turfing contract and shall end three months after the last day of the turfing operation. An unsatisfactory stand of turf shall be repaired as soon as turfing conditions permit.

3-11.2.7 **Satisfactory Stand of Turf.**

3-11.2.7.1 **Seeded Lawn Area.** A satisfactory stand of turf from the seeding operation for a lawn area is defined as a minimum of 160 grass plants per square meter [15 grass plants per square foot]. Bare spots shall be no larger than 150 mm [6 in] square. The total bare spots shall not exceed two (2) percent of the total seeded area.

3-11.2.7.2 **Seeded Field Area.** A satisfactory stand of turf from the seeding operation for a field area is defined as a minimum of 100 grass plants per square meter [10 grass plants per square foot]. The total bare spots shall not exceed two (2) percent of the total seeded area.

3-11.2.7.3 **Sodded Area.** A satisfactory stand of turf from the sodding operation is defined as living sod uniform in color and texture. Bare spots shall be no larger than 50 mm[2 in] square.

3-11.2.7.4 **Sprigged Area.** A satisfactory stand of turf from the sprigging operation is defined as a minimum of 20 sprigs per square meter [2 sprigs per square foot]. Bare spots shall be no larger than 225 mm [9 in] square. The total bare spots shall not exceed two (2) percent of the total sprigged area.

3-11.2.8 **Maintenance During Establishment Period.** The maintenance of the turfed areas shall include eradicating weeds, eradicating insects and diseases, protecting embankments and ditches from erosion, maintaining erosion control materials and mulch, protecting turf areas from traffic, mowing, watering, post-fertilization, and replacing unsatisfactory turf areas.

3-12 **SPRINKLER AND/OR IRRIGATION SYSTEM.** [Insert installation standards for sprinkler and irrigation systems.] [Provide a complete permanent automatic irrigation system with controllers covering all common planting areas and slopes. Design the system to function with available water pressure. Investigate and employ methods of irrigation based on sustainable design principles, where practical and feasible.] [In areas where sprinkler and/or irrigation systems are not required, delete the paragraph text and insert, "Not required"]

**CHAPTER 4**

**SITE ENGINEERING**

**4-1 SOILS.**

**4-1.1 1\1 Geotechnical Report.** A Geotechnical Report is provided as part of this RFP. The report provides and overview of subsurface conditions, general recommendations for design, and is furnished for informational purposes. The offeror to whom this contract is awarded, shall perform a geotechnical investigation specific to the proposed project. The contractor shall submit a project specific geotechnical report, certified by a professional engineer experienced in geotechnical engineering, to include, but not limited to: description and classification of geologic, soil, [rock,] and groundwater conditions; subsurface profiles, boring logs and location plans; summary of laboratory and field test results; [local seismic conditions]; [local soil, rock, and groundwater problems]; [extent of boulders;] soil resistivity, moisture, and chemistry for cathodic protection; infiltration and permeability conditions; surface and subsurface drainage conditions; [description of existing foundation systems]; bearing capacity of soil [and rock]; settlement type and potential; recommendations for type and depth of foundation systems, pavement sections, slab on grade sections; [recommendations for foundation drainage systems;] general earthwork, compaction, dewatering, erosion and sediment control, excavation and safety requirements; [recommendations for field tests]; [recommendations for underpinning]; [insert any site specific requirements]. /1/

**4-1.1.1 1\1 Certification.** The offeror and his or her professional geotechnical engineer consultant shall certify in writing that the design of the project has been developed consistent with the site specific geotechnical conditions. The certification shall be stamped by the consulting professional geotechnical engineer and shall be submitted with the First Site/Utility Design Submittal (100%) . If revisions are made to the design submission, a new certification shall be provided with the next design submission. /1/

**4-1.1.2 1\1 Changed Conditons.** As noted in paragrah 4-1.1.1, the geotechnical report in the RFP is for informational purposes and the offeror awarded the contract is responsible for conducting his or her own project specific geotechnical investigation and report. If the contractor encounters conditions different than provided in the RFP, the contractor shall notify the Government with the submission of the contractor project specific geotechnical report [differences that can impact cost such as rock or groundwater elevations; discovery of soil, rock, and groundwater problems; discovery of contamination; changes required for foundations or pavements; changes in earthwork requirements; etc.]. The Government shall evaluate the notification to determine if a Changed Condition exists prior to the approval to initiate construction. /1/

**4-1.2 Soil Compaction.** Soil compaction shall be achieved by equipment approved by a professional geotechnical engineer. Material shall be moistened or aerated as necessary to provide the moisture content that will readily facilitate obtaining the compaction specified with the equipment used. Compact each layer to not less than the percentage of maximum density specified in Table 4-1, determined in accordance with ASTM D 1557, Method D.

**TABLE 4-1 Soil Compaction**

Subgrade Preparation, Fills, Embankments, and Backfills	Compaction Requirements (Percentage of Maximum Density)
Structures & Building Slabs	90

**TABLE 4-1 Soil Compaction**

Subgrade Preparation, Fills, Embankments, and Backfills	Compaction Requirements (Percentage of Maximum Density)
Streets, Paved Areas, Bike Paths	90
Sidewalks	85
Grassed Areas	80

The requirements shall be verified or modifications recommended by the consulting professional geotechnical engineer in the report wherever engineering, soils, or climatic factors indicate the necessity. Any modification to the stated compaction requirements shall require the approval of the Contracting Officer.

4-1.3 **Capillary Water Barrier.** A capillary water barrier is required for all interior slabs on grade, including garages, carports and storage rooms. As a minimum, the capillary water barrier shall [Define minimum requirements.]

4-1.4 **Soil Treatment.** [If not required insert "... (DELETED)." and delete remainder of text.] Soil treatment for termites shall be by the chemical method. Methods and extent of protection required are as follows: [Insert project specific requirements.]

4-1.5 **Decay Treatment.** Decay treatment shall apply to the following: [Insert project specific requirements.]

4-1.6 **Radon Mitigation.** The design and construction of foundation walls, slabs, and crawl spaces shall include provisions for the reduction of radon entry and facilitate its removal. Radon mitigation shall comply with the requirements of ASTM E1465. [If not required, insert "... Deleted." and delete remainder of text. Design District technical specialists can contact Mr. David Price of EPA's Indoor Environments Division, 202-564-9447 regarding suggested language concerning indoor air quality and radon mitigation].

4-2 **EROSION AND SEDIMENT CONTROL.** Erosion and Sediment Control Facilities shall be required in accordance with [Insert state or local agency having jurisdiction and reference any applicable manual(s)], as specified in the manual entitled [insert criteria manual title].

4-3 **DEMOLITION.** Existing facilities scheduled for demolition includes [insert description or reference attached sketches]. [The following demolished materials shall [become][remain] the property of the [Contractor][Government: include installation list of recycled materials], unless otherwise indicated or specified.] Materials not owned by the Government and not used in construction shall be disposed of [off][on] government property. Obtain required demolition permits [and disposal permits] from [Insert appropriate agency having jurisdiction and reference any applicable manual(s)]. Obtain approval of the disposal site from the contracting officer[ and submit haul tickets for material disposed of off of Government property].

4-4 **CLEARING AND GRUBBING.** Clear and grub all trees and vegetation necessary for construction; but, save as many trees as possible. [All timber removed from the project site shall [become][remain] the property of the [Contractor] [Government], unless otherwise indicated or

specified.] [For all timber the Government desires to have ownership of, insert installation requirements for minimum size, delimiting, delivering, stacking, stump removal, and any requirements associated with chipping wastes (mulch).] [The contractor shall reimburse the Government for the value of the timber. The contractor shall submit payment to the Contracting Officer by cashier's or certified check in the amount of [\_\_\_], made payable to the U.S. Treasury. Payment shall be made within thirty (30) days of the Notice To Proceed. The contracting Officer will forward the check to [Insert appropriate office.]

[4-5 **WETLANDS.** Jurisdictional [tidal][ and ][non-tidal] wetlands [have][have not] been identified on the project site. [The following mitigation shall be incorporated into the design: [\_\_\_].] [Determination has been made that jurisdictional wetlands are not on the site.]]

4-6 **EARTHWORK.** The contractor is responsible for obtaining subsurface soil information for design purposes.

4-7 **BORROW MATERIAL.** Obtain borrow material required for construction from sources [off][on] government property. [Insert specific criteria regarding Government owned borrow sources, borrow site testing and acceptance, and other related information.]

4-8 **WATER DISTRIBUTION SYSTEM.** The design of the water distribution system shall be in accordance with the [Insert agency having jurisdiction.] Where the requirements of the agency having jurisdiction and the requirements defined herein disagree, the more stringent shall apply. The contractor shall determine the domestic and the fire demands for the facilities and shall verify the design of all components of the domestic and fire protection supply systems. Design of a water distribution system requires both domestic and fire flow demands be considered concurrently.

4-8.1 **Analysis of Existing System Capacity.** [The contractor shall obtain all necessary static pressure, residual pressure, and flow characteristics of the existing distribution system by actual field tests.] [The installation shall insert existing fire hydrant flow test results when available.][The contractor shall provide design calculations that show the existing system is capable of handling the additional flows.][The installation shall state that the existing system is capable of handling the additional flows.]

4-8.2 **Connections to Water Mains and Building Service Lines.** [Insert installation specific connection location requirements.] [The contractor shall be responsible for the design of the sizes, locations, and means of connections to the existing system based on Facility requirements and system conditions. Establish the location for the connection based upon economics and site design parameters.]

4-8.2.1 **Connections to Water Mains.** Design the connections to the station water system including the meter assemblies and the necessary backflow-preventing devices. Fire protection system shall be considered as that part of the distribution system supplying fire hydrants, or fire hydrant laterals. Service connections supply water from the main to the building. Mains shall be looped with no dead ends and be of adequate size to satisfy both domestic and fire flow requirements. Minimum main size is 150 mm [6 in]. Sufficient sectional control valves shall be provided so that no more than two fire hydrants will be out of service in the event of a single break in a water main. A copper tracer wire shall be placed directly above all non-metallic mains when plastic marking tape does not provide means of determining alignment of pipe by metal detecting equipment. The pipe, valves, and all other materials shall meet the requirements of the [agency having authority] or [Insert the installation standards] for a 1034 kPa [150 psi] working pressure

system. [Provide sacrificial anodes for all valves and metal pipe.]

4-8.2.2 **Building Connections.** Design and construction shall be in accordance with the International Building Code [2000 or latest edition].

4-8.3 **Trenches.** Water and gas mains [may] [may not] be installed in the same trench. [Determine if the local gas utility supplier will allow installation in the same trench and incorporate the standards of the gas utility supplier.] Water mains shall have a minimum earth cover of 750 mm [30 in] [as specified by the agency having jurisdiction] or [Insert the installation minimum cover]. Adequate cover must be provided for freeze protection. Where frost penetrates to a depth greater than the minimum above, greater cover will be required. Sufficient cover must also be provided to protect the pipe against structural damage due to superimposed surface loads. Lines installed with less cover than the minimums stated shall be concrete encased with a minimum concrete thickness of 150 mm [6 in].

4-8.4 **Fire hydrants.** Hydrants and valves shall conform to [the requirements of the agency having jurisdiction] or [Insert the installation's base hydrant standard]. Fire hydrants shall be compatible with those presently in use at the installation [or by local Governments], with similar pump and hose connections. The maximum amount of flow that can be permitted shall be determined. Fire hydrant spacing shall be no greater than 150 m [500 ft] apart by paved road. In addition, a hydrant shall be provided so that all parts of the facilities can be reached by hose lines not over 105 m [350 ft] long. All distances shall be calculated along the closest route that the fire apparatus must travel (i.e.; along the curb or access lane). Each hydrant may account for a maximum of 95 liters per second [1500 gpm] of fire protection regardless of existing pressures or water line capacity. A fire hydrant shall be located within 15m [50 ft] from any fire department connection provided. Hydrant laterals shall be 150 mm [6 in] minimum size, and shall not exceed 15 m [50 ft] in length, and shall have an underground shutoff valve. Valve box, at each lateral, shall be located within 3 m [10 ft] of the hydrant, and shall not be located where obstructed by parked vehicles, shrubbery, etc. Guard post barriers shall be provided where hydrant locations are subject to vehicle damage.

4-8.5 **Shutoff Valve.** Each building shall be provided with a separate service and main shutoff valve, readily accessible to maintenance and emergency personnel. Shutoff valves in walks are prohibited.

4-8.6 **Metering.** [Insert the installation metering requirements] [Meters shall be equipped with electronic or radio frequency transmitters for remote monitoring. The method of remote monitoring must be coordinated with installation utility systems.]

4-8.7 **Materials.** Materials for the water distribution system shall be in accordance with the [agency having jurisdiction] [Insert installation standards]. Copper water service lines will be dielectrically isolated from ferrous pipe. Dielectric isolation shall conform to the requirements of [insert the agency having jurisdiction]. For ductile iron piping systems (except for ductile iron piping under floor in soil) conduct an analysis to determine if cathodic protection and/or bonded or unbonded coatings are required. Unbonded coatings shall conform to the requirements of the agency having jurisdiction.

4-8.8 **Economic Analysis.** Conduct an economic analysis to determine if cathodic protection and protective coatings should be provided for the following structures in soil resistivity conditions above 10,000 Ohm-cm: ferrous metallic potable water lines; Concentric neutral cable; Other buried

and submerged ferrous metallic structures not covered above; Ferrous metallic piping passing through concrete shall not be in contact with the concrete.

4-8.9 **Field Quality Control for Water Distribution.** The [contracting officer] [Insert the appropriate person] will conduct field inspections and witness field tests specified. The contractor shall perform field tests, and provide labor, equipment, and incidentals required for testing, [except that water needed for field tests will be furnished as set forth in [Insert appropriate document]]. [Water needed for field tests will not be furnished by the government]. Do not begin testing on any section of a pipeline where concrete thrust blocks have been provided until at least 5 days after placing of the concrete. Testing procedures and requirements shall comply with the [requirements of the agency having jurisdiction.] [Insert the installation testing standards].

4-9 **SANITARY SEWERAGE SYSTEM.** The design of the sanitary sewer distribution system shall be in accordance with the [Insert State or local agency having jurisdiction.] Where the requirements of the agency having jurisdiction and the requirements defined herein disagree, the more stringent shall apply. The contractor shall determine the sewerage contribution for the facilities and shall verify the design of all components of the sanitary sewer system.

4-9.1 **Analysis of Existing System Capacity.** [The contractor shall provide design calculations that show the existing system is capable of handling the additional flows.] [The Installation shall state that the existing system is capable of handling the additional flows.]

4-9.2 **Calculate Sewage Contribution.** Calculate the sewage contribution from the new facilities in accordance with the [Insert State or local agency having jurisdiction.] [Insert installation standards for sewage contribution].

4-9.3 **Connections to Sewage Collection Mains and Building Service Lines.** [The installation shall insert specific connection location requirements.] [The contractor shall be responsible for the design of the sizes, locations, and means of connections to the existing system based on Facility requirements and system conditions. Establish the location for the connection based upon economics and site design parameters.] Connect to gravity mains with a manhole.

4-9.3.1 **Building Sewer Laterals and Connections.** Laterals and building connections shall be designed and constructed in accordance with the International Building Code [2000 or latest edition]. Minimum diameter for laterals shall be 150 mm [6 in] while maintaining a minimum velocity of 45 meters per minute [2.5 fps].

4-9.3.2 **Main Collection Trunks.** Pipe sizes and slopes shall be calculated using the Manning Formula. Manholes are required at all changes of direction and spaced not more than 122 m [400 ft] apart [or as required by installation]. Curved sewers are prohibited. Pipes shall be designed to flow full and maintain a minimum velocity of 45 meters per minute [2.5 fps]. If siphons are used, two lines of equivalent capacity shall be used with clean-outs.

4-9.4 **Trenches.** Sewer and water lines, mains or laterals, shall be placed in separate trenches. The separate trenches shall maintain a minimum lateral separation of 3m [10 ft].

4-9.5 **Minimum Sewer and Water Distribution Pipe Separation Requirements.** Parallel water and sewer pipe and crossings between water and sewer pipe shall be in accordance with the

[state or local agency having jurisdiction] [Insert the installation standards].

4-9.6 **Cover.** Sewer lines shall be located at a depth greater than the frost penetration. Coordinate with building connection requirements. To prevent the pipe from being crushed by construction vehicles and the design vehicle, the minimum cover above the top of pipes shall be 750mm [30 in] unless pipe materials are used and/or unless the pipe is concrete encased with a minimum of 150 mm [6 in] thickness of concrete.

4-9.7 **Sewage Pump Station and Force Main.** Pump stations and force mains shall only be used when absolutely necessary. If required, pump stations and force mains shall be designed in accordance with the [agency having jurisdiction] [base standards]. [An on-site sewage lift station and force main shall not be required.] [An on-site sewage lift station and force main shall be required.] [The contractor shall determine if an on-site sewage lift station and force main is required and use only when required by the design or the existing system conditions.]

4-9.8 **Field Quality Control for Sanitary Sewer Distribution System.** The [contracting officer] [Insert the appropriate person] will conduct field inspections and witness field test specified. The contractor shall perform field tests, and provide labor, equipment, and incidentals required for testing, [except that water needed for field tests will be furnished as set forth in [Insert appropriate document]]. [Water needed for field tests will not be furnished by the government]. For force mains, do not begin testing on any section of a pipeline where concrete thrust blocks have been provided until at least 5 days after placing of the concrete. Testing procedures and requirements shall comply with the [requirements of the agency having jurisdiction.][Insert the installation testing standards].

4-10 **STORMWATER MANAGEMENT SYSTEMS.** [Insert the agency having jurisdiction for storm water management and drainage system design.] The storm drainage system shall be properly coordinated with surrounding properties to ensure that runoff does not cause damage to other properties. All storm water management calculations shall be based upon a 10-year storm frequency. Design storm water management systems in accordance with the applicable requirements of "Controlling Urban Runoff: A Practical Manual for Planning and Designing Urban BMPS", by the Department of Environmental Programs or in accordance with the requirements of the agency having jurisdiction. The calculation of runoff and the evaluation of existing storm sewer drainage systems shall be as described herein paragraph entitled "Storm Drainage Collection Systems and Grading". Obtain required permits from the agency having jurisdiction prior to construction.

4-10.1 **Analysis of Existing System Capacity.** [The contractor shall provide design calculations that show the existing system is capable of handling the increased runoff from the improved site.] [The Installation shall state that the existing system is capable of handling the increased runoff from the improved site.]

4-10.2 **Storm Water Retention/Detention System for Volume Control.** [For volume control, an on-site storm water retention/detention system shall not be required.] [For volume control, an on-site storm water retention/detention system shall be required.] [For volume control, the contractor shall determine if an on-site storm water retention/detention system is required, based on the capacity of the receiving system and the installation requirements.]

4-10.3 **Storm Water Retention/Detention System for Runoff Treatment.** [For runoff treatment, an on-site storm water retention/detention system shall not be required.] [For runoff treatment, an on-site storm water retention/detention system shall be required.] [For runoff

treatment, the contractor shall determine if an on-site storm water retention/detention is required, based on the requirements of the [insert appropriate agency].]

#### 4-11 **STORM DRAINAGE COLLECTION SYSTEMS AND GRADING.**

4-11.1 **Location of Connections to Existing Systems.** [Insert installation specific connection location requirements.] [The contractor shall select the connection location. Establish the location for the connection based upon economics, design requirements, and downstream capacity.] Connect with a manhole or appropriate drainage structure.

4-11.2 **Building Connections.** Connection to building roof or area drain lines shall be designed and constructed in accordance with the International Building Code [2000 or latest edition].

4-11.3 **Storm Sewer System.** The storm sewer gravity drainage collection system shall be designed and constructed in accordance with the requirements of [Insert the state or local agency having jurisdiction] [Insert the appropriate State Department of Transportation Drainage Manual] [Insert the appropriate State Department of Transportation Road and Bridge Specifications]. Storm sewer system shall be designed for a minimum of a 10-year return frequency and pipes shall be sized for full flow. The minimum velocity of flow in conduits during a design storm shall be 45 meters per minute [2.5 fps]. The pipe capacity shall be determined so that the calculated hydraulic grade line of the storm sewer drainage system(s) shall not exceed the curb flow line grade in pavements and the finished site grades.

4-11.4 **Manholes.** Manholes shall be located at intersections and changes in alignment or grade. Intermediate manhole maximum spacing shall be 75 m [250 ft] for pipes 900mm [3 ft] or less in diameter or box drains with the smallest dimension less than 900 mm [3 ft]. Maximum spacing for intermediate manholes on larger pipes and drain boxes shall be 150 m [500 ft]. Manholes and manhole appurtenances shall be [pre-cast concrete] [insert other acceptable materials] and shall conform to the [agency having jurisdiction] [Insert base standard]. Shape manhole inverts to the shape of the pipe with cast in place concrete after installing pipes. The manhole lid shall have a 600mm [2 ft]. minimum opening as measured from the face of the wall or ladder where applicable.

4-11.5 **Drainage of Grass Areas.** Except at personnel and overhead doors, the difference in grade between the finish floor elevation and the surface of the ground immediately adjacent to the building shall be a minimum of 150 mm [6 in]. Minimum slopes across grass surfaces shall be one percent. In grass areas, overland sheet flow shall be held to a maximum length of 30 m [100 feet]; then, a swale or an inlet must be used. Minimum slopes in swale centerlines shall be 0.5 percent. Maximum swale side slopes shall be 1V: 4H and maximum swale depth shall be 600 mm [24 in]. Ditches shall not be permitted. Storm drain pipe, sheet flow surfaces, and swales shall be designed to prevent standing water under normal conditions.

4-11.6 **Drainage of Roads and Pavements.** Provide a positive crown in all streets and roads. Minimum cross slopes in streets and roads shall 1:48 [1/4":1'] and the maximum cross slope shall be 1:32 [3/8":1"]. Minimum sheet flow slopes across parking area and other paved areas shall be 1 percent. Curbs and gutters shall be installed at a minimum longitudinal slope of 0.30 percent. Pavement collectors for storm water shall be by curb inlets and gutters, or drop inlets. Field inlets and an underground collection system shall drain open areas. Ditches shall not be permitted. Gutter spread (or inlet approach spread) in roads shall not exceed 3 m [10 ft] when measured from the

face of curb. The amount of runoff to any one inlet in roads and parking areas shall not exceed the capacity of that inlet. The maximum spread allowable for determining inlet capacity shall equal that allowed for gutter spread in roads. The maximum spread allowable for determining inlet capacity in parking areas shall be height of curb or a depth of 150 mm [6 in], whichever is less.

4-11.7 **Materials.** All materials shall be in accordance with [insert the agency having jurisdiction or installation criteria]. [Select the allowable pipe materials based upon local conditions and facility criteria.] Pipe for culverts and storm drains may be of [[reinforced] concrete], [ductile iron,] [cast iron soil pipe,] [corrugated steel,] [corrugated aluminum alloy,] [ABS,] [PVC,] [insert other material here] or [HDPE].

4-11.8 **Field Quality Control for Storm Drainage System.** The [contracting officer] [Insert the appropriate person] will conduct field inspections. Testing procedures and requirements shall comply with the [requirements of the agency having jurisdiction.] [Insert the installation testing standards].

4-12 **PAVEMENT DESIGN CRITERIA.** Pavement design shall be in accordance with the [Insert state or local agency/ having jurisdiction] [Insert the state department of transportation road and bridge specification manual if desired or insert the installation standard]. Concrete curb [and curb/gutter] [shall] [shall not] be required at the perimeter of all streets, roads, parking areas, and interior islands. For streets and roads, the design vehicle for this facility is [Insert the design vehicle]; the anticipated axle load for design is [Insert the estimated axle load for the design vehicle]; and the estimated volume of traffic is [Insert the estimated volume of traffic per day]. For bid purposes, assume that the existing subgrade soils after compaction will have a California Bearing Ratio (CBR) of [4] [Insert installation assumed CBR value based upon experience]. For parking areas, the design vehicle for this facility is [Insert the design vehicle], the anticipated axle load for design is [Insert the estimated axle load for the design vehicle], and the estimated volume of traffic (including current traffic loading and traffic loading as a result of this project) is [Insert the estimated volume of traffic per day]. For bid purposes, assume a California Bearing Ratio (CBR) of [4] [Insert assumed CBR value.] Designs for streets, walks, roads, and parking areas shall include adequate space for trees. Include landscape islands at the ends of rows of parking.

4-13 **PERMIT REQUIREMENTS.** [Timely acquisition of all the necessary design related permits shall be the responsibility of the Government; including the erosion and control permit, storm water management permit, discharge permit, [air permit] and the health department permit(s). Operating permits and licenses shall be the responsibility of the Contractor, in accordance with Section 00721, "Contract Clauses".] [Timely acquisition of all the necessary design and construction related permits shall be the responsibility of the contractor. As some permit process times take 6 months or more, the Contractor, upon notice to proceed, shall immediately begin working on the permits so as not to delay completion of the project. The following permits have been identified as being required for this project: [Health Department Permits for Sanitary Sewer and Water], [Storm Water Management], [Erosion and Sediment Control], [National Pollution Discharge Elimination Service], [Wetland permits for mitigation, preservation and/or creation], [Insert any other design permits], [Excavation Permit], [Demolition Permit], [Disposal Permit] and [Insert any other permits required by the installation].

4-14 **GAS DISTRIBUTION SYSTEM.** [Insert " ... (DELETED)" if not applicable and delete remainder of text in sub-paragraphs.] [Coordinate with the installation to determine the responsible agency for installation of exterior gas lines, meters, regulators, hot taps, valves, etc. The design agent shall then add a sentence to this paragraph to inform the contractor of his or

her responsibility.] Provide a gas distribution system, connected to existing systems and designed in accordance with local codes, utility company requirements, or installation regulations, whichever is more stringent. Gas distribution systems shall comply with the requirements of ASME B31.8. Connection to existing gas distribution system shall be made at the location shown on the enclosed RFP drawings. When connecting to existing steel piping system, provision shall be made to ensure that the integrity of the cathodic protection is not compromised. Shutoff valves shall be provided on the exterior of each building. A gas regulator and provision for future installation of an individual gas meter to monitor fuel use shall be provided for each building structure. The building service entrance shall be installed at a height sufficient to allow for future installation of the gas meter. Existing lines that are to be abandoned shall be either removed or physically disconnected from all gas sources and purged.

Abandoning existing gas piping shall be done in accordance with ANSI B31.8, Gas Transmission and Distribution Piping Systems. Installation of gas piping will be in accordance with ANSI B31.8 and 49 CFR 192.

4-14.1 Materials. Materials and appurtenances shall be free of defects and suitable to accomplish the stated objectives of gas distribution systems. Pipe shall be polyethylene or steel as described below.

4-14.1.1 Polyethylene pipe. Shall conform to ASTM D2513, Standard Specification for Thermoplastic Gas Pressure Piping Systems, with fittings complying with either ASTM D2513 or ASTM D2683, Standard Specification for Socket-Type Polyethylene Fittings for Outside Diameter-Controlled Polyethylene Pipe and Tubing. Connections to metal pipe shall comply with ANSI B16.5, Pipe Flanges and Flanged Fittings, or manufacturer's recommended standards.

4-14.1.2 Steel pipe. Shall conform to ASTM A 53, Grade A or B, Type E or S, Schedule 40. Furnace butt welded pipe may be used in sizes 40 mm [1-1/2 inch] and smaller. Fittings 40 mm [1-1/2 inch] and smaller shall conform to ASME B16.11. Pipe flanges and flanged fittings larger than 40 mm [1-1/2 inch], including bolts, nuts, and bolt patterns shall be in accordance with ASME B16.5, Class 150. Butt weld fittings shall be in accordance with ASME B16.9. Weld neck flanges shall be used.

4-14.2 Testing. Prove that the entire system of gas mains and service lines is gas-tight by an air test, in accordance with ANSI B31.8. The test shall continue for at least 24 hours between initial and final readings of pressure and temperature.

4-14.3 Drips. Unless high pressure natural gas is used, drips shall be installed at the low points, immediately following reduction from high pressure to medium pressure (at supply points) and at occasional low points throughout the system to provide for blowing out the lines.

4-14.4 Valves. Plug valves shall be installed at intersections of mains and other locations so that interruptions to service can be confined to no more than one building.

4-14.5 Mains and service lines. Lines shall not be placed under any buildings. Lines shall be placed with a minimum of 0.6 m [2 ft] of earth cover. Protective casings shall be provided to protect lines from superimposed street or heavy traffic loads.

4-15 **HEATING HOT WATER [AND CHILLED WATER] DISTRIBUTION.** [Insert "DELETED" if not applicable and delete remainder of text in all paragraphs.] Prefabricated piping system shall be installed to supply and return heating hot [and chilled] water to mechanical equipment rooms. Metallic pressure pipe, fittings, and piping accessories shall conform to the requirements of ASME B31.1 and shall be types suitable for the temperature and pressure of the water.

4-15.1 Piping materials.

4-15.1.1 Steel pipe. Piping shall conform to ASTM A 53, Grade B, standard weight, black or to ASTM A 106, Grade B, standard weight.

4-15.1.2 Copper tubing. Copper tubing shall conform to ASTM B 88, Type K or L.

4-15.1.3 Reinforced Thermosetting Resin Pipe (RTRP). RTRP pipe shall conform to ASTM D 5686.

4-15.1.4 Polyvinyl Chloride (PVC) Pipe. PVC pipe shall conform to ASTM D 2241 with a Standard Thermoplastic Pipe Dimension Ratio (SDR) of 26 and PVC 1120 or 1220 as the material.

4-15.2 Casing materials.

4-15.2.1 Polyvinyl Chloride (PVC) Casing. PVC casings shall conform to ASTM D 1784, Class 12454-B with a minimum thickness equal to the greater of 1/100 the diameter of the casing or 1.50 mm. 60 mils.

4-15.2.2 Polyethylene (PE) Casing. Polyethylene casings shall conform to ASTM D 1248, Type III, Class C, Category 3 or 4, Grade P 34 with thickness as follows:

Casing Diameter (in mm)	Minimum Thickness (in mm)
250 and smaller	3
250 to 450	4
450 to 600	5
over 600	6

Casing Diameter (in inches)	Minimum Thickness (in mils)
10 and smaller	125
10 to 18	150
18 through 24	200
over 24	225

4-15.2.3 Reinforced Thermosetting Resin Pipe (RTRP) Casing. RTRP casing shall be of the same material as the pipe, with casing thickness as follows:

Casing Diameter (in mm)	Minimum Thickness (in mm)
200 and smaller	1.2
250	2.0
300	2.7
350	2.9
400 to 450	3.0
500	3.2
600	3.9

Casing Diameter (in inches)	Minimum Thickness (in mils)
--------------------------------	--------------------------------

8 and smaller	70
10	80
12	105
14	115
16 to 18	120
20	125
24	155

4-15.3 End seals. Each preinsulated section of piping shall have a complete sealing of the insulation to provide a permanent water and vapor seal at each end of the preinsulated section of piping. Preinsulated sections of piping modified in the field shall be provided with an end seal which is equivalent to the end seals furnished with the preinsulated section of piping. End seals must be tested and certified in accordance with manufacturer's recommendations.

4-15.4 Insulation.

4-15.4.1 Factory applied insulation. Prefabricated pipe and fittings shall be insulated in the factory. Foam insulation for prefabricated insulated pipe and fittings shall be polyurethane foam meeting the requirements of ASTM C 591 having a density not less than 32 kg per cubic meter (2 pounds per cubic foot). The polyurethane foam shall completely fill the annular space between the carrier pipe and the casing. Insulation thickness shall be a minimum of [20] [ ] mm ([0.9] [ ] inches). The insulation thermal conductivity factor shall not exceed the numerical value of 0.02 W/mK at 24 degrees C (0.15 Btu-inch/square foot-degree F-hour at 75 degrees F), when tested in accordance with ASTM C 518. Manufacturer shall certify that the insulated pipe is free of insulation voids.

4-15.4.2 Field applied insulation. Field applied insulation for fittings, and field casing closures, if required, and other piping system accessories shall be polyurethane matching the pipe insulation. Thickness shall match adjacent piping insulation thickness. Buried fittings and accessories shall have field applied polyurethane insulation to match adjacent piping and shall be protected with a covering matching the pipe casing. Shrink sleeves with a minimum thickness of 1.3 mm 50 mils shall be provided over casing connection joints.

4-15.5 Thrust blocks. Thrust blocks shall be installed at the locations shown or recommended by the pipe system manufacturer. No pipe joint shall be embedded in concrete unless the assembly has previously been hydrostatically tested. The thrust blocks shall provide for transfer of thrusts and reactions without exceeding the allowable stress of the concrete and shall be installed in accordance with pipe manufacturer's instructions. In muck or peat, all thrusts shall be resisted by piles or tie rods to solid foundations or by removal of peat or muck which shall be replaced with ballast of sufficient stability to resist thrusts.

4-15.6 Expansion loops. Expansion loops and expansion bends (Z- and L- type) shall be factory fabricated of casing, insulation, and carrier piping identical to that furnished for straight runs. Expansion loops and bends shall be properly designed in accordance with the allowable stress limits indicated in ASME B31.1 for the type of pipe used. Expansion loops and bends shall be shipped to the jobsite in the maximum size sections feasible to minimize the number of field joints. The expansion loops and bends casing and insulation where applicable, shall be suitably sized to accommodate pipe movement. Field joints shall be made in straight runs of the expansion loops and bends, and the number shall be kept to a minimum.

4-15.7 Manholes and anchors. Manholes shall be designed and installed as recommended by the system manufacturer. Anchor design shall be in accordance with the published data of the manufacturer and for prefabricated systems shall be factory fabricated by the prefabricated system manufacturer. In all cases, the design shall be such that water penetration,

condensation, or vapor transmission will not wet the insulation.

4-15.8 Installation. The piping system furnished shall be installed in accordance with the piping system manufacturer's instructions. The Contractor shall obtain the services of a trained representative of the pipe system manufacturer to instruct the Contractor's work forces in the installation procedures to ensure that the system is installed in accordance with the manufacturer's published instructions and the plans and specifications. The manufacturer's representative shall be a person who regularly performs such duties for the manufacturer.

4-15.9 Testing. The carrier piping shall be hydrostatically tested at 1 ½ times the working pressure for the system. The casing shall be tested in accordance with the manufacturer's recommendations.

4-16 **STEAM [AND CONDENSATE RETURN] [HIGH TEMPERATURE HOT WATER] DISTRIBUTION.** [Insert "DELETED" if not applicable and delete remainder of text in all paragraphs.] Distribution system shall be installed to supply steam to [and return condensate from] mechanical equipment rooms. A complete underground [heat distribution] [and] [condensate return] system including all required components such as carrier pipes, [steam pipe,] [high temperature hot water supply pipe,] [condensate return pipe,] [high temperature hot water return pipe,] and fittings, anchors, pipe supports, insulation, protective casing, and cathodic protection, for the system supplied. Gland type end seals will not be permitted. Drainable-Dryable-Testable (DDT) systems with fiberglass casings shall not be permitted.

4-16.1 Piping materials.

4-16.1.1 Steam and High Temperature Hot Water Pipe. Pipe material shall be steel; seamless ASTM A 53, Grade B or ASTM A 106, Grade B; or electric resistance welded ASTM A 53, Grade B; Schedule 40. Standard weight will be permitted for pipe sizes 300 mm 12 inches and above. ASTM A 53, Type F furnace butt welded pipe will not be allowed. Joints will not be allowed in the factory fabricated straight section of the carrier pipe. Factory fabricated piping sections, as part of an expansion loop or bend, shall have all welded joints 100% radiographically inspected in accordance with ASME B31.1.

4-16.1.2 Condensate pipe. Pipe shall be steel; seamless ASTM A 53, Grade B or ASTM A 106, Grade B, schedule 80; electric resistance welded ASTM A 53, Grade B; Schedule 80. ASTM A 53, Type F furnace butt welded pipe will not be allowed. Joints will not be allowed in the factory fabricated section of the carrier pipe. Factory fabricated piping sections, as part of an expansion loop or bend shall have all welded joints 100% radiographically inspected in accordance with ASME B31.1.

4-16.2 Factory fabricated, direct-buried DDT systems.

4-16.2.1 Casing. Casing shall be smooth-wall steel, electric resistance spiral welded, conforming to ASTM A 134, ASTM A 135, or ASTM A 139. Minimum casing thickness shall be 6.35 mm (0.25 inches). Eccentric connectors shall be provided between casing sections as needed to provide drainage of casing section between manholes and between manholes and buildings.

4-16.2.2 Casing End Plates, Vents, and Drains. End plates shall be made of ASTM A 36/A 36M steel, minimum thickness 13 mm (1/2 inch) for conduit pipe sizes above 300 mm (12 inches) and 9.5 mm (0.375 inches) for conduit pipe sizes 300 mm (12 inches) and less. A 25 mm (1 inch) ASTM A 53, Sch 40, galvanized vent riser pipe shall be provided on end plate vent opening. Vent pipe shall extend to top of manhole and terminate 300 mm (12 inches) above grade with a 180 degree bend. A 25 mm (1 inch) drain shall be provided at the bottom and vent at the top. Brass plugs and half coupling, constructed with welded steel and welded to the end plate, shall be furnished; drains shall be plugged; vents shall not be plugged.

- 4-16.2.3 Air space. Continuous 25 mm 1 inch minimum air space shall be provided between carrier pipe insulation and casing.
- 4-16.2.4 Casing coating. Coating shall be rated by manufacturer for continuous service for at least 25 years at temperatures of 110 degrees C. 230 degrees F. Coating shall be applied in accordance with the coating manufacturer's instructions, shall be factory inspected for holidays and repaired as necessary.
- 4-16.2.5 Field connections. Field connection of casing sections shall be made using a compatible steel section, welded to casing sections, coated on all surfaces with manufacturer's coating field repair compound, and covered with a 1.3 mm (0.05 inch) minimum thickness polyethylene shrink sleeve designed for a service temperature exceeding 80 degrees C (176 degrees F).
- 4-16.3 Factory fabricated, direct-buried water spread limiting (WSL) systems.
- 4-16.3.1 Casing for Steam and Condensate. The casing shall be reinforced thermosetting resin plastic (RTRP) piping manufactured by the filament winding process. The casing pipe shall be wound to meet ASTM D 2310 classification RTRP and ASTM D 2996. The resin shall be a polyester isothalic resin. The outer surface shall be coated with a pigmented, protected resin containing a parafinated wax and ultraviolet inhibitors. Casing thickness shall be 5 mm (0.185 inches) for 100 mm (4 inches) and below carrier pipe sizes and 6.5 mm (0.25 inches) for carrier pipe sizes above 100 mm (4 inches). Condensate piping shall not be located in casings which contain any other piping.
- 4-16.3.2 End seals. Each preinsulated section of piping shall completely seal the insulation, providing a permanent water and vapor seal at each end. Preinsulated factory fabricated sections of piping modified in the field shall be provided with an end seal which is equivalent to the end seals furnished with the preinsulated section of piping.
- 4-16.3.3 Pipe coupling, steam. Coupling shall be of a multi-stage seal designed to accommodate the expansion and contraction of the system in the coupling. Couplings shall be of corrosion resistant materials. The annular seals and carrier pipe ends shall be specifically designed to protect the seals and resist abrasion due to lateral loads in the system.
- 4-16.3.4 Pipe coupling, condensate. Coupling shall be a single stage seal design to accommodate the expansion and contraction of the adjacent pipes. Coupling shall be of corrosion resistant materials. The annular seals and carrier pipe ends shall be specifically designed to protect the seals and resist abrasion due to lateral loads in the system.
- 4-16.4 Insulation. The minimum thickness of insulation for the heat distribution system shall be in accordance with Tables 1 and 2.

**Table 4.2 Minimum Pipe Insulation Thickness (mm)  
 For Steam (100 to 2.800 kPa (gage)) and High Temperature  
 Hot Water Supply and Return (120 to 230 degrees C)**

INSULATIONS For Drainable/Dryable Systems				INSULATIONS For other Pre-Engineered Systems	
Nominal Pipe Diameter (mm)	Paroc	Epitherm Delta	Kaylo-10 Thermo-12 Super Caltemp	Calcium Silicate	WSL Polyurethane
-----				-----	

**Project Name**  
**UEPH Complex**

**Project Number**  
**Statement of Work**  
**26 November 2001**

25	50	63	100	N/A	N/A
40	50	63	100	N/A	N/A
50	63	85	110	N/A	N/A
65	63	85	110	N/A	N/A
80	75	100	125	25	+31
100	75	100	125	25	+31
125	75	100	125	N/A	N/A
150	85	110	135	35	+34
200	85	110	135	50	+30
250	100	125	150	63	+33
300	100	125	150	50	+32
350	100	125	150	N/A	N/A
400	100	125	150	N/A	N/A
450	100	125	150	N/A	N/A

**Table 4.3 Minimum Pipe Insulation Thickness (inches)  
For Steam (16 to 408 psig) and High Temperature  
Hot Water Supply and Return (250 to 450 degrees F)**

Nominal Pipe Diameter (inches)	INSULATIONS For Drainable/Dryable Systems			INSULATIONS For other Pre-Engineered Systems	
	Paroc	Epitherm Delta	Kaylo-10 Thermo-12 Super Caltemp	Calcium Silicate	WSL Polyurethane
1.0	2.0	2.5	4.0	N/A	N/A
1.5	2.0	2.5	4.0	N/A	N/A
2.0	2.5	3.5	4.5	N/A	N/A
2.5	2.5	3.5	4.5	N/A	N/A
3.0	3.0	4.0	5.0	1.0	+1.23
4.0	3.0	4.0	5.0	1.0	+1.22
5.0	3.0	4.0	5.0	N/A	N/A
6.0	3.5	4.5	5.5	1.5	+1.34
8.0	3.5	4.5	5.5	2.0	+1.21
10.0	4.0	5.0	6.0	2.5	+1.31
12.0	4.0	5.0	6.0	2.0	+1.29
14.0	4.0	5.0	6.0	N/A	N/A
16.0	4.0	5.0	6.0	N/A	N/A
18.0	4.0	5.0	6.0	N/A	N/A

**Table 4.4 Minimum Pipe Insulation Thickness (mm)  
For Condensate Return and High Temperature Hot Water Return System**

Nominal Pipe Diameter (mm)	Paroc	Epitherm Delta	Kaylo-10 Thermo-12 Super Caltemp	Polyurethane
25	35	50	75	N/A
40	35	50	75	N/A
50	35	50	75	19
65	35	50	75	N/A
80	50	63	85	26
100	50	63	85	26
125	50	63	85	N/A
150	63	76	110	30
200	63	76	110	N/A
250	76	100	125	N/A
300	76	100	125	N/A
350	76	100	125	N/A
400	76	100	125	N/A
450	76	100	125	N/A

**Table 4.5 Minimum Pipe Insulation Thickness (inches)**  
**For Condensate Return and High Temperature Hot Water Return System**

Nominal Pipe Diameter (inches)	Paroc	Epitherm Delta	Kaylo-10 Thermo-12 Super Caltemp	Polyurethane
1.0	1.5	2.0	3.0	N/A
1.5	1.5	2.0	3.0	N/A
2.0	1.5	2.0	3.0	0.77
2.5	1.5	2.0	3.0	N/A
3.0	2.0	2.5	3.5	1.05
4.0	2.0	2.5	3.5	1.05
5.0	2.0	2.5	3.5	N/A
6.0	2.5	3.0	4.5	1.32
8.0	2.5	3.0	4.5	N/A
10.0	3.0	4.0	5.0	N/A
12.0	3.0	4.0	5.0	N/A
14.0	3.0	4.0	5.0	N/A
16.0	3.0	4.0	5.0	N/A
18.0	3.0	4.0	5.0	N/A

4-16.5 Expansion loops and bends. Stresses shall be less than the maximum allowable stress from the Power Piping Code (ASME B31.1). Detailed design layout drawings and stress and anchor force calculations shall be provided for all loops and bends. Locations of all anchors, guides and supports shall be shown. Pipe-stress and system-expansion calculations for each expansion compensation elbow using a finite element computer generated 3 dimensional analysis. Calculations shall demonstrate that pipe stresses from temperature changes are within the allowable requirements in ASME B31.1 and that the anchors and the guides will withstand the resultant forces. Detailed design layout drawings shall include all analysis node points. As a minimum, computer analysis results shall include node stresses, forces, moments and displacements. Calculations shall be stamped by a registered Professional Engineer in the employ of the system manufacturer.

4-16.6 Manholes and anchors. Design and installation shall be in accordance with the published data of the manufacturer.

4-16.7 Installation. The piping system furnished shall be installed in accordance with the piping system manufacturer's instructions. The Contractor shall obtain the services of a trained representative of the pipe system manufacturer to instruct the Contractor's work forces in the installation procedures to ensure that the system is installed in accordance with the manufacturer's published instructions and the plans and specifications. The manufacturer's representative shall be a person who regularly performs such duties for the manufacturer.

4-16.8 Testing. The carrier piping shall be hydrostatically tested at 1 ½ times the working pressure for the system. The casing shall be tested in accordance with the manufacturer's recommendations.

4-17 **FUEL OIL STORAGE AND DISTRIBUTION.** [Insert "DELETED" if not applicable and delete remainder of text in all paragraphs.] Fuel oil storage and distribution system shall be

installed to supply the fuel oil-fired heating equipment. Provide a complete fuel oil storage and distribution system designed in accordance with local codes, installation requirements, NFPA 30, and NFPA 31, whichever are more stringent. Tank size shall be determined using the ASHRAE Degree Day Method using the degree-days for the coldest 30-day period for the site.

4-17.1 Tank storage. Each facility shall be provided with a separate fuel oil storage tank. Fuel oil storage tanks may be located underground or aboveground. Storage tanks shall be placed in a location suitable for filling from a curbside delivery truck. Above ground tanks shall be visually screened by a wall. Fuel oil tanks shall be located in accordance with local codes, and shall be installed a minimum of 0.3 m [1 ft] from the edge of the tank shell to the nearest outside wall of any building or basement or from the nearest adjoining property line. Where tanks are located adjacent to exterior walls or other surfaces requiring periodic painting or other maintenance/repair requirements, a minimum clearance of 1m [3ft] from the edge of the tank is preferred. Underground tanks shall be located such that loads supported by building foundations cannot be transferred to the tank. Proposed tank location shall be clearly indicated in the design submittal.

4-17.1.1 Aboveground tanks. Fuel oil storage tanks shall be aboveground, double wall type with leak detection monitoring. Tank containment shall comply with applicable NFPA, EPA, and local code requirements. Provide concrete pads as required by code or as recommended by the tank manufacturer.

4-17.1.2 Underground tanks. Fuel oil storage tanks installed below grade shall be double-walled type constructed using fiberglass or steel, and installed in accordance with the manufacturer's recommendations. The top of the tank shall be at least 0.6 m [2 ft] below finished grade. Fiberglass tanks shall be constructed in accordance with UL 1316. Steel tanks shall be Type II, constructed in accordance with UL 58, with an STI-P3 coating and guarantee except that the cathodic protection system shall be based on protecting 5 percent of the tank's metal surface. Tanks shall be provided with the necessary fill, vent, gauge, hatch, and suction connections.

4-17.2 Fuel oil piping. Underground fuel oil piping shall be of double-wall construction, installed without traps or sags. Outer, secondary containment pipe shall be non-metallic. Above ground piping shall be single-wall metallic pipe. Gate valves shall not be used in fuel oil piping systems. A replaceable filter shall be provided upstream of the fuel oil pump. Pipe connectors shall be in accordance with UL 567.

4-17.3 Leak detection system. A continuous surveillance leak detection system suitable for operation in an NFPA 70, Class 1, Division 1, Group D environment shall be provided to monitor the leak containment space between the interior and exterior walls of double-wall pipe and tanks. The system shall detect leakage into the containment space electronically or by monitoring interstitial pressure or liquid level variations. Liquids used in the containment space for steel tanks shall have a corrosion inhibitor. Liquids subject to freezing conditions shall contain an antifreeze solution. The leak detection system shall be compatible with the piping and tank furnished. Instructions and equipment required for calibration of the leak detection system and manufacturer's recommended calibration maintenance schedule shall be provided.

4-17.4 Special requirements. [Research local requirements for fuel oil systems installation and either add or delete items from this sub-paragraph.]

4-17.4.1 Spill containment fill. Underground tank fill connection shall be provided in a spill container of 11.4 L [3 GAL] capacity minimum. Contained spills shall be drained into the storage tank by means of a quick-acting drain valve.

4-17.4.2 Overfill prevention valve. The overfill prevention valve shall be placed within the tank interior and be an integral part of the fill tube. The valve shall be a float actuated shut-off valve.

The valve shall be constructed of the same material as the fill tube. The valve shall have two stages of shutoff. In the first stage, the valve shall restrict the flow of fuel oil into the tank to approximately 0.315 L/s [5 gpm] when the liquid level rises above 95 percent of the tank capacity. In the second stage, the valve shall completely stop the flow of fuel oil into the tank when the liquid level rises above 98 percent of the tank capacity.

4-17.4.3 Tank screening. Provide sight screening for the tank to reduce the visual impact of the fuel oil storage tank. Visual screening may be vegetation or fencing, in compliance with the local standards. [Design District shall ensure that aboveground fuel oil storage tanks are suitably screened from view. The requirements of this paragraph may be modified to suit local requirements.]

4-18 **LIQUEFIED PETROLEUM (LP) GAS STORAGE AND DISTRIBUTION.** LP gas tanks shall comply with requirements of NFPA 58 and the ASME Code, Section VII, Pressure Vessels. Tanks shall be pad mounted, and shall not be located inside any building. Tanks shall be provided with all required gauges, shut off valves, safety devices, and suction connections. Shut off valves shall be installed at each tank, at the service entry to the building (if not in sight of the tank), and at each heating unit. No shut off valve shall be installed between a safety device and tank. LP gas pressure shall be reduced to a minimum service pressure of 3.5 kPa [ $\frac{1}{2}$  psi] prior to the building entrance. LP gas pipe connectors shall be in accordance with UL 567.

4-19 **ELECTRICAL DISTRIBUTION.** [Design District shall determine where power is to be obtained, if system is to be overhead or underground, and provide applicable characteristics of the primary system.]

4-19.1 Overhead distribution. System shall consist of wood, steel, aluminum or concrete poles and bare copper conductors. Design shall be in accordance with ANSI C2 and NFPA 90.

4-19.2 Underground distribution. System shall consist of direct buried conduit and copper conductors. Design shall be in accordance with ANSI C2 and NFPA 90.

4-19.3 Service entrance. Shall be in accordance with NFPA 90.

4-19.4 Transformers. Transformers shall be pad mount. The high voltage compartment shall contain incoming primary feeder, load break switch, fuse protection and surge protection. The nameplate rating for the transformer shall not be less than 90 percent of the KVA demand load calculated for the transformer. [Insert transformer sizing, demand performance and other applicable characteristics.]

4-19.5 Street and area lighting. Residential roadway lighting, including collector streets, shall be provided in accordance with the IES Lighting Handbook. Provide lighting at roadway intersections, and at intervals not exceeding 60.9 m [200 ft] between intersections. Area lighting shall be provided at intervals not exceeding 60.9 m [200 ft] along area walkways not otherwise illuminated, common area walks, and at all steps in area walkways. Area lighting shall be provided in accordance with the IES Lighting Handbook. Luminaries shall be actuated by photoelectric control, one photocell per circuit.

4-19.6 Metering. [Design District shall determine metering requirements.]

4-20 **TELEPHONE.** The [Telephone company] [DOIM] [Contractor] will furnish and install distribution cables. Conduit required between underground terminal boxes and the buildings shall be provided by the Contractor. Trenching and backfill required to install the telephone company cables shall be included in the construction contract. Contractor provided boxes, conduits, and trenching shall comply with local telephone company criteria and shall be coordinated with the telephone company. Coordinate with Installation Director of Information Management (DOIM) for specific requirements.

4-21 **TELEVISION.** [Provide commercial cable TV or site distribution system(s) when feasible. Requirements to be edited in accordance with local conditions and availability.] An antenna system or connection to a TV distribution system shall be provided for each facility. The TV system shall provide for UHF and VHF reception for color TV. The antenna system may be either a common antenna serving the entire project (mast or dish), an attic antenna system for each separate building, or attic antenna for each facility [Edit as required]. The Contractor shall provide all trenching, conduit, boxes, and backfilling required to install commercial and/or Contractor provided distribution systems.

4-22 **CATHODIC PROTECTION.** Cathodic Protection (CP) is mandatory on buried ferrous metallic structures as described below:

4-22.1 Department of Transportation guidance. Shall be as stated in 49 CFR, Part 192, requires that all metallic natural gas piping be coated and cathodically protected regardless of the soil resistivity.

4-22.2 Corrosion control. Mandated for all metallic underground storage tanks storing petroleum or hazardous substance by 40 CFR, Part 280 and AR 200-1 and on hazardous liquid pipelines (e.g., liquid fuel) by 49 CFR, Part 195.

4-22.3 Design requirements. CP systems must be designed to provide protective potential to meet the requirements of the National Association of Corrosion Engineers (NACE) Standard RP-0169, Control of External Corrosion on Underground or Submerged Metallic Piping Systems, or NACE Standard RP-0185, Control of External Corrosion on Metallic Buried, Partially Buried, or Submerged Liquid Storage Systems, as appropriate.

4-22.4 Compatibility. New or supplemental CP systems shall be compatible with existing CP systems and other adjacent structures or components. New systems should be compatible with existing systems to allow ease of repair and maintenance.

4-22.5 Tracer wire. When plastic pipe is used to extend a steel gas distribution main, an insulated No. 8 AWG copper wire shall be exothermically welded to the existing steel main and run the length of the new plastic main. This wire can be used as a locator tracer wire and to maintain continuity to any future steel gas main extension.

4-22.6 Coatings. CP and protective coatings shall be provided for the following buried and submerged ferrous metallic structures regardless of soil or water resistivity.

4-22.6.1 Natural gas and propane piping.

4-22.6.2 Liquid fuel piping.

4-22.6.3 Underground fuel storage tanks. Not required for those coated in accordance with UL1746.

4-22.6.4 Fire protection piping.

4-22.6.5 Ductile or cast iron piping. Required for pressurized piping under floor (slab on grade) in soil.

4-22.6.6 Conduit piping systems. Required for underground heat distribution and chilled water piping in ferrous metallic conduit.

4-22.6.7 Hazardous storage structures. Structures with hazardous products as identified by the installation.

4-22.7 Cast iron pipe. Shall be treated as follows:

4-22.7.1 Below 10,000 Ohm-cm: For soil resistivity below 10,000 Ohm-cm at pipeline installation depth, provide CP, bonded joints, and protective coatings.

4-22.7.2 Between 10,000 and 30,000 Ohm-cm: For soil resistivity between 10,000 and 30,000 Ohm-cm at pipeline installation depth, provide bonded joints only.

4-22.8 Copper water service lines: Piping will be dielectrically isolated from ferrous pipe. Dielectric isolation shall conform with NACE RP-0286.

4-22.9 Ductile iron piping systems: Conduct an analysis (except for ductile iron piping under floor in soil) to determine if CP and/or bonded or unbonded coatings are required. Unbonded coatings are defined in ANSI/AWWA C105/A21.5.

4-22.10 Economic analysis: Conduct an economic analysis to determine if CP and protective coatings should be provided for gravity sewer lines and the following structures in soil resistivity conditions above 10,000 Ohm-cm:

4-22.10.1 Potable water lines.

4-22.10.2 Concentric neutral cable.

4-22.10.3 Other structures. Buried and submerged ferrous metallic structures not covered above.

4-22.11 Contact with concrete. Ferrous metallic piping passing through concrete shall not be in contact with the concrete.

## **CHAPTER 5**

### **ARCHITECTURAL DESIGN**

5-1 **DESIGN GOALS.** Overall architectural goals for the UEPH complex are to provide a functional, visually appealing campus of facilities that is a source of pride for residents, other facility users, and the installation.

5-1.1 **Site Planning Objectives.** Provide a pedestrian-oriented site. Locate buildings to create outdoor spaces. Group buildings in configurations that create a sense of community and enable residents to readily identify their homes. Integrate sustainable design principles by retaining and using existing topography to advantage; preserve environmentally sensitive areas and reduce overall project impact on the site.

5-1.2 **Exterior Design Objectives.** Design buildings to enhance the visual environment of the installation. Exterior materials, roof forms, and detailing shall comply with the Installation Design Guide, and shall be compatible with the immediate local context. Use durable, low-maintenance materials. Configure building massing and use exterior elements such as colonnades, porticos, entry porches, and material detailing to provide human scale.

5-1.3 **Interior Design Objectives.** Arrange spaces in an efficient, functional manner. Provide simple circulation schemes that allow easy wayfinding within buildings. Use durable materials and furnishings that can be easily maintained and replaced. Maximize use of daylighting and operable windows. Use interior surfaces that are easy to clean and light in color; avoid trendy or bright color schemes. Design UEPH interiors with a residential ambience. To the extent possible, design interiors that residents can personalize (for example, arrange living units to allow more than one furniture placement scheme; provide telephone/data jacks on multiple walls to allow optional locations for the desk). Structure interior spaces to allow maximum flexibility for future modifications; companies and battalions often change size or mission, requiring reconfiguration of facilities.

5-1.4 **Material and Product Selection Criteria.** Materials shall meet the requirements of the SOW. The SOW includes a range of specificity: some material requirements are specific (no option); other material requirements allow a range of options. The SOW requirements establish a minimum quality level. Higher quality materials will be judged more favorably. The offeror's proposal shall identify the quality level of all major materials to be provided.

5-2 **APPLICABLE CODES AND STANDARDS.** Except as specified otherwise in the RFP, design and construction of facilities shall comply with the latest editions (as of the date of the RFP) of the following. Major criteria references for building design are listed below; additional requirements are included throughout the RFP. Refer to Appendix A for a list of criteria references, and sources of availability.

5-2.1 National Fire Codes, published by the National Fire Protection Association (NFPA), including NFPA 101 Life Safety Code.

5-2.2 International Building Code (IBC).

5-2.3 Federal Std 795 Uniform Federal Accessibility Standards (UFAS), and Americans With Disabilities Act Accessibility Guidelines for Buildings and Facilities (ADAAG). Where these criteria conflict, the most stringent requirement shall apply.

5-2.4 Interim Department of Defense Antiterrorism / Force Protection Standards.

5-2.5 The [insert name of post] Installation Design Guide (IDG), excerpts of which are included in an appendix to the Statement of Work.

5-2.6 [Insert any additional regulations known to have an impact on facility design and construction, such as airfield height limitations; AICUZ/APZ information; historic area requirements; etc. Include excerpts of the document in an appendix to the SOW, or include source of availability in Appendix A References.].

### 5-3 **IBC OCCUPANCY AND BUILDING TYPE CLASSIFICATIONS.**

5-3.1 **General.** Occupancy classifications, construction types, allowable areas, maximum building heights, and fire separation requirements shall comply with the requirements of the International Building Code.

5-3.2 **UEPH Buildings.** Occupancy classification: Residential Group R-1.

5-3.3 **Company Operations Facilities.** [Note: previously constructed COFs have used Uniform Building Code Group B occupancy classification throughout. The following International Building Code occupancy classifications of spaces within the COF are intended to more accurately represent the uses of each area in the facility. Prior to issuance of the RFP, the design district shall coordinate with the authority having jurisdiction to determine occupancy classifications. Consult with the users to determine the hazard classification of items to be stored in the supply spaces. This model Statement of Work is written based upon IBC Storage Group S-1 or S-2 classification of the Arms Vault and other supply spaces. If hazardous materials, ammunition or other explosives will be stored, the IBC will require classification of the space as High-Hazard Group H-1, and if the amount of explosive material exceeds the maximum allowable quantity per control area, a separate building will be required (see IBC Section 307 and Table 307.7(1)). This, obviously, has a significant impact on the facility design and cost, and must be determined prior to issuance of the RFP.] Occupancy classification of administrative areas, and locker room facilities serving less than 50 occupants: Business Group B. Occupancy classification of supply areas: Storage Group S-2 [or S-1; verify contents of spaces with user]. Common Locker Rooms for 50 or more occupants: Assembly Group A-3.

5-3.4 **Battalion Headquarters.** Occupancy classification of administrative areas: Business Group B. Occupancy classification of classroom areas: Assembly Group A-3.

5-3.5 **Brigade Headquarters.** Occupancy classification: Business Group B.

### 5-4 **EXTERIOR DESIGN.**

5-4.1 **Acceptable Materials and Colors.** Exterior elements of the facilities shall comply with the Installation Design Guide (IDG) unless required otherwise by applicable codes or this Statement of Work.

5-4.2 **Exterior Walls.** Comply with IDG. Where masonry exterior wall finish material is used, and where allowed by code, concrete masonry or metal stud backup wall may be used. Exterior insulation finish systems shall not be used [may be used as exterior accent materials, not primary wall material] [Coordinate with installation facilities engineer (DPW) and edit

appropriately].

5-4.3 **Roofs.** Sloped roofs with a minimum pitch of [ ] : 12 shall be used on all buildings. Roofing material and color shall comply with IDG. Roofing system shall have Underwriters Laboratory (UL) Class A rating for fire resistance, UL 90 wind resistance rating, and Factory Mutual (FM) 1-90 fire and wind resistance rating

5-4.3.1 **Metal Roofing.** Provide manufacturers 20-year finish warranty.

5-4.3.2 **Asphalt Shingle Roofing.** Provide minimum 30-year shingles; provide minimum 30# felt underlayment. Provide self-adhering rubberized ice and water shield underlayment at all valleys, and roof perimeter [review requirement in regard to local climate].

5-4.4 **Trim and Flashing.** Materials and colors shall comply with IDG. [Review the IDG to make sure that trim and flashing materials and colors are sufficiently covered.] Gutters, downspouts, and fascias shall be prefinished metal; comply with SMACNA Architectural Sheet Metal Manual; provide 20 year manufacturers finish warranty.

5-4.5 **Miscellaneous Exterior Elements.** Comply with IDG. [review the IDG to make sure that trim and minor elements are sufficiently covered. It is advisable to prohibit any use of exterior wood with painted finish; require prefinished metal trim. If not stated in IDG, require exterior metal railings to be prefinished aluminum, or if acceptable to installation facilities engineer (DPW), allow the more economical option of using field-painted (and adequately pre-treated) galvanized steel railings. Coordinate with user to include requirements for any building-mounted operational items such as communications antennae, special lighting, warning beacons, etc.].

5-4.6 **Signage.** Comply with IDG. [Coordinate with installation facilities engineer (DPW); provide criteria for quantity, type, size and location of building identification signs. Note whether signs require illumination].

5-4.7 **Exterior Doors and Frames.**

5-4.7.1 **Main Entrance Doors.** Doors opening to building corridors or lobbies shall be aluminum storefront doors and frames with Architectural Class I anodic finish or AAMA 2605 organic coating finish. Color shall comply with IDG. Doors shall be minimum 45 mm [1-3/4"] thick. Fully glazed stile and rail doors shall be medium or wide stile. Provide aluminum storefront systems that comply with wind load requirements of applicable codes. Framing systems shall have thermal-break design.

5-4.7.2 **Exterior Non-entrance Doors.** Exterior doors and frames opening to spaces other than corridors or lobbies shall be hollow metal; comply with ANSI A250.8/SDI 100. Doors shall be Level 3, physical performance Level A, Model 2; insulated; top edge closed flush. Frames shall be Level 3, 14 gauge, with continuously welded corners and seamless face joints. Doors and frames shall be constructed of hot dipped zinc coated steel sheet, complying with ASTM A653, Commercial Steel, Type B, minimum A40 coating weight; factory primed. Anchors and accessories shall be zinc coated. Frames in masonry shall have bituminous back-coating, plaster guards, and shall be grouted solid. Fire-rated openings shall comply with NFPA 80, and the requirements of the labeling authority.

5-4.7.3 **Exterior Door Finish Hardware.**

5-4.7.3.1 **Hinges.** ANSI/BHMA A156.1; template, full mortise, heavy duty, ball bearing, minimum size 4 ½" x 4 ½", non-ferrous base metal, non-removable pins.

5-4.7.3.2 **Locksets on Living Unit Entry Doors.** ANSI/BHMA A156.13; mortise lockset with removable core; non-ferrous base metal.

5-4.7.3.3 **Locksets on Exterior Hollow Metal Doors.** ANSI/BHMA A156.2; series 4000, Grade 1, non-ferrous base metal, removable core.

5-4.7.3.4 **Exit (Panic) Devices.** ANSI/BHMA 156.3; heavy-duty touch-pad type, through-bolted mounting. Listed and labeled for panic protection based on UL 305.

5-4.7.3.5 **Closers.** ANSI/BHMA A156.4; series C02000, Grade 1, hydraulic, factory-sized, adjustable to meet field conditions. Provide for all exterior doors, all entry doors to living units, all doors opening to corridors and as required by codes. At exterior doors to lobbies, corridors, mechanical rooms, janitors closets, and COF supply areas provide overhead holders or closers with hold-open capability.

5-4.7.3.6 **Auxiliary Hardware.** ANSI/BHMA A156.16. Provide wall or floor stops for all exterior doors that do not have overhead holder/stops. Provide other hardware as necessary for a complete installation.

5-4.7.3.7 **Thresholds.** ANSI/BHMA A156.21; non-ferrous metal. Provide at all exterior doors.

5-4.7.3.8 **Weatherstripping.** ANSI/BHMA A156.22. Provide at all exterior doors.

5-4.7.3.9 **Kick Plates.** ANSI/BHMA A156.6; non-ferrous metal. Provide at all doors with closers.

5-4.8 **Exterior Windows.** Provide aluminum windows complying with American Architectural Manufacturers Association AAMA/NWWDA 101 / I.S. 2. Minimum performance class shall be Heavy Commercial (HC). Minimum wind load, and resulting design pressure and performance grade shall be determined in accordance with the International Building Code (IBC). Provide windows with insulating glass and thermal break necessary to achieve a minimum Condensation Resistance Factor (CRF) of 45 [edit to require higher factor for very cold climates]. Finish shall be Architectural Class I anodic coating or AAMA 2605 organic coating [Edit to allow anodic coating if clear or bronze anodized color is acceptable]. All sleeping rooms shall have operable windows complying with egress requirements of applicable codes. Operable windows shall have locks; provide fiberglass or aluminum insect screens removable from the inside.

5-4.8.1 **Exterior Glass and Glazing.** To comply with force protection minimum standards: Single glazing and the inner pane of insulated glass assemblies in exterior windows and doors shall be minimum 6 mm (1/4-inch) annealed laminated glass.

5-4.9 **Thermal Insulation.** Provide exterior wall, floor, and roof/ceiling assemblies with thermal transmittance (U-values) required to comply with the proposed energy calculations for the facilities. Insulation shall not be installed directly on top of suspended acoustical panel ceilings.

5-4.10 **Exterior Noise Control.** [Add requirements for insulation of exterior walls and roof/ceiling assemblies for attenuation of external noise sources such as airfields].

5-5 **INTERIOR DESIGN.**

5-5.1 **Floors.** Comply with requirements of applicable codes. Non-combustible construction is preferable, even where combustible materials are allowed by code. Floor finish materials shall be as specified in functional and area requirements listed in Chapter 2 of the Statement of Work.

5-5.2 **Ceramic Tile.** Comply with ANSI A 137.1 and the recommendations of Tile Council of America (TCA) Handbook For Ceramic Tile Installation. Provide marble threshold under doors where a ceramic tile floor meets a different floor finish.

5-5.3 **Interior Walls and Partitions.** Comply with requirements of applicable codes. Non-combustible construction is preferable, even where combustible materials are allowed by code. Wall finish materials shall be as specified in functional and area requirements listed in Chapter 2 of the Statement of Work

5-5.3.1 **Metal Support Systems.** Non-load bearing metal studs and furring shall comply with ASTM C 645; stud gauge shall be as required by height and loading, but shall not be less than 25 gauge. Maximum stud spacing: 406 mm [16"] on center. Provide galvanized finish.

5-5.3.2 **Gypsum Board.** Comply with ASTM C 36. Minimum panel thickness: 16 mm [5/8"]. Provide Type X panels in fire-rated assemblies. Provide moisture resistant panels at locations subject to moisture. Provide abuse-resistant panels where indicated in functional and area requirements. Joint treatment: ASTM C 475. Screws ASTM C 646. Drywall installation: ASTM C 840.

5-5.3.3 **Ceramic Tile.** Comply with ANSI A 137.1 and the recommendations of Tile Council of America (TCA) Handbook For Ceramic Tile Installation. Substrate for wall tile shall be mortar setting bed or cement backer board (gypsum board is not acceptable). Provide marble threshold under doors where a ceramic tile floor meets a different floor finish.

5-5.4 **Ceilings.** Comply with requirements of applicable codes. Non-combustible construction is preferable, even where combustible materials are allowed by code. Ceiling finish materials shall be as specified in functional and area requirements listed in Chapter 2 of the Statement of Work.

5-5.5 **Interior Doors and Frames.** Provide hollow metal doors, or flush wood solid core doors at UEPH and administrative spaces. Provide hollow metal doors at COF supply spaces. All frames shall be hollow metal.

5-5.5.1 **Wood Doors.** Provide flush wood solid core doors complying with National Wood Window and Door Association (NWWDA) I.S.-1A. Stile edges shall be non-finger jointed hardwood compatible with face veneer. Provide American Woodwork Institute (AWI) Grade A hardwood face veneer for transparent finished doors; provide AWI Sound Grade hardwood face veneer for painted doors. Transparent finished doors are preferred.

5-5.5.2 **Hollow Metal Doors.** Comply with ANSI A250.8/SDI 100. Doors shall be Level 2, physical performance Level B, Model 2; factory primed. Anchors and accessories shall be zinc

coated. Frames in masonry shall have bituminous back-coating, plaster guards, and shall be grouted solid.

5-5.5.3 **Hollow Metal Frames.** Comply with ANSI A250.8/SDI 100. Frames shall be Level 2, 16 gauge, with continuously welded corners and seamless face joints; factory primed. Anchors and accessories shall be zinc coated. Frames in masonry shall have bituminous back-coating, plaster guards, and shall be grouted solid.

5-5.5.4 **Fire-rated and Smoke Control Doors and Frames.** Comply with International Building Code (IBC), NFPA 80, and requirements of labeling authority. Doors and frames shall bear labels from IBC approved testing laboratory. Comply with positive pressure testing requirements of IBC.

5-5.5.5 **Interior Door Finish Hardware.**

5-5.5.5.1 **Hinges.** ANSI/BHMA A156.1; template, full mortise; heavy duty, ball bearing on doors with closers; standard duty anti-friction bearing on doors without closers. Minimum size 4 1/2" x 4 1/2".

5-5.5.5.2 **Locksets on Living Unit Entry Doors.** ANSI/BHMA A156.13; mortise lockset with removable core; non-ferrous base metal.

5-5.5.5.3 **Locksets on Interior Doors.** ANSI/BHMA A156.2; series 4000, Grade 1, non-ferrous base metal, removable core.

5-5.5.5.4 **Exit (Panic) Devices.** ANSI/BHMA 156.3; heavy-duty touch-pad type, through-bolted mounting. Listed and labeled for panic protection based on UL 305.

5-5.5.5.5 **Closers.** ANSI/BHMA A156.4; series C02000, Grade 1, hydraulic, factory-sized, adjustable to meet field conditions. Provide for all entry doors to living units, all doors opening to corridors and as required by codes.

5-5.5.5.6 **Auxiliary Hardware.** ANSI/BHMA A156.16. Provide wall or floor stops for all doors that do not have overhead holder/stops. Provide other hardware as necessary for a complete installation.

5-5.5.5.7 **Kick Plates.** ANSI/BHMA A156.6; non-ferrous metal. Provide at all doors with closers.

5-5.6 **Limitations on Use, Classification, and Flame Spread and Smoke Developed Ratings of Interior Finishes.** Refer to paragraph 12-6.2.

5-5.7 **Casework.**

5-5.7.1 **Service Areas in Living Units and Coffee Areas in Admin Areas.** Provide manufactured unitized kitchen; or provide architectural cabinets complying with AWI Quality Standards, Section 400, Custom Grade cabinets with high pressure decorative laminate finish, meeting NEMA LD3 standards. Horizontal laminate: nominal .050" thick; vertical laminate: nominal .028" thick. Door and drawer edges shall be heavy duty 3 mm extruded polyvinyl chloride with self-locking serrated tongue. Countertop shall be post-formed high pressure decorative laminate with waterfall front edge and integral coved backsplash, or solid surfacing

material.

5-5.7.2 **Bathroom Vanity in Living Units.** Provide manufactured unitized kitchen, or provide architectural cabinets complying with AWI Quality Standards, Section 400, Custom Grade cabinets with high-pressure decorative laminate finish, meeting NEMA LD3 standards. Horizontal laminate :nominal .048" thick; vertical laminate nominal .028" thick. Door and drawer edges shall be heavy duty 3 mm extruded polyvinyl chloride with self-locking serrated tongue. Vanity countertop shall be post-formed high pressure decorative laminate with waterfall front edge and integral coved backsplash, or solid surfacing material, or cast-filled acrylic with integral lavatory bowl.

5-5.7.3 **UEPH Building CQ Station Reception Desk.** Provide architectural casework complying with AWI Quality Standards, Section 400, Custom Grade cabinets with high pressure decorative laminate finish meeting NEMA LD3 standards. Horizontal laminate: nominal .048" thick; vertical laminate: nominal .028" thick. Door and drawer edges shall be heavy duty 3 mm extruded polyvinyl chloride with self-locking serrated tongue. Worksurfaces and counter shall be high pressure decorative laminate, or solid surfacing material.

5-5.7.4 **Vanity at Public Toilets.** Provide architectural casework complying with AWI Section 400, Custom Grade cabinets with high pressure decorative laminate finish meeting NEMA LD3 standards. Horizontal laminate: :nominal .050" thick; vertical laminate: nominal .028" thick. Provide enclosed wall-hung vanity cabinet with countertop, or wall-hung countertop with apron. Exposed piping at accessible lavatories shall be insulated in conformance with ADA/UFAS. Countertop shall be post-formed high pressure decorative laminate with waterfall front edge and integral coved backsplash, or solid surfacing material.

5-5.7.5 **Other casework.** Provide architectural casework complying with AWI Section 400, Custom Grade cabinets with high pressure decorative laminate finish meeting NEMA LD3 standards. Horizontal laminate: nominal .050" thick; vertical laminate: nominal .028" thick. Door and drawer edges shall be heavy duty 3 mm extruded polyvinyl chloride with self-locking serrated tongue. Worksurfaces and counter shall be high pressure decorative laminate, or solid surfacing material.

5-5.8 **Window Treatments.** Provide horizontal aluminum mini-blinds at all exterior windows, except windows and storefront in corridors and lobbies. Blinds shall have one-inch wide x .008-inch thick slats with anti-static, anti-microbial polyester baked enamel finish. Provide heavy duty 1" x 1-1/2" steel headrail, and tubular steel bottom rail finished to match slats.

5-5.9 **Interior Signage.** Comply with requirements of ADAAG and UFAS. Provide interior room identification signage for the following spaces: Public toilets, [Coordinate with user and installation facilities engineer (DPW). Identify all rooms which require room identification signage; coordinate with the installation interior signage standard, if one exists].

5-5.10 **Elevators.** The offeror shall provide the services of an elevator inspector employed by an independent testing company to inspect the elevator, witness the final testing, and certify elevator. The inspector shall meet all qualification requirements of ASME QEI-1 and shall be certified in accordance with ASME QEI-1. The offeror shall provide an elevator certificate signed by the inspector for each elevator. The certificate shall be provided to the Contracting Officer within 30 days of the completion of testing.

5-6 **PHYSICAL SECURITY REQUIREMENTS.**

5-6.1 **Anti Terrorism / Force Protection.** Comply with the minimum construction standards of the Interim Department of Defense Antiterrorism / Force Protection Construction Standards. [Coordinate with the installation security forces and facilities engineer (DPW) to determine if the minimum standards are adequate for the project location. If a threat analysis has identified a specific threat that requires more stringent measures than provided by the minimum standards, edit the SOW criteria accordingly.] UEPH buildings are classified as troop billeting structures; COFs, Locker Room Facilities, Battalion HQs and Brigade HQs are classified as primary gathering structures

5-6.2 **Arms Vaults at Company Operations Facilities.** Unless more stringent construction features are required by life safety or building codes, minimum construction requirements shall be as follows:

5-6.2.1 **Floor.** 152 mm [6"] slab on grade; reinforced with minimum 152 mm x 152 mm MW 25.8 x MW 25.8 [6 x 6, W2.4 x W2.4] welded wire fabric, on vapor barrier, on 152 mm [6"] deep porous fill.

5-6.2.2 **Walls.** 206 mm [8"] thick cast-in-place concrete reinforced with 15M [#5] bars at 152 mm [6"] on center, each way, each face.

5-6.2.3 **Ceiling.** 206 mm [8"] thick cast-in-place concrete reinforced with 15M [#5] bars at 152 mm [6"] on center, each way, each face.

5-6.2.4 **Door and Frame.** Class 5 vault door and frame complying with Federal Specification AA-D-00600C. Locks shall be Underwriters Laboratory listed Group 1 or 1R combination lock. Provide metal ramp type threshold. Provide wire mesh, dutch door style daygate with shelf for issuing arms and ammo. Daygate shall have lock operated from outside by key, and from inside by handle. Comply with egress requirements of applicable codes.

5-6.2.5 **Penetrations.** Penetrations shall be minimized. All openings or penetrations in Vault floor, walls or ceiling greater than .062 m<sup>2</sup> [96 square inches] shall be protected with welded steel rod-and-bar grid weighing 39.6 kg/m<sup>2</sup> [8.1 lb./sf], consisting of 25.4 mm x 4.8 mm [1" x 3/16"] vertical bearing bars at 25 mm [1"] on center, and 8 mm [5/16"] diameter horizontal rods at 50 mm [2"] on center; or equivalent protection.

5-6.2.6 **Arms Rack Anchor Rings.** Provide 10 mm [3/8"] diameter stainless steel bar bent into U-shape (25 mm inside radius) with 2" long 90 degree returns at ends of horizontal legs. Overall length shall be 127 mm [5"]; embed 76 mm [3"] of horizontal legs (open end) in concrete. 51 mm [2"] of U-shaped end will protrude from wall to provide anchorage for GFGI arms racks. Orient the projecting U-shape vertically, so that centerline of the U is 4'-0" above the floor slab. Provide anchor rings at 3'-0" on center along all walls inside the Arms Vault [Verify with user].

5-6.3 **Secured Documents Vaults.** Provide 5-sided (walls and ceiling) modular vault attached to building floor system. Vault shall conform to Class M (15 minute working time) requirements of UL 608 Standards for Modular Vault Panels. Vault shall be interfaced with building HVAC, fire protection, and electrical systems. Provide Class 5 vault door and frame complying with Federal Specification AA-D-00600C. Lock shall be Style K, key change combination lock. Provide metal ramp type threshold. Provide wire mesh, daygate with lock operated from outside by key, and from inside by handle. Comply with egress requirements of

applicable codes.

5-6.3.1 **Penetrations.** Penetrations shall be minimized. All openings or penetrations in Vault floor, walls or ceiling greater than .062 m<sup>2</sup> [96 square inches] shall be protected with welded steel rod-and-bar grid weighing 39.6 kg/m<sup>2</sup> [8.1 lb./sf], consisting of 25.4 mm x 4.8 mm [1" x 3/16"] vertical bearing bars at 25 mm [1"] on center, and 8 mm [5/16"] diameter horizontal rods at 50 mm [2"] on center; or equivalent protection.

5-6.4 **Floor Anchors for GFGL Security Safes.** Provide 10 mm [3/8"] diameter stainless steel bar bent into U-shape (25 mm inside radius) with 2" long 90 degree returns at ends of vertical legs. Overall height shall be 127 mm [5"]; embed 76 mm [3"] of vertical legs (open end) in concrete floor slab; 51 mm [2"] of U-shaped end will protrude above slab to provide anchorage for GFGL security safe.

## **CHAPTER 6**

### **STRUCTURAL DESIGN**

6-1 **GENERAL.** General: The structural criteria established herein shall be used for structural loading, design and installation of all structural systems and foundations, including manufacturing, erection, supervision, testing, and quality assurance of the completed installation of the buildings. All structural calculations shall be checked and initialed as such by a registered engineer other than the original design engineer. Construction Documents (drawings and specifications) shall be sealed and signed by a Professional Engineer registered and licensed to perform work in the jurisdiction.

6-2 **STRUCTURAL WORK.** The structural work generally consists of, but is not limited to, design and construction of:

6-2.1 Building Foundations. Spread footings, piles, drilled piers or others as required by the geotechnical investigation.

6-2.2 Ground floor slab systems. Slab on grade, pile supported or framed over crawl space as recommended by the geotechnical investigation.

6-2.3 Load Bearing and Nonload Bearing Walls, including masonry, concrete, or stud wall construction acting as primary vertical load carrying members and/or shear walls.

6-2.4 Vertical Framing Members, including steel and concrete columns, masonry pilasters or wood construction.

6-2.5 Horizontal Framing Members, including roof and floor decks and diaphragms, roof and floor beams, joists and trusses.

6-2.6 Interconnection Details, including all fastening requirements.

6-2.7 Special Conditions, such as expansion, construction, and control joints, and changes in floor levels.

6-2.8 Attachment provisions for architectural, mechanical, and electrical elements.

6-2.9 Site structures and foundations.

6-3 **DESIGN CRITERIA.** All structural loads (including dead, live, hydrodynamic, earth, snow, wind, and seismic loads) and design shall be in accordance with the International Building Code (IBC) and all codes referenced therein.

6-3.1 **Minimum Live Load Requirements:**

UEPH Floor	60 Pounds per square foot (psf)
Corridors	80 psf
Stairwells	100 psf
Roof	20 psf

6-3.2 All other building floor live loads shall be in accordance with the International Building Code (IBC).

6-4        **SELECTION OF STRUCTURAL SYSTEMS.** The structural systems shall conform to all applicable criteria and guidance as well as industry standards and commonly accepted methods of practice. Consider logical alternative foundations and framing methods when selecting an appropriate structural system. The following elements shall be evaluated and addressed:

- 6-4.1        Total Life Cycle cost effectiveness of the system.
- 6-4.2        Constructability.
- 6-4.3        Experience level of local contractors and labor force.
- 6-4.4        Availability and use of local materials.
- 6-4.5        Sustainable Design.

6-5        **SPECIAL REQUIREMENTS.**

6-5.1        AISC Certification requirements: All fabrication of structural steel shall be accomplished by an AISC certified Category Sbd fabricating plant.

6-5.2        Anti-terrorism Force Protection Systems: Designs shall conform to the DOD Interim Department of Defense Anti-terrorism/ Force Protection Construction Standards. [Design Districts need to indicate the Design Basis Threat here if not classified. If classified, ensure that the offerors will be notified of the minimum requirements.]

## **CHAPTER 7**

### **THERMAL PERFORMANCE**

7-1 **THERMAL CHARACTERISTICS.** Building construction shall conform to the current version of ASHRAE 90.1. All buildings shall be classified as non-residential. R and U values shall be calculated in accordance with ASHRAE methods.

#### 7-2 **THERMAL INSULATION.**

7-2.1 Characteristics. Thermal insulation shall have a flame-spread rating of 25 or less and a smoke-development rating of 50 or less, exclusive of the vapor barrier, when tested in accordance with ASTM E84. A vapor barrier shall be provided on the warm-in-winter side of exterior wall and ceiling insulation, except in humid areas as defined below. Polyurethane is allowed as an insulation material for slabs and outside concrete or unit masonry walls. It is prohibited as an injected insulation material in walls or floor cavities or within the building envelope.

7-3 Humid area design. [Climates which have 3000 hours or more of 19.4 degrees C [67 degrees F] or higher wet bulb temperature in combination with an outside design condition of 50 percent or higher relative humidity, or climates which have 1500 hours or more of 22.8 degrees C [73 degrees F] or higher wet bulb temperature in combination with an outside design condition of 50 percent or higher relative humidity shall be considered humid areas. . In other areas that do not meet the strict definitions of a humid area but experience humid conditions on numerous occasions, these same criteria shall be used by the designer as appropriate for the facility and the climate]. An effective infiltration barrier is critical to limiting moisture flow into occupied spaces. In humid areas, interior surfaces of ceilings and exterior walls shall be covered with materials which allow escape of water vapor from inside the walls into the conditioned space to prevent the growth of mold on interior surfaces. The vapor barrier in humid areas shall have a maximum perm rating of 0.5, and shall be located on the outside face of the exterior wall or ceiling insulation.

7-4 **INFILTRATION.** To limit air infiltration (especially in humid areas), buildings will be sealed with an air infiltration barrier, installed in accordance with the manufacturer's recommendations. The building envelope shall be caulked, gasketed, weatherstripped or otherwise sealed: around window and door frames, between wall cavities and frames, between walls and ceiling and roof, between walls and floors, at access doors and panels, at utility penetrations through walls, floors, and roofs, and at any other exterior envelope joint which may be a source of air leakage. These steps shall constitute tight building construction.

## **CHAPTER 8**

### **PLUMBING**

8-1 **DESIGN STANDARDS AND CODES.** Plumbing system shall be designed and installed in accordance with the latest edition of the International Plumbing Code (IPC). Inspection and testing of the plumbing system shall be performed as prescribed in the International Plumbing Code. Specified materials and equipment shall be standard products of a manufacturer regularly engaged in the manufacturer of such products. Specified equipment shall essentially duplicate equipment that has performed satisfactorily at least two years prior to bid opening.

8-1.1 Additional consideration in the technical evaluation will be given to systems which incorporate measures beyond the requirements of this STATEMENT OF WORK which are designed to increase energy conservation, ease of maintenance, or occupant comfort (such as water filtration and purification), higher efficiency water heating systems, higher grade plumbing fixture materials (such as enameled cast iron tubs as opposed to enameled steel or plastic), etc.

8-1.2 System design and installation must conform to the following mandatory energy and water conservation criteria: ASHRAE Standard 90.1-2001.

### 8-2 **DESIGN CALCULATIONS.**

8-2.1 Hot water heater calculations. Design shall be based on the methods described in the American Society of Plumbing Engineers (ASPE) Volume I, Fundamentals of Plumbing Design. Submit calculations for determining storage capacity and recovery rate. Hot water delivered to toilet facilities shall not exceed 38 C [100 F]; hot water delivered to showers shall not exceed 44 C [110 F].

8-2.2 Piping. Design shall be based on the International Plumbing Code for domestic water, sanitary waste and vent piping. All water piping shall be sized in accordance with methods outlined in the International Plumbing Code, to limit water velocity in the pipe to 2440 mm/sec [8 ft/sec] unless a lower velocity is recommended by the plumbing fixture manufacturer(s). An isometric diagram of the water system shall be included in the design submittal. An isometric diagram of the sanitary sewer system shall be included in the design submittal.

### 8-3 **EQUIPMENT.**

8-3.1 Water heaters shall have round, glass lined tanks, and shall be installed with an integral insulating wrap with a minimum R value of 5. Access shall be provided in the wrap for service and maintenance openings. Storage water heaters that are not equipped with integral heat traps and having vertical pipe risers shall be installed with heat traps directly on both the inlet and outlet. Circulating systems need not have heat traps installed. The water heater relief drain shall be manufacturer approved, and shall be indirectly connected to the building sanitary sewer system. Water heaters shall be sized in accordance with paragraph 8-2.1 for a 32 degrees C [90 degrees F] rise. Minimum water heater efficiencies shall be in accordance with DOE Buying Energy Efficient Product Recommendations (refer to [www.eren.doe.gov/femp/procurement](http://www.eren.doe.gov/femp/procurement)) and shall be Energy Star or with efficiencies in the upper 25% of what is available. Additional consideration in the technical evaluation will be given to designs which include water heaters which exceed the minimum energy efficiency

requirements and which utilize high efficiency, power vented, or sealed combustion water heaters. [Preparer of RFP shall clearly indicate which equipment applies when multiple building types are involved.]

8-3.1.1 Gas fired water heater. Gas fired water heaters shall be in accordance with ANSI Z21.10.1, Water Heaters, Gas, Volume I, Storage Type, 22 kW [75,000 BTUH] Input or less, and shall be sealed combustion high efficiency type. Units shall be UL listed.

8-3.1.2 Electric water heater. Electric water heaters shall comply with UL 174, Water Heaters, Household Electric Storage Tank Type. Units shall be UL listed.

8-3.1.3 Oil fired water heater. Oil fired water heaters shall be in accordance with UL 732. Units shall be UL listed.

8-3.1 Pumps. Recirculating pumps shall be inline type and shall be provided whenever hot water piping extends further than 50 feet from a tank.

8-4 **FIXTURES.** The following fixtures will be acceptable for the facilities on this project except where noted otherwise for specific buildings. Provide handicap accessible type as required by Uniform Federal Accessibility Standards (accessible fixtures are not required in UEPH living units). Fixtures shall be water conservation type, in accordance with the International Plumbing Code. Fixtures shall be provided complete with fittings, and chromium- or nickel-plated brass (polished bright or satin surface) trim. All fixtures, fittings, and trim in a project shall be from the same manufacturer and shall have the same finish.

8-4.1 Vitreous china plumbing fixtures shall conform to ANSI A112.19.2, Vitreous China Plumbing Fixtures. Stainless steel fixtures shall be in accordance with ANSI A112.19.3, Stainless Steel Plumbing Fixtures (residential design). Plastic fixtures shall conform to ANSI Z124. Enameled cast iron plumbing fixtures shall comply with ANSI A112.19.1, and enameled steel fixtures shall comply with ANSI A112.19.4.

8-4.2 Exposed traps shall be chromium-plated, adjustable-bent tube, 20-gauge brass. Concealed traps may be plastic (ABS).

8-4.3 Faucets shall be single-control type, with seals and seats combined in one replaceable cartridge designed to be interchangeable among lavatories, bathtubs and kitchen sinks, or having replaceable seals and seats removable either as a seat insert or as a part of a replaceable valve unit. Water flow shall be no more than .158 L/s [2.5 gpm] from any faucet.

8-4.4 Shower and bath combination shall be controlled by a diverter valve. Baths and shower and bath combinations shall be provided with waste fitting pop-up, concealed with all parts removable and renewable through the overflow and outlet openings in the tub. Showers and shower and bath combinations shall be equipped with a combination valve and flow control device to limit the flow to 0.158 L/s [2.5 gpm] at pressures between 137.9 to 413.7 kPa [20 and 60 psi].

8-4.5 Piping shall be concealed. Individual shutoff or stop valves shall be provided on water supply lines to all plumbing fixtures except bathtubs and showers. Shutoff valves shall be provided for each bathroom group. In multi-story units, additional consideration shall be given in the technical evaluation to designs which provide separate shutoff valves for each floor.

8-4.6 Water closets. Water closets shall have regular bowl with inclined tank, close coupled siphon jet, floor outlet with wax gasket, closed-front seat and cover, and an anti-siphon float valve. Water consumption shall be no more than 6 L [1.6 gal] per complete flushing cycle. Water closet trim shall conform to ANSI A112.19.5, Trim for Water-Closet Bowls, Tanks, and Urinals (Dimensional Standards). Shall be tank type for floor or wall mounted, water saver type and shall meet the requirements of the code.

8-4.7 Urinals. [Shall be flush valve, wall mounted type and shall meet the requirements of the code.] [Urinals shall be wall mounted, waterless type and shall meet the requirements of the code.]

8-4.8 Lavatories. Lavatories shall be rectangular counter top type, minimum 508 by 457 mm [20 by 18 inches] in size or oval minimum 480 by 410 mm [19 by 16 inches] in size. Lavatories shall be vitreous china, cast iron rimless type (without rings), or cross-link acrylic molded counter top with integral bowl. Lavatories shall have pop-up drains. Shall meet the requirements of the code.

8-4.9 Bathtubs. Bathtubs shall be slip resistant and shall be constructed of enameled cast iron, porcelain enameled formed steel, or gel-coated, glass fiber reinforced polyester resin with wainscot. Metal bathtubs shall have fiberglass, porcelain-on-steel panels, or ceramic tile wainscot. Shall meet the requirements of the code.

8-4.10 Showers. Shower stalls shall be of ceramic tile, floor to ceiling, over membrane waterproofing on a cementitious substrate; or gel-coated, glass-fiber reinforced polyester. Shower receptors shall be slip resistant cast stone or gel-coated, glass-fiber-reinforced polyester. Shower stall wainscots shall be ceramic tile or gel-coated, glass-fiber-reinforced polyester. Shall be fiberglass enclosure type.

8-4.11 Kitchen sinks. Kitchen sinks shall be Type 302 stainless steel, 20-gauge minimum, seamless drawn, and sound deadened. Sinks shall be single bowl, self-mounting without mounting rings, complete with cup strainer and plug. Food waste disposers, where provided, shall be in accordance with UL 430 and ASSE 1008, and shall have a minimum motor size of 370 watts [ $\frac{1}{2}$  horse power]. Strainer and plug shall be eliminated where food waste disposers are provided. Shall meet the requirements of the code.

8-4.12 Service sinks. Shall meet the requirements of the code.

8-4.13 Electric water coolers. Units shall be electric refrigerated type and shall conform to the requirements of ARI 1010 and the Lead Contamination Control Act of 1988.

8-5 **PIPING SYSTEMS.** Piping shall be concealed. Individual shutoff or stop valves shall be provided on water supply lines to all plumbing fixtures except bathtubs and showers. Shutoff valves shall be provided for each bathroom group. In multi-story units, additional consideration shall be given in the technical evaluation to designs which provide separate shutoff valves for each floor or as required to facilitate servicing in the interest of minimizing down time and interruption of service. Provide cathodic protection and pipe joint bonding systems as required.

8-5.1 Gas. The design and installation of natural gas distribution systems and equipment shall be in conformance with manufacturer's recommendations and applicable sections of ASME B31.8 and AGA-01. The installation of interior natural gas distribution systems shall be in conformance with the provisions of NFPA 54 and AGA-01. The use of semi-rigid tubing and

flexible connectors for gas equipment and appliances is prohibited, except that the final connections to the kitchen ranges shall be made using flexible connectors conforming to ANSI Z21.45, Flexible Connectors of Other Than All Metal Construction for Gas Appliances, not less than 1000 mm [40 inches] long. Provide accessible gas shutoff valve and coupling for each gas equipment item. Comply with UBC or model code seismic requirements. Exposed horizontal piping shall not be installed farther than 150 mm [6 inches] from the nearest parallel wall in laundry areas or areas where clothes hanging could be attempted.

8-5.2 Domestic water piping. Piping and fittings shall be copper tubing or chlorinated polyvinyl chloride (CPVC) plastic pipe. Valves shall be provided at each fixture and piece of equipment, at each toilet and kitchen, and on takeoffs from risers to each floor. Under slab supply piping shall be limited to service entrance only.

8-5.2.1 Copper tubing. Water piping under concrete slabs shall be copper tubing, type K, annealed. Joints under the slabs are prohibited. If copper tubing is selected for interior water piping, it shall be type K, L, or M hard-drawn copper. Type M copper tubing shall not be installed in exposed areas where the tubing may be exposed to external damage. Additional consideration in the technical evaluation shall be given to designs using copper types K or L. Fittings for soft copper tubing shall conform to ANSI B16.26, Cast Copper Alloy Fittings for Flared Copper Tubes, and for hard-drawn to ANSI B16.22, Wrought Copper and Copper alloy Solder Joint Pressure Fittings.

8-5.2.2 Chlorinated Polyvinyl Chloride (CPVC) Plastic Pipe. [Determine the acceptability of CPVC and edit text as required.] If plastic pipe is selected for interior water piping, it shall be Chlorinated Polyvinyl Chloride (CPVC) plastic pipe, conforming to ASTM D-2846, Standard Specification for Chlorinated Poly(Vinyl Chloride) (CPVC) Hot- and Cold-Water Distribution Systems. CPVC thicknesses shall meet Standard Design Ratio 11 for sizes 13-mm [ $\frac{1}{2}$ -inch] to 51 mm [2 inches] and shall be schedule 80 pipe for sizes larger than 51 mm [2 inches].

8-5.2.3 Soil, waste, vent, and drain. Piping and fittings shall be cast iron, copper or polyvinyl chloride (PVC) plastic pipe. Cleanouts shall be provided as required by the code.

## 8-6 MISCELLANEOUS ITEMS.

8-6.1 Cleanouts. Cleanouts shall be provided at each change in direction of sanitary sewer lines, at the intervals specified in the National Standard Plumbing Code, and at the building service entrance. All cleanouts shall be permanently accessible. Ground cleanouts shall be installed in a 305-mm by 305-mm [12-inch by 12-inch] concrete pad, flush with grade. Wall and floor types shall be provided as required by the code. Provide access panels or cover plates in exposed areas.

8-6.2 Hose bibbs. Hose bibbs shall be provided at the front and rear of each building, for each ground level housing unit. Hose bibbs shall be frostproof, and shall be supplied with an integral vacuum breaker. Provide as required by the code.

8-6.3 Wall hydrants. Provide every 150 feet along the perimeter of the building.

8-6.4 Backflow preventers. Provide as required by the code.

8-6.5 Washer wall boxes. Clothes Washer Connections at each washer location. Drainage and hot and cold water supply shall be provided for automatic clothes washers. Washer

connection, complete with 50-mm [2-inch] drain, 20-mm [3/4-inch] hose thread supplies shall be provided in standard manufactured recessed wall box with single-face plate. Boxes shall be constructed of plastic or sheet steel. Steel boxes shall have a corrosion-resistant epoxy enamel finish. Boxes shall be mounted a minimum of 865 mm [2 ft-10 inches] above the finish floor. Electrical outlets for both washer and dryer shall also be provided.

8-7 **PIPE INSULATION.** Insulation type shall be fiberglass, closed cell foam, or phenolic foam.

8-7.1 Domestic service hot water piping. Minimum pipe insulation performance shall be in accordance with the requirements of the latest edition of ASHRAE/IESNA 09.1.

8-7.2 Domestic service cold water piping shall be insulated with a minimum of 13-mm [1/2-inch] insulation with vapor jacket

8-7.3 Roof drain piping. Provide 25-mm [1-inch] thickness insulation on all horizontal piping.

## **CHAPTER 9**

### **ELECTRICAL SYSTEMS**

9-1 **DESIGN STANDARDS AND CODES.** The electrical design for all facilities shall be in accordance with the current version of the National Electrical Code.

9-1.1 **Facility Energy Conservation Requirements.** The entire facility design, including siting, building envelope, plumbing systems, lighting, electrical systems, and HVAC systems form a complete assembly/structure which is in compliance with ASHRAE 90.1-2001.

9-2 **DESIGN CALCULATIONS.** Provide calculations for the following:

9-2.1 Interior lighting. Provide calculations for each room or area.

9-2.2 Exterior lighting. Provide calculations for all site lighting to include parking areas, walkways, roadways and security.

9-2.3 Load Analysis for each building to include connected and estimated demand. Separate loads by categories such as lighting, receptacles, HVAC, special equipment, etc.

9-2.4 Fault – short circuit calculations for electrical system(s).

9-2.5 Voltage drop – Provide calculations to verify voltage drops. Do not exceed limits as given in the National Electric code (NEC).

9-2.6 Coordination – provide data to verify proper protection and coordination is provided for the equipment/system(s).

9-3 **MATERIALS AND EQUIPMENT.** All materials and equipment shall be the standard catalogued products of manufacturers regularly engaged in the production of such equipment and material, and shall be the manufacturer's latest design. All equipment and material shall conform to the requirements of American National Standards Institute (ANSI), American Society of Testing and Materials (ASTM), National Electrical Manufacturer's Association (NEMA), National Fire Protection Association (NFPA) or other national trade association as applicable. Where standards exist, materials and equipment shall bear the label and be listed by Underwriters Laboratories, Inc. (UL) or other recognized testing organization.

9-3.1 Space requirements. Electrical space shall be provided for all electrical equipment. Space shall provide clearances and working areas as required by codes. Coordinate location to consider factors such as ease of maintenance, vicinity to loads being served and accessibility.

9-3.2 Wiring. Shall be copper and shall be run in conduit. Use solid bare copper wire for sizes No. 8 AWG and smaller diameter, and Class B, stranded bare copper wire for sizes No. 6 AWG and larger diameter.

9-3.3 Motors. Motors shall be high energy efficient type. Motors larger than one-third horse power shall be three phase. Motors one-third horsepower and smaller shall be single phase. Motor starters for mechanical and special equipment will be furnished as an integral part of the mechanical or special systems.

9-3.3.1 Motor Efficiencies. Minimum motor efficiencies shall be either Energy Star or in accordance with DOE Buying Energy Efficient Products Recommendations ( refer to [www.eren.doe.gov/femp/procurement](http://www.eren.doe.gov/femp/procurement) for recommended efficiencies). Applications which require definite purpose, special purpose, special frame, or special mounted polyphase induction motors are excluded from these efficiency requirements. Motors provided as an integral part of motor driven equipment are excluded from this requirement if a minimum seasonal or overall efficiency requirement is indicated for that equipment by the provisions of another section.

9-3.4 Switchboard/panelboard. Dead-front construction, NEMA PB1 and UL 67.

9-4 **LIGHTING.**

9-4.1 Interior. Lighting shall conform to Illumination Engineering Society (IES) recommended levels and in general shall be energy efficient fluorescent with electronic ballast. Lighting in occupied areas shall be color corrected with a Color Rendering Index (CRI) of 85 or better. For energy conservation dual switch, automatic dimming, or occupancy sensors shall be considered. [ Design District may review <http://www.energystar.gov/products/> for additional information.]

9-4.2 Exterior. Site and area lighting shall be high intensity discharge (HID).

9-5 **TELECOMMUNICATIONS.** [Design District shall coordinate all RFP communications requirements with the user, the Installation DOIM and USAISEC-FDEO. Define general requirements by reference to the EIA/TIA standards. Coordinate with DOIM and USAISEC-FDEO to determine if specific project requirements may be included by reference to the "Installation Information Infrastructure Architecture (I3A) Design and Implementation Guide," and add other specific requirements as necessary to fully define the scope of communications requirements prior to issuance of the RFP. If reference is made to the I3A document, include it in the list of references in Appendix A to the SOW.] Cable and jacks shall be Category 5E per EIA/TIA 568A, Commercial Building Telecommunications Cabling Standard. Provide wiring from outlet jack to termination on applicable PATCH-PANEL. Follow requirements of ANSI/TIA/EIA-569-A for telecommunications closets and equipment rooms. [For specialized circuits, such as pay phones, coordinate with the local telephone company. Provide electrical and telephone outlets installed per the Americans with Disabilities Act (ADA) to accommodate TTD's and other devices.] When systems furniture is installed as part of the construction contract, insure that systems furniture specifications include ANSI/TIA/EIA-568-A and ANSI/TIA/EIA-569-A cabling and raceway standards. Use fiber optic cable for backbone data service [Unless expanding an existing site where other backbone cable types are required or requested by user. Coordinate with DOIM and USAISEC-FDEO].

9-5.1 Telecommunication outlet locations. [Coordinate with users and list general and specific locations of telephone and data outlets.] In UEPH buildings provide a minimum of one combination telephone/data outlets in each Living/Sleeping room. Coordinate outlet locations with furniture arrangement.

9-6 **SECURITY SYSTEM(S).** [ Design District shall determine requirements for security systems.]

9-7 **SPECIAL SYSTEMS.** [ Design District shall determine requirements for special systems.]

**Project Name**  
**UEPH Complex**

**Project Number**  
**Statement of Work**  
**26 November 2001**

9-8 **CABLE TELEVISION (CATV) SYSTEM.** [Edit if CATV system is not to be included in project, or if master antenna system will be used in lieu of CATV] Refer to the "Installation Information Infrastructure Architecture (I3A) Design and Implementation Guide". Provide TV outlets in the UEPH buildings per guide requirements, except provide minimum of one CATV outlet in each Living/Sleeping room. In COF, Battalion HQ, and Brigade HQ provide CATV outlets in the following locations: [Coordinate with user].

**CHAPTER 10**

**UNIT DESIGN - HEATING, VENTILATING, AND AIR CONDITIONING**

[Delete all references to comfort cooling where air conditioning is not authorized. Delete references to inapplicable systems throughout the following paragraphs.]

10-1 **DESIGN STANDARDS AND CODES.** The HVAC design shall be in accordance with 10 CFR Part 434 and the current version of the International Mechanical Code.

10-1.1 **Facility Energy Conservation Requirements.** The entire facility design, including siting, building envelope, plumbing systems, lighting, electrical systems, and HVAC systems form a complete assembly/structure which is in compliance with ASHRAE 90.1-2001.

10-2 **DESIGN CALCULATIONS.**

10-2.1 Heat loss[ and heat gain] calculations. Heating[ and cooling] loads shall be in accordance with the current edition of the ASHRAE Handbook of Fundamentals. Computer-generated load calculations shall be provided, and shall include complete input and output summaries. Equipment shall be sized to meet the total load determined by computer calculation. Equipment may be oversized to no more than 115 percent of the computer generated load. Design shall be based on weather data from UFC 3-400-02, Engineering Weather Data; from ASHRAE Handbook of Fundamentals; or from other recognized and authoritative sources of weather data. Room air flow requirements shall be computed based on the individual room load. Values for internal cooling loads shall be included in the computerized load calculations in accordance with ASHRAE recommendations. Minimum space heating and ventilation shall be provided in spaces normally unoccupied, such as bulk storage and equipment rooms.

**TABLE 10-1 – WEATHER DATA**

Type of Design /Design Information	Metric	Inch/pound
Heating		
Indoor Design Temperature	21 °C	70 °F
Unoccupied Space Design Temperature	13 °C	55 °F
Outdoor Design Temperature	Note1	Note1
Annual Heating Degree Days	Note1	Note1
Largest Number of Monthly Heating Degree Days	Note1	Note1
Cooling		
Indoor Design Temperature	24 °C	75 °F
Outdoor Design Dry Bulb Temperature	Note1	Note1
Outdoor Design Wet Bulb Temperature	Note1	Note1

Metric data are based on Celsius degree days to a base of 18° C. Inch-pound data are based on degree days Fahrenheit to a base of 65° F.

[Insert weather data for the specific location involved<sup>1</sup>. A table with bin weather data shall also be provided after this table if heat pumps are a selected alternative.]

10-2.1.1 Load design criteria –UEPH Facilities (Barracks): The internal loads shown in Table 10-2 shall be included for each space listed. The degree of activity for all people shall be moderately active office work. Lights shall be included for the actual quantity provided. Any additional equipment furnished under this contract shall also be included in the appropriate space.

**TABLE 10-2 – INTERNAL LOADS**

Space	People	Equipment
Sleeping/Living Room	1	1 PC, 1 TV
Kitchen	0	1 Refrigerator
Bathroom	0	None

10-2.1.2 Load design criteria – Company Operations Facilities. The internal loads shown in Table 10-3 shall be included for each space listed. The degree of activity for all people shall be moderately active office work. Lights shall be included for the actual quantity provided. Any additional equipment furnished under this contract shall also be included in the appropriate space.

**TABLE 10-3 – INTERNAL LOADS**

Space	People	Equipment
Office	1 / 142 sf	1 PC/ person
Conference Room	1 / 20 sf	1 PC
Lobby	1 / 33 sf	1 Coffee Pot
Activities Room	1 / 20 sf	1 PC
Mail Room	1 / 100 sf	None
TV Lounge	1 / 20 sf	1 TV
Kitchen	1 / 100 sf	1 KW
Toilet, Janitor Closet	0	None
Corridor/Balcony/Vending	1 / 300 sf	None
Laundry	0	None

10-2.1.3 Load design criteria – Battalion/Brigade Operations Facilities. The internal loads shown in Table 10-4 shall be included for each space listed. The degree of activity for all people shall be moderately active office work. Lights shall be included for the actual quantity provided. Any additional equipment furnished under this contract shall also be included in the appropriate

space.

**TABLE 10-4 – INTERNAL LOADS**

Space	People	Equipment
Offices	1 / 142 sf	1 PC/person
Conference Room	1 / 20 sf	1 PC
Lobby	1 / 33 sf	Coffee Pot
Classroom	1 / 20 sf	1 PC/person
Toilet, Janitor Closet	0	None
Corridor	1 / 300 sf	None

10-2.2 Ventilation air. Calculations determining minimum outside ventilation air and exhaust shall be provided for each building space. Ventilation rates shall be in accordance with the current edition of the International Mechanical Code. Outside air quantities will be sufficient to meet ventilation requirements and maintain a positive pressure relative to the outdoors in the living/sleeping rooms, interior corridors, offices, conference rooms, lobby and similar occupied areas.

10-2.3 Piping calculations. Calculations shall be provided for pressure drop calculations for all piping systems, including head loss calculations for all pumps.

10-2.4 Duct calculations. Calculations shall be provided for sizing all duct systems, including static pressure drop calculations for all fans. Ductwork layout drawings shall also be provided to indicate all fittings and devices to substantiate calculations.

10-3 **HUMID AREA DESIGN.** [Climates which have 3000 hours or more of 19.4 degrees C [67 degrees F] or higher wet bulb temperature in combination with an outside design condition of 50 percent or higher relative humidity, or climates which have 1500 hours or more of 22.8 degrees C [73 degrees F] or higher wet bulb temperature in combination with an outside design condition of 50 percent or higher relative humidity shall be considered humid areas. In other areas that do not meet the strict definitions of a humid area but experience humid conditions on numerous occasions, these same criteria shall be used by the designer as appropriate for the facility and the climate.] In humid areas, all air heating and cooling systems shall be provided, and economizer cycles will not be allowed. Closet and storage spaces shall have louvered doors, and building return air shall be drawn through these spaces to a ducted return air system. Cooling coils shall have a maximum of 315 fins/m [8 fins/inch] to allow for easy cleaning, and shall be sized for a maximum face velocity of 2.8 m/s [550 fps] to preclude moisture carryover. Heating and cooling equipment in humid areas shall be designed to meet the load determined by computer calculation. However, a larger fan may be required to meet minimum air flow requirements than would be anticipated based on the computer load. Equipment may be oversized by no more than 15 percent of the computer generated sensible load.

10-3.1 Load calculations. The one percent wet bulb temperature, from the approved weather data source of 10-1.2 above, will be used in calculating the latent cooling load and for equipment sizing. In addition to calculating the cooling load at maximum design temperature, cooling load calculations or thermal simulations should also be made at maximum dew point temperatures or for low temperature, high humidity conditions to determine the greatest dehumidification load that may be encountered. Latent heat gain due to water vapor flow through roofs and walls will be included in the cooling load analysis when the ambient design dew point exceeds the room design dew point by more than 11.1 degrees C [20 degrees F].

10-3.2 Chilled water systems. The cooling capacity of 350 kW [100 tons] and over systems will be divided between two or more chillers to ensure reliability and constant chilled water supply without temperature fluctuations, to prevent short cycling, and to minimize hot gas by-pass. The combined capacity of the chillers will not exceed the total requirement, including diversity. The selection of the number of chillers will be based on the analysis of part load operating hours for extended periods of low load conditions.

10-3.3 Packaged units. Packaged unitary units with multiple reciprocating compressors (not to exceed eight) will be used for systems between 123 kW and 750 kW [35 tons to 200 tons]. Each compressor will have separate, independent, refrigerant circuits and cycles to provide multiple steps of capacity control. Two compressors may be combined into one independent refrigerant circuit. For systems up to 123 kW (35 tons), single compressors with a minimum of three-step capacity unloading may be used.

10-3.4 Outside air. Where the outside air requirements are a significant part of the cooling load, the use of desiccant cooling, enthalpy wheels and similar devices for conditioning the outside air and transferring latent and sensible heat to the exhaust air shall be considered. If appropriately sized, these units can eliminate or minimize the latent load in the conditioned space saving significant energy and greatly increasing the comfort level.

10-4 **MECHANICAL SYSTEMS.** Each building shall be provided with a [central] heating [and air conditioning] system[s]. Systems shall be designed, installed, balanced, and adjusted to distribute heat [and cooling] to all habitable rooms, as well as bathrooms, in proportion to the calculated load requirements of these spaces. [The Installation shall determine the allowable

system types and fuel options to be used. Select a system type below or provide a description of other acceptable systems as an additional subparagraph. UEPH buildings shall be limited to individual heat pumps, fan coils, or similar units with individual adjustable thermostat and fan switch in each space (sleeping room, not module). Coordinate unit locations with installation facilities engineering personnel (DPW). Most installations prefer that fan coils and similar units for UEPH modules not be ceiling mounted if located in the living/sleeping room or the service area; floor mounted units or vertical units are often preferred for ease of maintenance and minimization of water damage if condensate drains get plugged. A central preconditioned outside air system, supplying neutral air (at or near room temperature) to each occupied space, shall also be provided for UEPH buildings. All reasonably equivalent fuel options within a range of 10 percent based on life cycle cost analysis shall be allowed. The Design District may assist the Installation in preparation of the fuel life cycle cost comparison.] Additional consideration in the technical evaluation will be given to systems utilizing energy efficient equipment, additional space in the mechanical room, and other features which contribute to ease of system operation and maintenance. Additional consideration will also be given to designs which provide measures to increase energy conservation or occupant comfort such as division of each unit into more than one conditioning zone for increased control.

[Edit the following list as applicable for the particular project. If not acceptable, insert "... (Deleted)" following subparagraph letter and delete remainder of text. If a system type is acceptable for one facility but not for the others, note what exceptions are not allowed after the subparagraph title. If the desired system type is different than what is described, modify the description as required for the particular system desired or provide additional paragraphs as necessary. Preparer of RFP shall get approval from installation for each system used.]

10-4.1 Incremental equipment. [Provide individual thru-wall self-contained air-to air heat pumps for each sleeping room and individual space that is to be conditioned.] [Provide individual thru-wall packaged terminal air conditioning units for each sleeping room and individual space that is to be conditioned.] [Fan coil units with hydronic heating [and cooling] shall be provided for each sleeping room and individual space that is to be conditioned.]

10-4.2 Air distribution systems. Heating [and cooling] will be provided from [rooftop air handling units] [central air handling units] [warm air furnaces] [fan coil units]. [Air handling units shall deliver air to [variable air volume boxes in] [dual duct boxes in] [induction units in] each space.] [Air handling units shall deliver preconditioned ventilation air to [fan coil units] [heat pumps] in each space.] [Designate a maximum area served per individual unit or a maximum unit size.]

10-4.3 Hydronic distribution systems. Provide pumped [condenser water] [hot water] [and] [chilled water] piping system[s] with a standby pump provided for each system pump provided. Chilled water will be provided from [central system] [central equipment indicated]. Hot water will be provided from [central hot water system] [central steam system and convertor] [central equipment indicated]. Condenser water will be from [ground source heat pump system] [central equipment indicated]

10-4.4 Ground source heat pump systems. Provide a ground source heat pump system with water source heat pumps. System design shall be in accordance with IGSHPA standards. Supplemental heating and cooling source shall be as indicated. [Designate a maximum area served per individual unit or maximum unit size.]

10-4.5 Heating only systems. For spaces where heating only is required, provide [unit heaters], [fin tube radiation], [cabinet heaters] or [convectors]. Units shall be [hydronic] [electric]

[gas fired].

10-4.6 Central heating equipment. Provide [gas fired hot water boiler] [oil fired hot water boiler] [dual fuel gas/oil fired hot water boiler]. [Designate if multiple units are required.]

10-4.7 Central cooling equipment. Provide [packaged air cooled chiller] [water cooled chiller with cooling tower] [water cooled chiller with evaporative cooler] for cooling. [Designate if multiple units are required.]

10-4.8 Exhaust systems. Provide [individual ceiling mounted fans for][central building continuous exhaust systems for] toilet exhausts. [Central continuous toilet exhaust is normally preferred for barracks.] Provide [individual ceiling mounted fans for][central building exhaust systems for] general exhaust systems. Provide individual thermostatically controlled exhaust fans for laundries, mechanical/electrical rooms and other spaces where ventilation only is required. [Provide recirculating type exhaust hoods for all residential type ranges and cooking surfaces.] [Provide exhaust hoods individually and directly ducted to the exterior through a wall louver for all residential type ranges and cooking surfaces.]

10-5 **INCREMENTAL EQUIPMENT.** The following equipment will be acceptable for the facilities on this project except where noted otherwise for specific buildings. Minimum equipment efficiencies shall be in accordance with DOE Buying Energy Efficient Products Recommendations ( refer to [www.eren.doe.gov/femp/procurement](http://www.eren.doe.gov/femp/procurement) for recommended efficiencies) or Energy Star.

10-5.1 Packaged air conditioning units. Unit shall be a through-the-wall mounted, heavy-duty commercial grade, factory assembled and precharged air-conditioner [heat pump] unit. Unit shall be in accordance with ARI 310/380 and UL 1995. Units shall be removable from inside the building for servicing without removing the outside cabinet. Louver shall be stormproof type, constructed of anodized, stamped or extruded aluminum. Controls shall include an on-off switch, multiple speed fan mode and an adjustable [cooling and] heating thermostat. Outside air can not be supplied through unit. Function and temperature controls shall be [integral to unit][remote mounted].

10-5.2 Air-to-air heat pump units. Unit shall be a through-the-wall mounted, heavy-duty commercial grade, factory assembled and precharged heat pump unit. Unit shall be in accordance with ARI 310/380 and UL 1995. Units shall be removable from inside the building for servicing without removing the outside cabinet. Louver shall be stormproof type, constructed of anodized, stamped or extruded aluminum. Sleeve shall be a water and airtight [completely insulated] [noninsulated] assembly, with weather-resistant protective coating. Units shall contain a reversing valve to change unit to heating cycle. An outdoor coil temperature sensor shall be provided to guard against coil freeze-up by either switching to supplemental heat only, or by cycling the compressor to defrost the coil. Controls shall include an on-off switch, multiple speed fan mode and an adjustable [cooling and] heating thermostat. Outside air can not be supplied through unit. Function and temperature controls shall be [integral to unit][remote mounted].

10-5.3 Water source heat pumps. Units shall be horizontal or vertical type with easily accessible filters. Controls shall include an on-off switch, multiple speed fan mode and an adjustable [cooling and] heating thermostat.

10-5.4 Evaporative coolers. [Evaporative coolers shall be considered only at installations which traditionally use evaporative cooling, and comfort conditions can be maintained through their use. Determine whether evaporative coolers will be allowed as a design option to the

offeror.] Units shall be self-contained, single stage, weather-resistant type, and shall conform to UL 507 and UL 746C. The fan shall be centrifugal type and shall be complete with motor, drive equipment, and vibration-isolation supports between motor and fan housing on single phase motors. Water distributor or rotary wheel motor shall be provided with a time delay in the fan circuit to allow media to be thoroughly wetted before air flow starts. Manual or automatic reset type thermal overload protection shall be provided. Evaporative cooler fans shall have air delivery ratings based on AMCA 210 tests by an AMCA approved laboratory. An ultraviolet retarding agent shall be part of or applied on exterior nonmetallic components susceptible to ultraviolet degradation from sun rays and conforming to UL 746C. Evaporative media shall be specifically manufactured for use with evaporative coolers. Media shall be honeycombed type, fabricated such that no moisture entrainment shall occur. Face velocities shall be limited to those recommended by media manufacturer. Indirect coolers shall consist of an air-to-air heat exchanger, water distribution header, scavenger fan and motor, recirculating water pump, supplemental cooling coil (as required), drain, overflow and makeup water lines and an accessible damper to allow change-over from heating to cooling. Cooler shall be drainable, and shall be provided with a mounting frame.

10-5.5 Unit heaters. Units shall be horizontal or vertical air discharge types complete with fans, [electric] [hot water] [steam] coils, housing and discharge vanes or diffuser.

10-5.6 Fin tube radiation. Units shall be complete with [electric] [plate fin] heating elements and enclosures. Enclosures shall be constructed of sheet steel not less than 20 gauge.

10-5.7 Cabinet heater. Units shall be complete with fans, heating elements and enclosing cabinets. Heating elements shall be constructed of cast iron or of nonferrous material. Cabinets shall be constructed of sheet steel not less than 20 gauge.

10-5.8 Convectors. Units shall be complete with heating elements and enclosing cabinets having bottom recirculating opening, manual control damper and top supply grille. Heating elements shall be constructed of cast iron or of nonferrous alloys. Cabinets shall be constructed of black sheet steel not less than 20 gauge.

10-6 **AIR DISTRIBUTION TERMINAL UNITS.** Minimum equipment efficiencies shall be in accordance with DOE Buying Energy Efficient Products Recommendations ( refer to [www.eren.doe.gov/femp/procurement](http://www.eren.doe.gov/femp/procurement) for recommended efficiencies) or Energy Star.

10-6.1 Fan coil units. Base units shall include galvanized coil casing, coil assembly drain pan valve and piping package, air filter, fans, motor, fan drive, and motor switch, plus an enclosure for cabinet models and casing for concealed models. Outside air can not be supplied directly through unit. Room fan-coil units shall be certified as complying with ARI 440, and shall meet the requirements of UL 1995. Enclosures shall be fabricated of not lighter than 18 gauge steel, reinforced and braced. Front panels of enclosures shall be removable and provided with 1/2 inch thick dual density fibrous glass insulation. Access doors or removable panels shall be provided for piping and control compartments. Duct discharge collar shall be provided for concealed models. Enclosures shall have easy access for filter replacement. Fans shall be galvanized steel or aluminum, multiblade, centrifugal type. Disassembly and re-assembly shall be by means of mechanical fastening devices and not by epoxies or cements. Coils shall be seamless copper tubing, with copper or aluminum fins mechanically bonded or soldered to the tubes. Drain and drip pans shall be sized and located to collect all water condensed on and dripping from any item within the unit enclosure or casing. Drain pans shall be constructed of not lighter than 21 gauge steel, galvanized after fabrication, thermally insulated to prevent

condensation. Auxiliary drain pans to catch drips from control and piping packages, eliminating insulation of the packages, may be plastic; if metal, the auxiliary pans shall comply with the requirements specified above. Insulation at control and piping connections thereto shall extend 1 inch minimum over the auxiliary drain pan. Filters shall be of the fiberglass disposable type, 1 inch thick. Filters in each unit shall be removable without the use of tools. Motors shall be of the permanent split-capacitor type with built-in thermal overload protection, directly connected to unit fans. Motor switch shall be two or three speeds. In lieu of the above fan speed control, a solid-state variable-speed controller having a minimum speed reduction of 50 percent may be provided. Motors shall have permanently-lubricated or oilable sleeve-type or combination ball and sleeve-type bearings with vibration isolating mountings suitable for continuous duty.

10-6.2 Variable air volume terminal unit. Units shall be pressure independent type. Unit enclosures shall be constructed of galvanized steel not lighter than 22 gauge or aluminum sheet not lighter than 18 gauge. Units shall be internally insulated with factory mounted controls. Unit air volume shall be factory preset and readily field adjustable without special tools. Heating coils shall be provided. Filters shall be provided when air is recirculated. Acoustic performance of the terminal units shall be based upon units tested according to ARI 880. Acoustical lining shall be according to NFPA 90A.

10-6.2.1 Constant volume type. Terminal units shall contain within the casing, a mechanical or pneumatic constant volume regulator. Volume regulators shall control air delivery to within plus or minus 5 percent of specified air flow subjected to inlet pressure from 3/4 to 6 inch water gauge.

10-6.2.2 Variable volume type. Terminal units shall be provided with a calibrated air volume sensing device, air valve or damper, actuator, and accessory relays. Units shall control air volume to within plus or minus 5 percent of each air set point volume as determined by the thermostat with variations in inlet pressures from 3/4 to 6 inch water gauge. Internal resistance of units shall not exceed 0.4 inch water gauge at maximum flow range. External differential pressure taps separate from the control pressure taps shall be provided for air flow measurement with a 0 to 1 inch water gauge range. Unit volume controller shall be normally [open] [closed] upon loss of pneumatic pressure.

10-6.2.3 Fan-powered type. Terminal units shall be provided with a calibrated air volume sensing device, air valve or damper, actuator, fan and motor, and accessory relays. Units shall control primary air volume to within plus or minus 5 percent of each air set point as determined by the thermostat with variations in inlet pressure from 3/4 to 6 inch water gauge. Unit fan shall be centrifugal, direct-driven, double-inlet type with forward curved blades. Fan motor shall be either single speed with speed controller or three-speed, permanently lubricated, permanent split-capacitor type. Fan/motor assembly shall be isolated from the casing to minimize vibration transmission. Fan control shall be factory furnished and wired into the unit control system. A factory-mounted pressure switch shall be furnished to operate the unit fan whenever pressure exists at the unit primary air inlet or when the control system fan operates.

10-6.3 Dual duct terminal unit. Unit enclosures shall be constructed of galvanized steel not lighter than 22 gauge or aluminum sheet not lighter than 18 gauge. Units shall be internally insulated with factory mounted controls. Units shall be provided with hot and cold inlet valve or dampers. Dampers shall be controlled in unison by single or dual actuators. Unit shall control delivered air volumes within plus or minus 5 percent with inlet air variations from 1 to 8 inch water gauge in either duct. Mixing baffles shall be included with the unit casing. Cabinet and

closed duct leakage shall not exceed 2 percent of maximum rated air volume. Unit air volume shall be factory preset and readily field adjustable without special tools. Acoustic performance of the terminal units shall be based upon units tested according to ARI 880. Acoustical lining shall be according to NFPA 90A.

10-6.4 Unit ventilators. Unit ventilators shall be of the year-round classroom type with automatic controls arranged to properly heat, cool, and ventilate the room. Automatic valves and controls shall be provided. Enclosures shall be fabricated of not lighter than 16 gauge galvanized steel, reinforced and braced, or all welded framework with panels to provide equivalent strength. The casing shall be acoustically and thermally insulated internally with not less than 1/2 inch thick dual density fibrous glass insulation. Removable panels or access doors shall be provided for all piping and control compartments. Gaskets shall be provided at the back and bottom of the unit for effective air seal, as required. Fans shall be of galvanized steel or aluminum, multiblade, centrifugal type, direct connected, dynamically and statically balanced. Drain and drip pans shall be sized and located to collect all condensed water dripping from any item within the unit enclosure. An outside air proportioning damper shall be provided on each unit. In addition, a vane shall be provided to prevent excessive outside air from entering unit and to prevent blow-through of outside air through the return air grille under high wind pressures. Where outside air and recirculated air proportioning dampers are provided on the unit, an additional vane will not be required. Face and bypass dampers shall be provided for each unit to ensure constant air volume at all positions of the dampers. Each unit shall be provided with a factory installed control cam assembly, pneumatic motor, or electric motor to operate the face and bypass dampers and outside air damper or outside air and recirculated air dampers. Motors shall be of the permanent split-capacitor type with built-in thermal overload protection and automatic reset. Motor shall be mounted on a resilient mounting, isolated from the casing and shall be suitable for operation on electric service available. A manually operated motor switch shall provide for 2 or 3 speeds. In lieu of speed control, a solid state variable speed controller having minimum speed reduction of 50 percent may be provided. Outside air intakes shall be the manufacturer's standard design and provided with 12 mm [1/2 inch] mesh bird screen or louvers on 12 mm [1/2 inch] centers.

10-6.5 Induction units. Unit shall include air plenums, air-discharge nozzles, air discharge grilles, recirculation grilles, water coil assembly, valve and piping package, condensate drain pan, filters and adjustable air-balancing dampers, plus an enclosure for cabinet models and casing for concealed models. Automatic valves and controls shall be provided. Each unit shall be secured to the building structure. The induction units shall conform to the provisions of ARI 445. Enclosures shall be fabricated of not lighter than 18 gauge steel, reinforced and braced. Front panel of enclosure shall be removable and insulated when required acoustically and to prevent condensation. Plastic discharge and return grilles are not acceptable. Access doors shall be provided for all piping and control compartments. An adjustable air-balancing damper shall be provided in each unit. Drain and drip pans shall be sized and located to collect condensed water dripping from any item within the unit enclosure. Drain pans shall be constructed of not lighter than 21 gauge steel, galvanized after fabrication, and thermally insulated to prevent condensation.

10-6.6 Exhaust fans. Fans shall be centrifugal [or propellar] type, roof or wall mounted, direct or V-belt driven with backward inclined, non-overloading wheel. Motor compartment housing shall be hinged or removable and weatherproof, constructed of heavy gauge aluminum. Fans shall be provided with birdscreen, disconnect switch, gravity or motorized dampers. Roof mounted units shall be provided with roof curb. Lubricated bearings shall be provided. Fans shall be tested and rated according to AMCA 210. [Grease-laden kitchen exhaust fans shall be

centrifugal type according to UL 705 and fitted with V-belt drive, round hood, and windband upblast discharge configuration, integral residue trough and collection device, motor and power transmission components located in outside positively air ventilated compartment.]

10-6.7 In-line fans. Fans shall have centrifugal, backward inclined blades, stationary discharge conversion vanes, internal and external belt guards, and adjustable motor mounts. Fans shall be mounted in a welded tubular casing. Air shall enter and leave the fan axially. Inlets shall be streamlined with conversion vanes to eliminate turbulence and provide smooth discharge air flow. Fan bearings and drive shafts shall be enclosed and isolated from the air stream. Fan bearings shall be sealed against dust and dirt and shall be permanently lubricated, and shall be precision self aligning ball or roller type. Fans shall be tested and rated according to AMCA 210.

10-6.8 Ceiling exhaust fans. Suspended cabinet-type ceiling exhaust fans shall be centrifugal type, direct-driven. Fans shall have acoustically insulated housing. Integral backdraft damper shall be chatter-proof. The integral face grille shall be of egg-crate design or louver design. Fan motors shall be mounted on vibration isolators. Unit shall be provided with mounting flange for hanging unit from above. Fans shall be U.L. listed.

10-6.9 Range hoods. Kitchen range exhaust fans shall be two-speed, and shall be sized for an exhaust rate of 7.6 (L/s)/m<sup>2</sup> [1.5 cfm/ ft<sup>2</sup> ]. Maximum allowable noise level shall be 6 sones as installed.

10-6.10 Dryer Vents. A 100 mm [4-inch] diameter dryer vent shall individually and directly discharge to the exterior. The vents shall be rigid aluminum with exterior wall cap and backdraft damper. Vent pipes shall be a maximum of 6100 mm [20 ft] long, with no more than three right angle elbows (with minimum radius of 150 mm [6 inches]), and have a maximum vertical run of 3660 mm [12 ft]. Means shall be provided for cleaning entire length of dryer vents. Dryer vents shall not exhaust near air conditioning condensing units, entry doors, patio or balconies. Dryer vents shall not run through non-accessible spaces.

10-7 **AIR DISTRIBUTION CENTRAL EQUIPMENT.** Minimum equipment efficiencies shall be in accordance with DOE Buying Energy Efficient Products Recommendations ( refer to [www.eren.doe.gov/femp/procurement](http://www.eren.doe.gov/femp/procurement) for recommended efficiencies) or Energy Star.

10-7.1 Air handling units. Units shall include fans, coils, airtight insulated casing, adjustable V-belt drives, belt guards for externally mounted motors, access sections for maintenance, combination sectional filter-mixing box, vibration-isolators, and appurtenances required for required operation. Air handling unit shall have published ratings based on tests performed according to ARI 430. All sections shall be constructed of a minimum 18 gauge galvanized steel, or 18 gauge steel outer casing protected with a corrosion resistant paint finish. Casing shall be designed and constructed with an integral structural steel frame such that exterior panels are non-load bearing. Casings shall be provided with inspection doors, access sections, and access doors. Inspection and access doors shall be insulated, fully gasketed, double-wall type, of a minimum 18 gauge outer and 20 gauge inner panels. Drain pans shall be constructed water tight, treated to prevent corrosion, and designed for positive condensate drainage. Coils shall be fin-and-tube type constructed of seamless [copper] [red brass] tubes and [aluminum] [or] [copper] fins mechanically bonded or soldered to the tubes. Coils shall be rated and certified according to ARI 410. Filters shall be listed according to requirements of UL 900. Filters shall be 50 mm [2] inch depth, sectional, disposable type of the size indicated and shall have an average efficiency of 25 to 30 percent when tested according to ASHRAE 52.1. Filters shall be UL Class

2. Fans shall be double-inlet, centrifugal type with each fan in a separate scroll. Fan bearings shall be sealed against dust and dirt and shall be precision self-aligning ball or roller type. Bearing life shall be L50 rated at not less than 200,000 hours as defined by AFBMA Std 9 and AFBMA Std 11. Bearings shall be permanently lubricated or lubricated type with lubrication fittings readily accessible at the drive side of the unit.

10-7.2 Rooftop air handling units shall not be used.

10-7.3 Warm air furnaces. Furnace shall be a manufacturer's standard, self-contained, forced circulated air heating type furnace. Furnace and furnace components shall be completely factory-assembled and wired. Furnace casing shall be factory insulated and be compatible with the operating temperatures. Furnace shall be provided with removable service panels which allow access to all internal components requiring cleaning, servicing, or adjustment.

10-7.3.1 Gas-fired furnace. Shall be the [conventional] [high efficiency, condensing] type in accordance with **ANSI Z21.47**. Furnace design shall be certified by the AMERICAN GAS ASSOCIATION LABORATORIES (AGA). Gas-burning equipment shall include the gas burners, ignition equipment, gas-control valve, gas piping, gas-pressure regulating valve, when applicable, and accessories necessary for a fully automatic system that is listed in **IAS Directory**. Gas-fired units equipped with programming controls shall be furnished both with high and with low gas supply pressure switches in the fuel supply piping. Ignition systems shall be of the direct spark, hot surface, or interrupted intermittent type with automatic electric ignition. The pilots shall be of the electrically-ignited proven type. Continuous pilots will not be permitted. Burner shall be designed in accordance with **NFPA 54** and located so that parts are protected against overheating. Provisions shall be made in the burner housing for inspection of the pilot flame. Vent piping shall be in accordance with **UL 441**, [Type B] [Type BW]. Vent shall conform to **NFPA 211** and **NFPA 54**. Plastic materials polyetherimide (PEI) and polyethersulfone (PES) are forbidden to be used for vent piping of combustion gases. [Direct venting shall be used for high efficiency, condensing type furnaces. Both the air intake and exhaust vents shall be sized and located as recommended by the furnace manufacturer. A separate combustion air intake vent and exhaust shall be provided for each furnace. The combustion air intake piping shall be constructed of Schedule 40 PVC in accordance with **ASTM D 1784**. The exhaust vent piping shall be constructed of Schedule 40 CPVC or stainless steel in accordance with **UL 1738** and the furnace manufacturer's recommendations.]

10-7.3.2 Oil-fired furnace. Shall be in accordance with **UL**. The equipment shall include the oil burner motor, ignition equipment safety devices, and accessories necessary for a full automatic system that conforms to UL 296. Oil-fired units equipped with programming controls shall be furnished with low oil-pressure switches in the fuel supply piping. Oil-fired units not equipped with programming controls shall be equipped with a delayed opening or shutoff valve. The valve shall automatically delay delivery of oil to the burner until such time as the combustion air fan and, when applicable, the induced draft fan are operated at rated speed. Ignition systems shall be of the [direct-electrical spark type] [direct-electric spark type or interrupted type] in accordance with UL 296. Vent piping shall be in accordance with UL 641, Type L. Vent shall conform to NFPA 211. Plastic materials polyetherimide (PEI) and polyethersulfone (PES) are forbidden to be used for vent piping of combustion gases.

10-8 **CENTRAL HEATING EQUIPMENT.** Minimum equipment efficiencies shall be in accordance with DOE Buying Energy Efficient Products Recommendations ( refer to [www.eren.doe.gov/femp/procurement](http://www.eren.doe.gov/femp/procurement) for recommended efficiencies) or Energy Star.

10-8.1 Hot water boilers, gas fired. Boilers shall be gas fired and shall be designed, constructed and equipped in accordance with the ASME Boiler Pressure Vessel Code, Section IV, Heating Boilers. Each boiler shall be of the [firtube] [watertube] [cast iron] [condensing] type. The boiler capacity shall be based on the ratings shown in HYI-01 or as certified by the American Boiler Manufacturers Association, or American Gas Association. Boiler shall be designed to burn [gas] [oil] [combination gas and oil]. Each boiler shall comply with Federal, state, and local emission regulations. Burners shall be UL approved [mechanical draft burners with all air necessary for combustion supplied by a blower where the operation is coordinated with the burner] [natural draft/atmospheric burners]. Burners shall be provided complete with fuel supply system in conformance with UL 795, ANSI Z21.13 or NFPA 8501.

10-8.2 Hot water boilers, oil fired. Boilers shall be gas fired and shall be designed, constructed and equipped in accordance with the ASME Boiler Pressure Vessel Code, Section IV, Heating Boilers. Each boiler shall be of the [firtube] [watertube] [cast iron] type. The boiler capacity shall be based on the ratings shown in HYI-01 or as certified by the American Boiler Manufacturers Association. Boiler shall be designed to burn [gas] [oil] [combination gas and oil]. Each boiler shall comply with Federal, state, and local emission regulations. Oil-fired burners and controls for oil-fired units firing No. 2 oil shall be atomizing, forced-draft type in conformance with UL 726.

10-8.3 Hot water boilers, dual fuel fired. Boilers shall be gas fired and oil fired. Boilers shall be designed, constructed and equipped in accordance with the ASME Boiler Pressure Vessel Code, Section IV, Heating Boilers. Each boiler shall be of the [firtube] [watertube] [cast iron] type. The boiler capacity shall be based on the ratings shown in HYI-01 or as certified by the American Boiler Manufacturers Association, or American Gas Association. Boiler shall be designed to burn gas and oil. Each boiler shall comply with Federal, state, and local emission regulations. Combination gas and oil-fired units shall conform to UL 296. Burner shall be provided complete with fuel supply system in conformance with ASME CSD-1 or NFPA 8501.

10-8.4 Steam converter. Exchangers shall operate with steam in shell and low temperature water in tubes. Shell and tube sides shall be designed for 150 psig working pressure and factory tested at 300 psig. Steam, water, condensate, and vacuum and pressure relief valve connections shall be located in accordance with the manufacturer's standard practice. Tubes shall be seamless copper or copper alloy, constructed in accordance with ASTM B 75 or ASTM B 395, ASTM B 395M, suitable for the temperatures and pressures specified.

10-9 **CENTRAL COOLING EQUIPMENT.** Minimum equipment efficiencies shall be Energy Star or in accordance with the following minimum efficiencies:

Minimum Efficiencies for Air-Cooled Chillers

Full Load COP (EER)	IPLV COP (kW/ton)
------------------------	----------------------

Air-Cooled (with Condenser):

**Project Name**  
**UEPH Complex**

**Project Number**  
**Statement of Work**  
**26 November 2001**

527 kW (150 tons) or less	2.8 (9.5)	3.1 (1.12)
greater than 527 kW (150 tons)	2.7 (9.2)	2.9 (1.22)
Air-Cooled (Condenserless): All Capacities	3.1 (10.6)	3.2 (1.10)

Minimum Efficiencies for Water-Cooled Chillers

Capacity	Full Load		IPLV	
	COP	(EER)	COP	(kW/ton)
281 kW (80 tons) or less	3.9	(13.3)	4.7	(0.75)
greater than 281 kw (80 tons) or less than or equal to 351 kw (100 tons)	3.9	(13.3)	5.1	(0.70)
greater than 351 kw (100 tons) or less than or equal to 702 kw (200 tons)	4.7	(16.0)	5.4	(0.65)
greater than 702 kw (200 tons) or less than or equal to 1757 kw (500 tons)	5.7	(19.4)	6.1	(0.58)
greater than 1757 kw (500 tons)	5.9	(20.0)	6.3	(0.56)

10-9.1 Packaged air cooled liquid chillers. Units shall be assembled, leak-tested, charged (refrigerant and oil), and adjusted at the factory. Chiller shall be provided with factory installed insulation on surfaces subject to sweating including the liquid cooler, suction line piping, economizer, and cooling lines. Chiller shall include all customary auxiliaries deemed necessary by the manufacturer for safe, controlled, automatic operation of the equipment. Chiller shall be provided with a single point wiring connection for incoming power supply. Factory installed insulation shall be provided on all suction piping from the evaporator to the compressor and on the liquid cooler shell. Where motors are the gas-cooled type, factory installed insulation shall be provided on the cold-gas inlet connection to the motor per manufacturer's standard practice. Compressors shall be scroll, reciprocating, rotary screw or centrifugal type. Scroll and reciprocating chillers shall be constructed and rated in accordance with ARI 590. Rotary screw chillers shall be constructed and rated in accordance with ARI 550 or ARI 590 as applicable. Centrifugal chillers shall be constructed and rated in accordance with ARI 550. Chiller shall conform to ASHRAE 15. Refrigerants shall be one of the fluorocarbon gases. Refrigerants shall have number designations and safety classifications in accordance with ASHRAE 34. Refrigerants shall meet the requirements of ARI 700 as a minimum. Refrigerants shall have an Ozone Depletion Potential (ODP) of less than or equal to 0.05. Chiller shall be provided with a complete factory mounted and prewired [electric] [microprocessor based control system]. Controls package shall contain as a minimum a digital display or acceptable gauges, an on-auto-off switch, motor starters, power wiring, control wiring, and disconnect switches. Controls package shall provide operating controls, monitoring capabilities, programmable setpoints, safety controls, and EMCS interfaces.

10-9.2 Water cooled liquid chillers. Total chiller system shall be constructed and rated in accordance with ARI 590. Individual chiller components shall be constructed and rated in accordance with the applicable ARI standards. Chiller shall be assembled, leak-tested, charged (refrigerant and oil), and adjusted at the job site by a factory representative. Unit components delivered separately shall be sealed and charged with a nitrogen holding charge. Unit assembly shall be completed in strict accordance with manufacturer's recommendations. Chiller shall operate within capacity range and speed recommended by the manufacturer. Parts weighing 50 pounds or more which must be removed for inspection, cleaning, or repair, shall have lifting eyes or lugs. Chiller components (excluding field installed refrigerant piping) shall be provided with factory installed insulation on surfaces subject to sweating. Chiller shall include all customary auxiliaries deemed necessary by the manufacturer for safe, controlled, automatic operation of the equipment. Refrigerants shall be one of the fluorocarbon gases. Refrigerants shall have number designations and safety classifications in accordance with ASHRAE 34. Refrigerants shall meet the requirements of ARI 700 as a minimum. Refrigerants shall have an Ozone Depletion Potential (ODP) of less than or equal to 0.05. Chiller shall be provided with a complete factory mounted and prewired [electric] [microprocessor based control system]. Controls package shall contain as a minimum a digital display or acceptable gauges, an on-auto-off switch, motor starters, power wiring, control wiring, and disconnect switches. Controls package shall provide operating controls, monitoring capabilities, programmable setpoints, safety controls, and EMCS interfaces.

10-9.3 Absorption Liquid Chiller. Chiller shall be constructed and rated in accordance with ARI 560 and shall bear the appropriate underwriter's laboratories (UL) label. Chiller shall be the [single-stage] [two-stage] hermetic, water-cooled type design. Chiller shall be [indirectly-fired with [steam] [hot water]] [directly-fired with a [single] [dual] fuel burner]. [For direct-fired units, ratings for cooling capacity, fuel consumption, and COP shall be based on the higher heating value (HHV) or the specific type of fuel utilized.] Unless necessary for delivery purposes, chiller shall be assembled, leak-tested, charged, and adjusted at the factory. In lieu of delivery

constraints, a chiller may be assembled, leak-tested, charged, and adjusted at the job site by a factory representative. Unit components delivered separately shall be sealed and charged with a nitrogen holding charge. Unit assembly shall be completed in strict accordance with manufacturer's recommendations. Chiller shall operate within capacity range and speed recommended by the manufacturer. Chiller shall be provided with factory installed insulation on surfaces subject to sweating including the liquid cooler and water boxes. Chiller shall be provided from the factory with a single point wiring connection for incoming power supply. Magnetic across-the-line motor starters with overload protection shall be provided for each factory supplied pump. Chiller shall include all customary auxiliaries deemed necessary by the manufacturer for safe, controlled, automatic operation of the equipment. Evaporator, absorber, condenser, generator(s), and heat exchanger(s) shall be of the shell-and-tube type construction and be in accordance with ASME BPV VIII Div 1. Chiller shall be provided with a forced draft, flame retention type burner and fuel train assembly. Burner shall be the [single] [dual] fuel type capable of burning [natural gas] [propane] [and] [number 1 fuel oil] [number 2 fuel oil] [diesel]. Burner and fuel train shall be listed by the underwriters laboratories (UL). Chiller shall be provided with a complete factory mounted and prewired [electric] [microprocessor based control system]. Controls package shall contain as a minimum a digital display or acceptable gauges, an on-auto-off switch, motor starters, power wiring, control wiring, and disconnect switches. Controls package shall provide operating controls, monitoring capabilities, programmable setpoints, safety controls, and control system interfaces.

10-9.4 Cooling towers. Each tower shall be the [induced] [forced] mechanical draft, [crossflow] [or] [counterflow], factory fabricated, factory-assembled type. Towers shall conform to NFPA 214. Fire hazard rating for plastic impregnated materials shall not exceed 25. Plastics shall not drip or run during combustion. Determine ratings by ASTM E 84 or NFPA 255. Casing shall be constructed Type 304 stainless steel or FRP. Basin shall be completely watertight and constructed of Type 304 stainless steel or FRP. The fill shall be [PVC formed sheets arranged in a honeycomb or waveform configuration] [or] [treated Douglas-fir, hemlock or redwood]. Fill shall be removable or otherwise made accessible for cleaning. Provide space supports as required to prevent sagging and misalignment, and provide for an even mixing of air and water. Structural supports shall be provided in accordance with the recommendations of the manufacturer of the tower unless otherwise indicated. Water distribution systems shall be accessible and permit flexibility of operation. Systems shall be self-draining and nonclogging. Provide drift eliminators in tower outlet to limit drift loss to not over 0.02 percent of specified water flow. Fans shall be the [centrifugal] [or] [adjustable-pitch propeller] type, constructed of Type 304 stainless steel, aluminum or an aluminum alloy, or FRP.

10-9.5 Closed circuit coolers. Casing shall be constructed of hot-dip galvanized steel with fan section constructed of stainless steel. Coil and frame shall be steel and hot-dip galvanized after fabrication. Access doors or panels suitably sized and located shall be provided for access for cleaning, repair, or removal. Provide discharge damper controls to minimize heat loss during reduced operation and electric heater in sump for freeze protection.

10-9.6 Evaporative condensers. Condenser shall be rated and tested in accordance with requirements of ASHRAE 64. Condenser shall include fans, water pump with suction strainer, electric motor and drive equipment, water eliminators if required, condensing coil, liquid receiver if required, water pan or sump, spray nozzles or water-distribution pan, water strainer, water make-up assembly, bleeder with flow valve of the needle valve type sized for the flow required or a fixed orifice, enclosure with suitable access doors, and air-inlet and outlet openings. No water shall carry over into the unit discharge outlet. Enclosure shall be constructed of [18 gauge hot-dip galvanized steel] [aluminum], reinforced and braced. Access doors or panels suitably

sized and located shall be provided for access to water nozzles or distribution pan, coils, and valves for cleaning, repair, or removal of the item.

10-9.7 [Manufacturer's multiyear compressor warranty. The Contractor shall provide a [5] [10] year [parts only (excludes refrigerant)][parts and labor (includes refrigerant)] manufacturer's warranty on the chiller compressor(s). This warranty shall be directly from the chiller manufacturer to the Government and shall be in addition to the standard one-year warranty of construction. The manufacturer's warranty shall provide for the repair or replacement of the chiller compressor(s) that become inoperative as a result of defects in material or workmanship within [5] [10] years after the date of final acceptance. When the manufacturer determines that a compressor requires replacement, the manufacturer shall furnish new compressor(s) at no additional cost to the Government. Upon notification that a chiller compressor has failed under the terms of the warranty, the manufacturer shall respond in no more than [6] [24] [ ] hours. Response shall mean having a manufacturer-qualified technician onsite to evaluate the extent of the needed repairs. The warranty period shall begin on the same date as final acceptance and shall continue for the full product warranty period.]

10-10 **AIR DISTRIBUTION SYSTEMS.** Provide duct systems conforming to the recommendations of the SMACNA Duct Construction Standards including seal class requirements. Fire dampers shall be provided where required by code. Balancing dampers shall be provided at all branch takeoffs and for all supply outlets. Permanent access to dampers shall be provided.

10-10.1 Ductwork. All ductwork including fittings and components shall conform to SMACNA HVAC Duct Construction Standards. Seal class shall be as recommended by SMACNA. [Internally lined ductwork shall not be allowed.] Pressure sensitive tape shall not be used as a sealant.

10-10.2 Supply diffusers and registers. Diffusers shall be located to ensure that the air distribution will completely cover all surfaces of exterior walls with a blanket of conditioned air or may be of a compact design so long as 'dead spots' within the units are avoided. At least one diffuser shall be provided in each habitable room. Diffusers shall be provided with integral opposed blade damper. Diffusers shall be provided with air deflectors as required for proper air flow in the space. Plastic diffusers are prohibited. Core velocity shall be limited to 3 m/sec [600 fpm] maximum, with a maximum pressure drop of 0.82 Pa/m [0.1 inch water]. Airflow from any single diffuser shall be limited to 94.4 L/s [200 cfm] maximum. Ceiling mounted units shall have factory finish to match ceiling color, and be installed with rims tight against ceiling. Sponge-rubber gaskets shall be provided between ceiling or wall and surface-mounted diffusers for air leakage control. Diffuser boots shall be sealed tight to the wall or ceiling they penetrate using duct mastic or caulking. Suitable trim shall be provided for flush-mounted diffusers. Duct collar connecting the duct to diffuser shall be airtight and shall not interfere with volume controller. Wall supply registers shall be installed at least 150 mm [6 inches] below the ceiling.

10-10.3 Return/exhaust registers and grilles. Grilles shall be fixed horizontal or vertical louver type similar in appearance to the supply diffuser face. Registers shall be provided with integral opposed blade damper. Plastic units are prohibited. Core velocity shall be limited to 2 m/sec [400 fpm] maximum, with a maximum pressure drop of 0.5 Pa/m [0.06 inch water]. Grilles shall be provided with sponge-rubber gasket between flanges and wall or ceiling. Register/grille boots shall be sealed tight to the wall or ceiling they penetrate using duct mastic or caulking. Wall return grilles shall be located at least 150 mm [6 inches] above the floor or below the ceiling.

10-10.4 Flexible duct. Shall be limited to runouts, shall be adequately supported to prevent kinks and shall not exceed 3.2 m [10 feet] in length. Runouts shall be preinsulated, factory fabricated, and conform with NFPA 90 and UL 181.

10-10.5 Fire dampers. Fire dampers shall be located and installed in accordance with NFPA requirements, and shall conform to the requirements of UL 555. Fire dampers shall be automatic operating, and shall be rated for the maximum system velocity and pressure. Fire dampers shall be equipped with a steel sleeve or adequately sized frame installed in such a manner that disruption of the attached ductwork, if any, will not impair the operation of the damper. Dampers shall not reduce the duct or the air transfer opening cross-sectional area. Access doors shall be provided at all fire dampers.

10-10.6 Balancing dampers. Provide in ducts serving each supply, return and exhaust air device.

10-10.7 Access doors. Provide in ductwork and plenums at all air flow measuring devices, automatic dampers, fire dampers, coils, thermostats and other devices requiring service and inspection.

#### 10-11 **HYDRONIC DISTRIBUTION SYSTEMS.**

10-11.1 Pumps. Provide [inline] [basemounted] centrifugal pump for each hydronic system provided. Provide flexible connections and pressure gauges on pump inlet and outlet. [Provide primary and backup pump for each hydronic system provided.]

10-11.2 Air separator. Provide air separator for each closed hydronic system provided.

10-11.3 Expansion. Provide a [bladder tank] [expansion tank] for each closed hydronic system provided.

10-11.4 Chemical feed systems. Provide means for chemical treatment for each hydronic system provided. Provide automatic chemical treatment systems for all open water systems. Provide initial treatment and one year supply of chemicals for each system provided.

10-11.5 Makeup water. Provide backflow preventers and pressure reducing valves on each makeup water system provided. Each hydronic system shall have a separate pressure reducing valve.

10-12 **PIPING SYSTEMS.** Piping systems shall be in accordance with the following subparagraphs. Fittings and valves shall be compatible for the piping systems in which installed. Provide dielectric unions where required. Provide flexible connections where necessary to prevent vibrations from transmitting from equipment to the piping system. Expansion loops,

expansion joints and offsets shall provide with adequate anchors and guides where required to prevent excessive forces within the piping systems. All piping shall be properly and adequately supported. Pipe supports shall conform to MSS SP-58 and MSS SP-69.

10-12.1 Chilled water. Shall be steel piping conforming to ASTM A 53/A 53M, Grade A or B, black steel, schedule 40 or copper tubing conforming to ASTM B 88, ASTM B 88M, Type K or L.

10-12.2 Hot water. Shall be steel piping conforming to ASTM A 53/A 53M, Type E or S, Grade A or B, black steel, schedule 40 or copper tubing conforming to ASTM B 88, ASTM B 88M, Type K or L.

10-12.3 Refrigerant. Copper tubing shall conform to ASTM B 280 annealed or hard drawn as required. Copper tubing shall be soft annealed where bending is required and hard drawn where no bending is required. Soft annealed copper tubing shall not be used in sizes larger than 35 mm [1-3/8 inches]. Refrigerant piping, valves, fittings, and accessories shall conform to the requirements of ASHRAE 15.

10-12.4 Steam. Shall be steel piping conforming to ASTM A 53/A 53 M, Type E or S, Grade A, black steel, schedule 40.

10-12.5 Steam condensate. Shall be steel piping conforming to ASTM A 53/A 53 M, Type E or S, Grade A, black steel, schedule 80.

10-12.6 Condensate drain. Shall be copper tubing or PVC pipe.

10-13 INSULATION. Pipe and duct insulation shall be in accordance with ASHRAE 90.1. Equipment insulation shall be a minimum of 50 mm [2 inch] thickness or as necessary to prevent the surface temperature from exceeding 60 degrees C [140 degrees F].

10-13.1 Duct insulation. Provide on the exterior of all supply and outside air ducts and plenums and on all return ducts in unconditioned spaces. Exhaust ductwork does not require insulation. Insulation shall be faced with a vapor barrier material having a performance rating not to exceed 1.0 perm. Insulation, vapor barrier, and closure systems shall be non-combustible as defined in NFPA 255, with a flame-spread rating of not more than 25, and a smoke development rating of not more than 50, as defined in ASTM E-84. Where insulated ducts pass through fire walls, fire partitions, above grade floors, and fire rated chase walls, the penetration shall be sealed with fire stopping materials.

10-13.2 Pipe. Provide on all aboveground hot and cold piping systems except PVC condensate drains. Insulation shall form a continuous thermal retarder and shall have a vapor retardant to prevent condensation on cold piping systems. Installation shall be with full length units of insulation and using a single cut piece to complete a run. Cut pieces or scraps abutting each other shall not be used. Supply the insulation with manufacturers recommended factory applied jacket except for flexible cellular. Piping exposed to weather shall be insulated and an aluminum jacket or PVC jacket shall be applied. Where insulated pipes pass through fire walls, fire partitions, above grade floors, and fire rated chase walls, the penetration shall be sealed with fire stopping materials.

10-13.2.1 Cold aboveground piping. Insulation for minus 34.5 degrees to plus 15.6 degrees C [minus 30 degrees to plus 60 degrees F] for outdoor, indoor, exposed or concealed applications, shall be as follows:

10-13.2.1.1 Cellular Glass: ASTM C 552, Type II, and Type III.

10-13.2.1.2 Flexible Cellular Insulation: ASTM C 534, Type I or II with vapor retarder skin on both sides.

10-13.2.1.3 Phenolic Insulation: ASTM C 1126, Type III.

10-13.2.1.4 Polyisocyanurate Insulation: ASTM C 591, Type I.

10-13.2.1.5 Hot aboveground piping. Insulation for above 15.6 degrees C [60 degrees F] for outdoor, indoor, exposed or concealed applications, shall be as follows:

10-13.2.2.1 Mineral Fiber: ASTM C 547, Types I, II or III.

10-13.2.2.2 Calcium Silicate: ASTM C 533, Type I indoor only, or outdoors above 121 degrees C [250 degrees F] pipe temperature.

10-13.2.2.3 Cellular Glass: ASTM C 552, Type II and Type III.

10-13.2.2.4 Flexible Cellular Insulation: ASTM C 534, Type I or II to 93 degrees C [200 degrees F] service.

10-13.2.2.5 Phenolic Insulation: ASTM C 1126 Type III to 121 degrees C [250 degrees F] service shall comply with ASTM C 795.

10-13.2.2.6 Polyisocyanurate Insulation: ASTM C 591, Type 1, to 149 degrees C [300 degrees F] service.

10-13.3 Equipment. Provide on all equipment when temperatures are below 16 degrees C [60 degrees F], above 40 degrees C [104 degrees F] or where condensation can occur. Insulation shall be suitable for the temperature encountered. Insulation shall be formed or fabricated to fit the equipment. Removable insulation sections shall be provided to cover parts of equipment which must be opened periodically for maintenance including vessel covers, fasteners, flanges and accessories. Supply the insulation with manufacturer's recommended factory applied jacket.

10-14 **CONTROLS.** Control system shall be [pneumatic] [DDC] [or] [electric]. Provide all devices required, including air compressors, refrigerated dryers, current transducers, transformers, thermostats, sensors, controllers, actuators, control valves, dampers, transmitters, flow meters, etc., to provide a complete and operable system. All thermostats for systems that provide both heating and cooling shall have a deadband of 2.8 degrees C [5 degrees F]. All equipment and systems shall be automatically controlled [and monitored] by the control system. [The control system shall tie into the existing [EMCS] [UMCS] system.] [A description of the existing system shall be provided by the design agent.] Control system instructions shall be provided for each system. The instructions shall consist of half-size laminated drawings and shall include the control system schematic, equipment schedule, ladder diagram, sequence of operation, panel arrangement drawings, wiring diagram, and valve and damper schedules.

10-15 **TESTING, ADJUSTING AND BALANCING.** Testing, adjusting and balancing of each system shall be the Contractor's responsibility. Testing and balancing of air and hydronic systems shall be accomplished by a firm certified for testing and balancing by the Associated Air Balance Council (AABC) or National Environmental Balancing Bureau (NEBB). Prior to testing, adjusting, and balancing, the Contractor shall verify that the systems have been properly installed and are operating as specified. Testing of individual items of equipment shall be performed by a person authorized to perform such testing and startup by the equipment manufacturer. The contractor shall correct all systems and equipment not found in compliance, and shall be responsible for all labor and materials required for this effort. AABC MN-1, NEBB-01, SMACNA-07 or ASHRAE 111 shall be used as the standard for providing testing of air and water systems. The selected standard shall be used throughout the entire project. All recommendations and suggested practices contained in the selected standard shall be considered mandatory. Instrumentation accuracy shall be in accordance with selected standard.

10-15.2 Piping systems. Each piping system including pipe, valves, fittings and equipment shall be hydrostatically tested and proved tight at a pressure of 1-1/2 times the design working pressure, but not less than 699 kPa [100 psi] for a period of not less than two hours with no appreciable loss in pressure. Piping shall not be insulated until testing is completed and acceptable. Upon completion of installation and prior to startup, each hydronic system shall be balanced. All balancing data, including deficiencies encountered and corrective action taken, shall be recorded. Following final acceptance of certified reports by the Contracting Officer, the setting of all HVAC adjustment devices shall be permanently marked by the Contractor's balancing engineer so that adjustment can be restored if disturbed at any time.

10-15.3 Air systems. Following adjusting and balancing, duct pressure testing of air systems shall be performed on 10 percent of the systems which have been randomly selected by the Contracting Officer. No additional testing will be required if at least 90 percent of the tested systems pass the air leakage test requirements. If less than 90 percent of the tested systems pass the air leakage test, an additional 10 percent of the systems shall be tested. This process shall continue until 90 percent of the total number of tested systems pass. Where specific systems require special or additional procedures for testing, such procedures shall be in accordance with the standard selected. All data, including deficiencies encountered and corrective action taken, shall be recorded. Following final acceptance of certified reports by the Contracting Officer, the setting of all HVAC adjustment devices shall be permanently marked by the Contractor's balancing engineer so that adjustment can be restored if disturbed at any time.

10-15.4 Equipment. Each item of central operating equipment provided, including boilers, [air handling units,] [ ] and chillers shall be tested in accordance with the equipment manufacturer's standard testing procedures. A factory representative shall be present for the

startup and testing of each item of equipment. A certified report shall be provided for each item of equipment tested.

10-16 **COMMISSIONING.** All HVAC systems and equipment including controls shall be commissioned in accordance with ASHRAE Guideline 1.

10-17 **TRAINING.** The Contractor shall conduct a training course for the operating for all HVAC operating systems and individual items of equipment. The field instructions shall cover all of the items of equipment provided as well as the overall systems. The training period shall consist of a total of [8] [16] [ ] hours of normal working time and shall start after the systems are functionally completed and testing, adjusting and balancing have been completed. Factory representatives shall be present to assist in training for every item of operating equipment provided. Contractor shall provide two copies of operation and maintenance instructions for each item of equipment provided. Training shall consist of startup, normal operation and shutdown, as well as demonstrations of routine maintenance operations. The Contracting Officer shall be notified at least 14 days prior to date of proposed conduction of the training course.

## **CHAPTER 11**

### **ENERGY CONSERVATION**

[The Installation shall determine which energy conservation alternatives are feasible and should be used. UEPH buildings should always consider heat recovery for the central preconditioned outside air system and dessicant cooling where applicable. Where life cycle cost effective, specify equipment efficiencies in the upper 25% of that available. In all cases, all equipment in the project shall, as a minimum, conform to FEMP or Energy Star criteria.]

**11-1 PASSIVE SOLAR APPLICATIONS.** Passive solar architectural applications shall routinely be considered as a part of all project designs. Unique applications such as attached sun spaces, earth sheltering, mass trombe walls, solar chimneys, solar dehumidifiers, and other innovations may be considered. Operational controls, such as shading and venting mechanisms, to control the amount of heat admitted into the building during the day, reduce the amount of heat escaping from the building at night, and provide for thermal comfort of the occupants, are parts of this system.

**11-1.1 South glazing.** If used as part of the solar energy system, glazing shall be of the commercially available off-the-shelf type and shall face within 20 degrees of solar south. The glazing shall be architecturally compatible with building design and the environment. It shall face directly into the living space so that the walls, floors, ceiling, and other massive objects can absorb the entering solar energy, and shall have a whole-window U value less than 1.6 square meter-kelvin (K)/watt [0.28 ft<sup>2</sup>-degrees F/BTUH].

**11-1.2 Storage mass.** If thermal performance calculations indicate a need for additional mass (beyond that provided by the building structure) substantiating data will be submitted. The storage mass will be well integrated into the building design. The thermal mass surface area in the space must be a minimum of three times the glazing area. Six to nine times the glazing area is recommended to control temperature swings. The surfaces to absorb solar energy must not be more than 10% covered.

**11-1.3 Shading of Glazing.** Cooling season shading of glazed surfaces on the east, west and south elevations is required.

**11-2 PRE-ENGINEERED ACTIVE SOLAR APPLICATIONS.** Pre-engineered active solar applications proposed for domestic water heating shall be evaluated for life-cycle-cost effectiveness using a recognized process design program. Whether site-mounted or unit-mounted, systems must be designed for maximum ease of maintenance and for architectural compatibility with the UEPH complex environment. .

**11-3 GEOTHERMAL.** Geothermal energy sources such as wet or dry steam sources, geothermal hot water, hot dry rock, etc., when determined cost effective, may be considered in regions with established geothermal sources. Each design utilizing geothermal sources shall address the project's environmental impact relating to discharge of hazardous, noncondensable gases or other hazardous effluents, noise emission, heat rejection, ground water contamination, land use, etc.

11-4 **WIND.** Wind power may be considered in regions where determined cost effective. Factors such as average wind speed, available wind power, and wind variability shall be considered when investigating the annual useful energy production potential.

11-5 **CONDENSER HEAT RECOVERY.** In regions authorized for cooling, consideration shall be given to installation of a heat exchanger to recover condenser heat and desuperheat for use in heating domestic water. A standard, domestic water heater shall be provided in conjunction with this system to provide hot water during the heating season. Heat pump water heaters can be considered in hot climates.

11-6 **ENERGY RECOVERY EQUIPMENT.**

11-6.1 Plate heat exchangers. Unit shall be a factory fabricated and tested assembly for stationary air-to-air energy recovery by transfer of sensible heat from exhaust air to supply air stream. Heat transfer surface shall be constructed of aluminum. Enclosure shall be fabricated from galvanized steel and shall include maintenance access provisions.

11-6.2 Rotary heat exchangers. Unit shall be a factory fabricated and tested assembly for air-to-air energy recovery by transfer of sensible heat from exhaust air to supply air stream. Device performance shall be according to ASHRAE 84. Exchange media shall be chemically inert, moisture-resistant, fire-retardant, laminated, nonmetallic material which complies with NFPA 90A. Exhaust and supply streams shall be isolated by seals which are static, field adjustable, and replaceable. Chain drive mechanisms shall be fitted with ratcheting torque limiter or slip-clutch protective device. Enclosure shall be fabricated from galvanized steel and shall include maintenance access provisions.

11-6.3 Heat recovery coils. Coil assembly shall be factory fabricated and tested air-to-liquid-to-air energy recovery system for transfer of sensible heat from exhaust air to supply air stream. System shall deliver an energy transfer effectiveness without cross-contamination with maximum energy recovery at minimum life cycle cost. Components shall be computer optimized for capacity, effectiveness, number of coil fins per inch, number of coil rows, flow rate and frost control. Coils, pumps, controls and piping materials shall conform to Chapter 10 – HVAC.

11-6.4 Heat pipe. Device shall be a factory fabricated, assembled and tested, counterflow arrangement, air-to-air heat exchanger for transfer of sensible heat between exhaust and supply streams. Device shall deliver an energy transfer effectiveness without cross-contamination. Heat exchanger tube core shall be seamless aluminum or copper tube with extended surfaces, utilizing wrought aluminum Alloy 3003 or Alloy 5052, temper to suit. Tubes shall be fitted with internal capillary wick, filled with an ASHRAE 15, Group 1 refrigerant working fluid, selected for system design temperature range, and hermetically sealed. Heat exchanger frame shall be constructed of not less than 16 gauge galvanized steel and fitted with intermediate tube supports, and flange connections. Tube end-covers and a partition of galvanized steel to separate exhaust and supply air streams without cross-contamination and in required area ratio shall be provided. [A drain pan constructed of welded Type 300 series stainless steel shall be provided.] Heat recovery regulation shall be provided by [system face and bypass dampers and related control system as indicated] [interfacing with manufacturer's standard tilt-control mechanism for summer/winter operation, regulating the supply air temperature and frost prevention on weather face of exhaust side at temperature indicated]. Coil shall be fitted with pleated flexible connectors.

**Project Name**  
**UEPH Complex**

**Project Number**  
**Statement of Work**  
**26 November 2001**

11-6.5 Pretreatment of Outside Air for UEPH Buildings. Dessicant cooling and other methods should be considered for pretreatment of outside air for UEPH buildings.

11-7 **REBATES AND INCENTIVES.** Systems and techniques which take advantage of rebates and incentives offered by utilities are preferred and shall be stated by the government and local utility districts.

**CHAPTER 12**

**FIRE PROTECTION**

12-1 **DESIGN STANDARDS AND CODES.** The fire protection design for all facilities shall be in accordance with the current versions of the International Building Code and the National Fire Protection Association (NFPA) standards and codes.

12-1.1 **Fire Protection Engineer.** The contractor shall provide the services of a qualified registered fire protection engineer. The fire protection engineer shall be an integral part of the design team and shall be involved in all aspects of the design of the fire protection system.

12-1.2 **Fire Protection and Life Safety Analysis.** The fire protection engineer shall perform a fire protection and life safety design analysis of the proposed facility design. The analysis shall be submitted with the preliminary design submittal. The analysis shall include type of construction; height and area limitations; classification of occupancy; building separation or exposure protection; specific compliance with NFPA codes and the IBC; requirements for fire-rated walls, doors, fire dampers, etc.; analysis of automatic suppression systems and protected areas; water supplies; smoke control systems; fire alarm system, including connection to the base-wide system; fire detection system; standpipe systems; fire extinguishers; interior finish ratings; and other pertinent fire protection data. The submittal shall include a life safety floor plan showing occupant loading, occupancy classifications and construction type, egress travel distances, exit capacities, sprinklered areas, fire extinguisher locations, ratings of fire-resistive assemblies, and other data necessary to exhibit compliance with life safety code requirements.

12-2 **HYDRANT FLOW DATA.**

/1/

**[ The Activity preparing the RFP shall address the adequacy of the existing water supply to meet the demands of the fire protection system required. The Activity preparing the RFP shall perform or witness the required water flow testing and verify that test results are accurate. Flow testing shall be conducted at or near the point of connection to the existing water main. Accepting historical water supply information without verification is not acceptable. The Activity preparing the RFP shall perform a preliminary hydraulic analysis to determine if the existing water supply is adequate to meet the demand, or if a fire pump and water storage tank is needed. Information shown below must be completed by the RFP preparing Activity.]**

12-2.1 A preliminary hydraulic analysis performed using recent flow test data indicates that the sprinkler system design for this facility will require a [fire pump] [fire pump and storage tank] [.....]. Proposed design shall be based on test data as described below.

Flow Data:

Date and Location of Test: [\_\_\_\_\_]

Static Pressure Measured: [ ] [kPa] [psi]

Residual Pressure of: [ ] [kPa] [psi] Flowing [ ] [liters/min] [gpm]

12-2.2 The contractor shall provide detailed calculations which demonstrate that the systems designed meet the flow demands of the sprinkler systems within the facility and the fire department hose stream requirements from the fire hydrants.

/1/

12-3 **SPRINKLER SYSTEM.**

12-3.1 Wet pipe sprinkler system. [ The entire building ] [ describe spaces to be sprinkled ] shall be protected by a wet pipe sprinkler system. Sprinkler system shall be designed and installed in accordance with the provisions of NFPA 13, Standard for the Installation of Sprinkler Systems. UEPH building four stories or less may be protected by a wet pipe sprinkler system designed and installed in accordance with the provisions of NFPA 13R, except that buildings, which use the sprinkler system to increase allowable floor area based on particular construction type, shall be designed and installed in accordance with the provisions of NFPA 13. Provide hydraulic calculations to support design of the system.

12-3.2 Dry pipe sprinkler system. Provide dry pipe sprinkler system for [ describe spaces to be sprinkled ]. Sprinkler system shall be designed and installed in accordance with the provisions of NFPA 13, Standard for the Installation of Sprinkler Systems. Provide hydraulic calculations to support design of the system.

12-3.1 Sprinkler Heads. All sprinkler heads located in finished areas shall be recessed pendant type.

12-4 **FIRE PUMP.**

12-4.1 Electric fire pump. Provide electric driven fire pump and controllers in accordance with NFPA 20.

12-4.2 Diesel fire pump. Provide electric driven fire pump and controllers in accordance with NFPA 20. Provide a diesel fuel tank in accordance with NFPA criteria.

12-5 **STANDPIPE AND HOSE SYSTEM.** Provide standpipe and hose system for all buildings in accordance with NFPA criteria.

12-6 **BUILDING CONSTRUCTION.** Comply with requirements of International Building Code and NFPA 101 Life Safety Code.

12-6.1 **Fire Extinguishers and Cabinets.** Provide portable fire extinguishers in accordance with NFPA 10. Provide semi-recessed aluminum fire extinguisher cabinets with clear view panel in public areas, and where indicated in functional and area requirements. Provide fire-rated cabinets in fire-rated wall assemblies.

12-6.2 **Interior Wall and Ceiling Finishes.** Wall and ceiling finishes and movable partitions shall conform to the requirements of the IBC and NFPA 101, except as follows [The following, more stringent, interior finish requirements are included to comply with MilHdbk 1008C, Fire Protection for Facilities Engineering, Design, and Construction]:

12-6.2.1 Interior finish for exits, exit passageways, sleeping rooms shall be Class A only.

12-6.2.2 Flame spread (FS) and smoke development (SD) shall be tested in accordance with ASTM E84. Tests shall not exceed FS rating of 25 and SD rating of 50 for Class A materials; FS rating of 75 and SD rating of 100 for Class B materials; and FS rating of 200 and SD rating of 200 for Class C materials. Class C materials shall only be permitted in fully sprinklered buildings.

12-6.2.3 Cellular plastics shall not be used as interior wall and ceiling materials.

12-6.2.4 Carpeting and other textile wall coverings shall only be applied as an interior finish if the material passes the acceptance criteria of the Uniform Building Code (UBC) Standard 8-2, Test Method for Textile Wall Coverings, conducted by a nationally recognized testing laboratory.

12-7 **FIRE ALARM.** Provide fire alarm and detection system conforming to requirements of NFPA 72 and NFPA 101. Fire alarm system shall be addressable (intelligent) and consist of smoke and/or heat detectors, pull stations, audiovisual devices, control/annunciation panel and tamper and/or flow connection/supervision to the sprinkler system. Heat detectors are not required in UEPH buildings. Provide supervision of fire pump where fire pump is provided. [Fire alarm system shall tie into the base-wide system.]

12-7.1 [ Design Activity shall provide detailed information on the existing base-wide fire alarm system if one exists. ]

## **CHAPTER 13**

### **SUSTAINABLE DESIGN**

13-1 **SUSTAINABLE DESIGN GOALS.** The goals for improving the sustainability of facilities include: (a) use resources efficiently and minimize raw material resource consumption, including energy, water, land and materials, both during the construction process and throughout the life of the facility, (b) maximize resource reuse, while maintaining financial stewardship, (c) move away from fossil fuels towards renewable energy sources, (d) create a healthy and productive work environment for all who use the facility, (e) build facilities of long-term value, and (f) protect and, where appropriate, restore the natural environment.

13-2 **PROJECT REQUIREMENTS.** Sustainable design techniques shall be considered as they relate to site and building design, construction, and operation. Techniques which conserve energy, improve livability, and can be justified by life cycle cost analysis as cost effective are encouraged.

13-2.1 Sustainable design is a proposal evaluation factor. The level of incorporation of sustainable design principles will be measured through use of the Sustainable Project Rating Tool (SPiRiT), available from the following website: [fill in web address, or modify this sentence and attach the most current SPiRiT document to the Statement of Work]. SPiRiT is the government version of the LEED Green Building Rating System™, developed by the U.S. Green Building Council.

13-2.2 Each offeror will complete and submit the SPiRiT Facility Points Summary with the proposal; the total point score will determine the SPiRiT Sustainable Project Certification Level: SPiRiT Bronze, Silver, Gold, or Platinum. The certification level will be used as a proposal evaluation factor as defined in RFP Section 00120 – Proposal Evaluation and Contract Award.

13-2.3 Proposals that do not achieve a SPiRiT Bronze certification level will be considered non-conforming.

13-2.4 Proposals that do not comply with the “Required” criteria listed in the SPiRiT document will be considered non-conforming. For example: SPiRiT category *3.R3 CFC Reduction in HVAC&R Equipment* requires zero use of CFC-based refrigerants in new mechanical systems. Although no credit points are available, the requirement must be met to achieve the minimum certification level.

13-2.5 Some SPiRiT categories award potential points (credits) for strategies or decisions that are not within the control of the Offeror. These areas may include installation master planning, site selection, or involving facility users in the programming process. The Offeror will receive points in the following credit categories for criteria met by the government: [insert the credits earned by government actions that are not within the scope of the proposal requirements. Especially look at SPiRiT categories 1.C1 Site Selection, 1.C2 Installation/Base Redevelopment, 1.C10 Facility Impact, and 6.C1 Holistic Delivery of Facility]. Other than the credits stated in this paragraph, the Offeror shall not receive points for any SPiRiT criteria that cannot be substantiated by information contained in the proposal.

**APPENDIX A**

**REFERENCES**

**GOVERNMENT PUBLICATIONS:**

Code of Federal Regulations  
Government Printing Office  
Washington, DC 20402

49 CFR 192      Transportation of Natural  
and other Gas by Pipeline: Minimum  
Federal Safety Standards

40 CFR 280      Owners and Operators of  
Underground Storage Tanks

49 CFR 195      Transportation of  
Hazardous Liquids by Pipeline

10 CFR 430      Energy Conservation  
Program for Consumer Products

Department of the Navy

Standardization Documents Order  
Desk  
700 Robbins Avenue, Bldg. 4D  
Philadelphia, PA 19111-5094

MIL-HDBK-1008, Fire Protection for  
Facilities Engineering, Design, and  
Construction

U.S. Government Printing Office

Superintendent of Documents  
U.S. Government Printing Office  
Washington, DC 20402

U.S. Government Printing Office (GPO)  
Style Manual

**NON-GOVERNMENT PUBLICATIONS:**

Air Movement and Control Association  
30 W. University Drive  
Arlington Heights, IL 60004-1893

AMCA 210      (1985) Laboratory  
Methods of Testing Fans for Rating

Air Conditioning and Refrigeration Institute  
4301 North Fairfax Drive  
Arlington, VA 22203

ARI 310/380      (1993) Packaged  
Terminal Air-Conditioners and Heat Pumps

ARI 440      (1998) Room Fan-Coil and  
Unit Ventilator

**Project Name**  
**UEPH Complex**

**Project Number**  
**Statement of Work**  
**26 November 2001**

	ARI 445 (1987; R 1993) Room Air-Induction Units
American Architectural Manufacturers Association (AAMA) 1827 Walden Office Square, Suite 104 Schaumburg, IL 60173-4268	ARI 880 (1998) Air Terminals AAMA 101 Voluntary Specifications for Aluminum, Vinyl and Wood Windows and Glass Doors  AAMA 605 Voluntary Specification Performance Requirements and Test Procedures for High Performance Organic Coatings on Aluminum Extrusions and Panels  AAMA 607.1 Voluntary Guide Specifications and Inspection Methods for Clear Anodic Finishes for Architectural Aluminum  AAMA 1503 Voluntary Test Method for Thermal Transmittance and Condensation Resistance of Windows, Doors, and Glazed Wall Sections
American Bearing Manufacturers Association 1200 19 <sup>th</sup> Street, NW Washington, DC 20036-4303	AFBMA Std 9 (1990) Load Ratings and Fatigue Life for Ball Bearings  AFBMA Std 11 (1990) Load Ratings and Fatigue Life for Roller Bearings
American Boiler Manufacturers Association (ABMA) 950 N. Glebe Rd, Suite 160 Arlington, VA 22203-1824	ABMA ISEI Industry Standards and Engineering Information
American National Standards Institute 11 West 42 Street New York, NY 10036	ANSI Z21.10.1 (1993; Z21.10.1a; Z21.10.1b; Z21.10.1c) Gas Water Heaters Vol. I, Storage Water Heaters with Input Ratings of 75,000 Btu Per Hour or Less  ANSI Z124.3 (1995) American National Standard for Plastic Lavatories.  ANSI Z124.6 (1997) Plastic Sinks  ANSI Z21.45 (1995) Flexible

**Project Name**  
**UEPH Complex**

**Project Number**  
**Statement of Work**  
**26 November 2001**

Connectors of Other Than All-Metal  
Construction for Gas Appliances

ANSI C2 (1997) National Electrical  
Safety Code

ANSI 70 (1996) National Electrical  
Code

ANSI/TIA/EIA-569-A (1998)  
Commercial Building Standard for  
Telecommunications Pathways and  
Spaces

American Society for Testing and  
Materials  
100 Bar Harbor Drive  
West Conshohocken, PA 19428-2959

ASTM E84 (2000) Surface Burning  
Characteristics of Building Materials

ASTM D 2846/D 2846M (1999)  
Chlorinated Poly(Vinyl Chloride) (CPVC)  
Plastic Hot- and Cold-Water Distribution  
Systems

ASTM D 2513 (1999; Rev. A)  
Thermoplastic Gas Pressure Pipe, Tubing,  
and Fittings

ASTM D 2683 (1998) Socket-Type  
Polyethylene Fittings for Outside  
Diameter-Controlled Polyethylene Pipe  
and Tubing

ASTM A 53 (1999) Pipe, Steel, Black  
and Hot-Dipped, Zinc-Coated Welded and  
Seamless

ASTM A 106 (1999) Seamless Carbon  
Steel Pipe for High-Temperature Service

ASTM B 88 (1999) Seamless Copper  
Water Tube

ASTM D 5686 (1995) "Fiberglass"  
(Glass-Fiber-Reinforced Thermosetting-  
Resin) Pipe and Pipe Fittings, Adhesive  
Bonded Joint Type Epoxy Resin, for  
Condensate Return Lines

ASTM D 2241 (1996b) Poly(Vinyl Chloride) (PVC) Pressure-Rated-Pipe (SDR Series)

ASTM D 1784 (1999a) Rigid Poly(Vinyl Chloride) (PVC) Compounds and Chlorinated Poly(Vinyl Chloride) (CPVC) Compounds

ASTM D 1248 (1998) Polyethylene Plastics Molding and Extrusion Materials

ASTM C 591 (1994) Unfaced Preformed Rigid Cellular Polyisocyanurate Thermal Insulation

ASTM C 518 (1998) Steady-State Heat Flux Measurements and Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus

ASTM A 134 (1996) Pipe, Steel, Electric-Fusion (Arc)-Welded (Sizes NPS 16 and Over)

ASTM A 135 (1997c) Electric-Resistance-Welded Steel Pipe

ASTM A 139 (1996e1) Electric-Fusion (Arc)-Welded Steel Pipe (NPS 4 and over)

ASTM A 36/A 36M (2000) Carbon Structural Steel

ASTM D 2310 (1997) Machine-Made "Fiberglass" (Glass-Fiber-Reinforced Thermosetting-Resin) Pipe

ASTM D 2996 (1996; Rev. A) Filament-Wound "Fiberglass" (Glass-Fiber-Reinforced Thermosetting Resin) Pipe

American Society of Heating, Refrigerating and Air Conditioning Engineers  
1791 Tully Circle. NE

ASHRAE 90.1 (1989; 90.1b; 90.1c; 90.1d; 90.1e; 90.1g; 90.1i 90.11-1995; 90.1m-1995; 90.1n-1997) Energy Efficient

**Project Name**  
**UEPH Complex**

Atlanta, GA 30329-2305

American Society of Mechanical Engineers  
International  
Three Park Place  
New York, NY 10016-5990

Architectural Woodwork Institute  
1952 Isaac Newton Square W.  
Reston, VA 20190

Associated Air Balance Council  
1518 K Street NW, Suite 708  
Washington, DC 20005

Builders Hardware Manufacturers  
Association  
355 Lexington Ave, Suite 1700  
New York, NY 10017-6603  
Council of American Building Officials  
5203 Leesburg Pike, Suite 708  
Falls Church, VA 22041

Electronic Industries Association (EIA)  
2500 Wilson Blvd  
Arlington, VA 22201-3834

**Project Number**  
**Statement of Work**  
**26 November 2001**

Design of New Buildings Except Low-Rise  
Residential Buildings

ASHRAE Hdbk-IP (1997) Handbook,  
Fundamentals I-P Edition

ASME B31.8 (1995) Gas  
Transmission and Distribution Piping  
Systems

ASME B16.11 (1996) Forged Fittings,  
Socket-Welding and Threaded

ASME B31.1 (1998; Addenda 1999  
and 2000) Power Piping

ASME BPVC SEC VII (1995; Addenda  
1995, 1996, and 1997) Boiler and  
Pressure Vessel Code: Section VII  
Recommended Guidelines for the Care of  
Power Boilers

ASME (1996) Pipe Flanges and  
Flanged Fittings NPS 1/2 Through NPS 24

AWI Quality Standards (1999) 7<sup>th</sup> Edition,  
Version 1.2

AABC MN-1 (1989) National  
Standards for Testing and Balancing  
Heating, Ventilating, and Air Conditioning  
Systems

ANSI/BHMA A156.4 (2000) American  
National Standards for Door Controls -  
Closers...

CABO A117.1 (1992; Errata Jun  
1993) Accessible and Usable Buildings  
and Facilities

EIA/TIA 568-B (2001) Commercial  
Building Telecommunications Cabling  
Standards

**Project Name**  
**UEPH Complex**

**Project Number**  
**Statement of Work**  
**26 November 2001**

	EIA/TIA 569-A (2001, amendment 5) Commercial Building Standard for Telecommunications Pathways and Spaces
Illuminating Engineering Society of North America 120 Wall Street, 17 <sup>th</sup> Floor New York, NY 10005-4001	IESNA RP-8 (1983; R 1993) Roadway Lighting  IES LHBK (1993) Lighting Handbook, Reference and Application Standard for Use of the International System of Units (SI): the Modern Metric System
Institute of Electrical and Electronics Engineers Inc. (IEEE) 445 Hoes Lane, P.O. Box 1331 Piscataway, NJ 08855-1331	
International Approval Services (IAS) 8501 E. Pleasant Valley Rd Cleveland, OH 44131	IAS Directory (1999) IAS Directory of AGA & CGA Certified Appliances and Accessories
International Association of Plumbing and Mechanical Officials 20001 Walnut Drive South Walnut, CA 91789-2825	IAPMO Z124.1 (1995) Plastic Bathtub Units  IAPMO Z124.3 (1995) Plastic Lavatories  IAPMO Z124.5 (1997) Plastic Toilet (Water Closets) Seats  IAPMO Z124.9 (1994) Plastic Urinal Fixtures
International Code Council, Inc. 5203 Leesburg Pike, Suite 708 Falls Church, VA 22041-3401	ICC (2000) International Building Codes
International Conference of Building Officials 5360 Workman Mill Road Whittier, CA 90601-2298	ICBO (1997) Uniform Building Code
National Association of Corrosion Engineers International 1440 South Creek Drive Houston, TX 77084-4906	NACE RP0169 (1996) Control of External Corrosion on Underground or Submerged Metallic Piping Systems  NACE RP0185 (1996) Extruded, Polyolefin Resin Coating Systems with Soft Adhesives for Underground or

Submerged Pipe

National Electrical Manufacturers  
Association  
1300 N 17<sup>th</sup> Street, Suite 1847  
Rosslyn, VA 22209

NEMA C12.1 (1995) Code for  
Electricity Metering

NEMA LD3 High Pressure Decorative  
Laminates

National Environmental Balancing Bureau  
8575 Grovemont Circle  
Gaithersburg, MD 20877-4121

NEMA PB 1 (1995) Panelboards  
NEBB Procedural Stds (1991)  
Procedural Standards for Testing  
Adjusting Balancing of Environmental  
Systems

National Fire Protection Association  
One Batterymarch Park  
Quincy, MA 02269-9101

NFPA 10 (1998) Standard for Portable  
Fire Extinguishers

NFPA 13 (1999) Installation of Sprinkler  
Systems

NFPA 13R (1996) Residential  
Occupancies up to and Including Four  
Stories in Height Sprinkler Systems

NFPA 20 (1999) Installation of  
Centrifugal Fire Pumps

NFPA 30 (2000) Flammable and  
Combustible Liquids Code

NFPA 31 (1997; TIA 97-11)  
Installation of Oil Burning Equipment

NFPA 54 (1999) National Fuel Gas Code

NFPA 58 (1998; Errata 58-98-1)  
Liquefied Petroleum Gas Code

NFPA 70 (2002) National Electrical Code

NFPA 72 (1996) National Fire Alarm  
Code

NFPA 80 (1999) Standard for Fire  
Doors and Fire Windows

**Project Name**  
**UEPH Complex**

**Project Number**  
**Statement of Work**  
**26 November 2001**

	NFPA 90A (1999) Installation of Air Conditioning and Ventilating Systems
	NFPA 101 (2000) Life Safety Code
Plumbing and Drainage Institute 45 Bristol Drive, Suite 101 South Easton, MA 02375	PDI G 101 (1996) Testing and Rating Procedure for Grease Interceptors with Appendix of Sizing and Installation Data
	PDI WH201 (1992) Water Hammer Arrestors
	PDI WH 201 (1992) Water Hammer Arresters
Sheet Metal and Air Conditioning Contractor's National Association PO Box 221230 Chantilly, VA 20153-1230	SMACNA HVAC Duct Const Stds (1995; Addenda Nov 1997)) HVAC Duct Construction Standards - Metal and Flexible
	SMACNA Arch. Manual (1993; Errata; Addenda Oct 1997) Architectural Sheet Metal Manual
Steel Door Institute (SDI) 30200 Detroit Road Cleveland, OH 44145-1967	ANSI A250.8/SDI 100 Standard Steel Doors and Frames
Steel Tank Institute (STI) 570 Oakwood Rd Lake Zurich, IL 60047	STI P3 Underground Steel Storage Tank Protection
Underwriters Laboratories 333 Pfingsten Road Northbrook, IL 60062-2096	UL 430 (1994; Rev thru Nov 1996) Waste Disposers
	UL 567 (1996; Rev thru Oct 1997) Pipe Connectors for Petroleum Products and LP-Gas
	UL 1746 (1993; Rev thru Sep 1998) External Corrosion Protection Systems for Steel Underground Storage Tanks
	UL 1995 (1995; Rev thru Aug 1999) Heating and Cooling Equipment
	UL 507 (1999) Electric Fans
	UL 608 Modular Vault Panels

**Project Name**  
**UEPH Complex**

**Project Number**  
**Statement of Work**  
**26 November 2001**

UL 746C (1995; Rev thru Jul 1999)  
Polymeric Materials - Use in Electric  
Equipment Evaluations

UL 705 (1994; Rev thru Feb 1999)  
Power Ventilators

UL 1316 (1994; Rev Apr 1996) Glass-  
Fiber-Reinforced Plastic Underground  
Storage Tanks for Petroleum Products,  
Alcohols, and Alcohol-Gasoline Mixtures

**LIST OF ATTACHMENTS TO THE STATEMENT OF WORK**

**NUMBER DESCRIPTION**

---

1. TECHNICAL SPECIFICATIONS  
Section 01012 - Design After Award (Design/Build)  
1\ 1/
2. RESERVED
3. RESERVED
4. 1\ RESERVED 1/
5. PROPOSAL DRAWING FORMAT
6. SITE AND LOCALITY MAPS
7. PROJECT AND SAFETY SIGNS
8. GEOTECHNICAL REPORT
9. EXCERPTS FROM THE INSTALLATION DESIGN GUIDE
10. FIRE FLOW DATA
11. LIST OF DRAWINGS
12. ASBESTOS AND LEAD PAINT SURVEY RESULTS

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**ATTACHMENT 1**  
**TECHNICAL SPECIFICATIONS**

**ATTACHMENT 1****TECHNICAL SPECIFICATIONS****GUIDE SPECIFICATIONS MODIFIED FOR DESIGN-BUILD CONSTRUCTION CONTRACTS:**

Several Guide Specifications, covering contract procedures and execution issues must be modified for design-build construction contracts to reflect the integrated design and construction aspects, as well as the non-traditional roles and responsibilities of the parties. Some of these modified Specifications have been included herein. In addition, we have included a sample Section 01012 "DESIGN AFTER AWARD" modified to suit a typical UEPH construction project. USACE Design District must review, edit, and tailor these specifications to suit the particular project.

1\1 Current UFGS Specification Sections available through CCB have been edited to include provisions to address Design-Build contracts. Design Districts shall take particular care in preparing these administrative specifications so that the provisions which address Design-Build requirements remain in the edited sections. /1/

**SUBMITTALS (SECTION 01330)**

Design submittals are covered in Division 01 General Requirements, Section 01012 "DESIGN AFTER AWARD". Construction submittal requirements are addressed in, Section 01330, "SUBMITTAL REQUIREMENTS". In design-build contracts, design and construction submittals are generally reviewed for conformance to the contract requirements. They are NOT routinely "reviewed for approval". The only time review for approval is necessary is for totally prescriptive specialty designs for which the Government desires to assume design responsibility. The requirement for approval should be determined during the development of the D-B RFP. The design-build project team needs to be explicit as to what needs Government approval and why the approval is necessary. The team also needs to be explicit as to what needs Government review and that the review is to ensure conformance to the contract requirements. The primary principle to remember is that if the Government chooses to approve the submittal, they may be taking some responsibility from the Contractor on design issues. One of the main advantages of D-B is the single point of responsibility for both design and construction. The Government shifts the risk of design adequacy to the D-B by avoiding assumption of the traditional role of "approval" of design and construction products to the maximum extent possible.

Section 01330 makes the D-B Contractor's Designer(s) of Record responsible for assuring the adequacy and integration of the design, including written approval for all extensions of design, critical materials, any deviations from the solicitation, the accepted proposal, or the completed design, equipment whose compatibility with the entire system must be checked. The Government must concur with deviations to the completed design and must approve deviations to the accepted proposal and RFP; the latter are considered formal "changes", unless inconsequential in scope and cost

This attachment provides the location for the placement of the "font end" type specifications which are used to control contractor overall operations and represent the standards of operation and communication between the Corps Construction District and the contractor.

The specifications included here should represent the minimum information necessary for the construction Area Office to adequately administer the contract, it is not the intention of this attachment to include material specific technical specifications from the Corps of Engineers Guide Specifications (UFGS) or other similar sources.

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

Below is a list of specifications which could typically be included in this attachment.

Section 01005	Special Work Requirements and Restrictions
Section 01012	Design After Award (Design/Build)*
Section 01111	Safety and Health Requirements
Section 01200	Project Meetings
Section 01300	Submittal Procedures
Section 01320	Project Schedule
Section 01330	Submittal Procedures
Section 01451	Contractor Quality Control
Section 01500	Temporary Construction Facilities
Section 01560	Environmental Protection
Section 01780	Closeout Submittals
Section 09900	Painting, General
Section 13280	Asbestos Abatement
Section 13283	Removal and Disposal of Lead-Contaminated Paint

*\* Sample specifications edited to suit the design build procurement strategy are included in this UFC for editing and use by Design Districts*

SECTION 01012  
**DESIGN AFTER AWARD**

*[Design Districts shall review and edit this specification as necessary to suit the project.]*

**1.0 GENERAL**

1.1 The Contractor shall propose a schedule for the number and composition of the design submittal phases. As a minimum, design submittals are required at the preliminary (50%), final (100%), and at the design complete stage. The requirements of each design stage are listed hereinafter. The Contractor shall reflect the number and schedules for the design submittals phases in the progress charts. As a maximum, the 50%, 100%, and design complete submittals shall be made in one consolidated package which includes each of the major categories listed in paragraph "Contents of Design Submittals".

*[Design District shall edit and remove the following paragraph if fast track design-construction is not be permitted in the particular project. Fast-track design-construction is the established standard for this program. Designers are cautioned that removal of the fast track option will inherently increase contractor costs and may cause the proposers to eliminate some quality features from the design proposal.]*

1.2 To facilitate fast-track design-construction activities the contractor shall submit a 100% Site/Utility Design as the first design submittal. Following review, resolution, and incorporation of all Government comments, and submittal of a satisfactory set of site/utility design documents, the [insert USACE Construction District] shall issue a limited Notice to Proceed (NTP) which shall allow the contractor to proceed with site development activities within the parameters set forth in the accepted design submittal. Submittal review, comment, and resolution times from this specification apply to this initial 100% Site/Utility Design Submittal. No on-site construction activities shall begin prior to receipt of a construction NTP by the contractor.

**2.0 DESIGNER OF RECORD**

The Contractor shall identify, for approval, the Designer of Record for each area of work. One Designer of Record may be responsible for more than one area. All areas of design disciplines shall be accounted for by a listed, registered Designer of Record. The Designer(s) of Record shall stamp, sign, and date all design drawings under their responsible discipline at each design submittal stage (see SCR - "Registration of Designers" ).

**3.0 DEFINITION OF DESIGN SUBMITTALS**

3.1 First Site/Utility Design Submittal (100%). This submittal is provided to allow the contractor to concentrate initial efforts for the site/utility portions of the project. By allowing this work to be separated, the contractor is given the opportunity to fast track and begin construction on the site/utility work prior to completion of the building designs. This submittal shall consist of the following:

3.1.1 Design analysis, developed to 100%, site work and utility work only.

3.1.2 100% complete site/utility drawings

3.1.3 Final site/utility specifications

3.1.4 Environmental permits, as required. When environmental permits are not required, the Contractor shall provide a statement with justification to that effect.

3.2 Preliminary Conformance – 50% Building Submittal. This submittal is intended to insure that the contractor's design is proceeding in accordance with the terms of the solicitation and the contractor's original proposal as well as in a timely manner. This submittal shall consist of the following:

3.2.1 Design analysis, developed to 50%

3.2.2 50% complete drawings

3.2.3 Draft specifications

3.2.4 Site Utility design information need not be included in this submittal package except where interface to the interior building systems is required.

3.3 Final Design - 100% Building. The review of this submittal is to insure that the design is in accordance with directions provided the Contractor during the design process as well as the original solicitation and the contractor's proposal. The Contractor shall submit the following documents for Final Design Review:

3.3.1 50% review comments and responses.

3.3.2 The Design Analysis submitted for Final Design Review shall be in its final form. The Design Analysis shall include all backup material previously submitted and revised as necessary. All design calculations shall be included. The Design Analysis shall contain all explanatory material giving the design rationale for any design decisions which would not be obvious to an engineer reviewing the Final Drawings and Specifications.

3.3.3 The Contract Drawings submitted for Final Design Review shall include the drawings previously submitted which have been revised and completed as necessary. The Contractor is expected to have completed all of his coordination checks and have the drawings in a design complete condition. The drawings shall be complete at this time including the incorporation of any design review comments generated by the previous design reviews. The drawings shall contain all the details necessary to assure a clear understanding of the work throughout construction. Shop drawings will not be considered as design drawings. All design shall be shown on design drawings prior to submittal of shop drawings.

3.3.4 The Draft Specifications on all items of work submitted for Final Design Review shall consist of legible marked-up specification sections.

3.3.5 Site Utility design information need not be included in this submittal package except where interface to the interior building systems is required.

3.4 Design Complete Submittal. After the Final Design Review, the Contractor shall revise the Contract Documents by incorporating any comments generated during the Final Design Review and shall prepare final hard copy Contract Specifications. The Contractor shall submit the following documents for the design complete submittal:

3.4.1 Design analysis, in final 100% complete form.

3.4.2 100% complete drawings.

3.4.3 Final specifications

3.4.4 Final review comments and responses.

3.4.5 Electronic Submission: All CADD files in native [AutoCAD] [MicroStation] format, as well as all prepared technical specifications shall be provided on CD-ROM. Two copies are required.

### 3.5 Structural Interior Design.

3.5.1 Definition: The Structural Interior Design (SID) shall involve the selection and sampling of all applied finishes including material, color, texture and patterns necessary to complete the building's interior architectural features. The SID shall also include all prewired workstation finishes and required drawings for prewired workstations. This information shall be submitted in 3" D-ring binders, 8-1/2" x 11" format.

3.5.2 Present architectural finish samples in an orderly arrangements according to like rooms/areas receiving like finishes. Each like room receiving like finishes will be noted as a Color Scheme. Each Color Scheme shall have a written description of material used. This written description shall use the same material abbreviations and notes that appear on the Room Finish Schedule and Legend in the contract drawings. Present prewired workstation finishes on a color board separate from the architectural finishes. Submit the SID binders concurrently with the architectural design submittals.

3.5.3 Preliminary Submittals: The Contractor shall submit three complete sets of the initial SID package. The design philosophy shall use a warm neutral background color with appropriate accent colors. All SID proposals shall be reviewed and approved by the Government. The Interior Designer shall revise the SID binders after each review and update the SID to satisfy review comments. Each submittal will follow this method of review until the Government approves the completed SID package.

3.5.4 Final Submittal: After approval of the Preliminary Submittal, the Contractor shall submit three (3) complete sets of the approved and final Structural Interior Design package. Once the Contractor has submitted the SID and the Government has approved the submittal, all materials, finishes, colors, textures and pattern submitted and approved for this project are then considered as part of the contract and the Contractor shall furnish all approved SID finishes. No deviations will be considered.

3.5.5 Format: Submit all SID information and samples on 8 1/2"x 11" modules with only one foldout. The maximum foldout width shall be approximately 25 inches. No foldouts on the top or bottom of the pages. Place the project title, base, architectural firm, page number and date on the bottom of each page or module.

3.5.5.1 The module shall support and anchor all samples. Anchor large or heavy samples with mechanical fasteners, velcro or double sided foam tape. Rubber cement or glue will not be acceptable.

3.5.5.2 Assemble the 8 1/2" x 11" pages and modules in a 3" D-ring binder. Holes for placement of the modules in the binder shall be 3/8" in diameter. Each binder shall be identified on the outside spine and front cover by title, project number, percentage phase and date.

3.5.5.3 Material and finish samples shall indicate true pattern, color and texture. Carpet samples shall be large enough to indicate a complete pattern or design.

3.5.5.4 Where paint manufacturers color names and numbers are used indicated the finish of the paint such as gloss, semi-gloss, flat and so on.

3.5.5.5 Signage may include emblems, striping, letters, numbers and logos. The interior designer shall consider visual appearance, organization, location, structural supports (if required) and relation to other base graphics. Indicate on a separate signage sheet the location and message for all signage. Submit a sample of the signage material finish and color with the structural finishes.

3.5.5.6 No photographs or colored photocopies of materials will be accepted or approved.

3.5.6 The SID Binder shall include the following information at each design submittal in this order:

=====

**SEQUENCE OF SID SUBMITTAL**

- 1. Title page
- 2. Table of contents
- 3. Design objectives - A statement of design objectives explaining the interior design philosophy of the facility shall be provided in the SID. Design objectives and the proposed method of accomplishing the objectives. Shall cover, when applicable, energy efficiency, safety, health, maintenance, image, personal performance of occupants and functional flexibility.
- 4. Interior floor plan
- 5. Interior sample finish boards

Scheme A  
 Scheme B  
 Scheme C

Example all restrooms could be noted as color scheme "A", all general open office finishes could be noted as color scheme "B" and the main lobby could be noted as color scheme "C".

- 6. Room finish schedule
- 7. Signage
- 8. Signage plan
- 9. Prewired workstation composite floor plans
- 10. Prewired workstation typicals - elevations and component inventory.
- 11. Prewired workstation panel identification plan with electrical outlet placement including base feed.
- 12. Integration and layout of ACSIM specific furniture. Plan must show suitability of proposed space to suit the furniture to be provided.

=====

**4.0 QUANTITY OF DESIGN SUBMITTALS**

4.1 General. The documents which the Contractor shall submit to the Government for each submittal are listed and generally described hereinafter.

DISTRIBUTION

Activity and Address	Drawings Size <Full>	Drawing Size <Half>	Color Boards **
Commander, U.S. Army Engineer District,	*	*	*
Commander, Installation	*	*	*
U.S. Army Corps of Engineers Construction Area Office	*	*	*
[Other As Applicable]	*	*	

\*USACE Design District to complete required quantities based on project requirements.

\*\* Color boards shall be submitted with the 100% building submittal only.

**5.0 MAILING OF DESIGN SUBMITTALS**

5.1 Mail all design submittals to the Government during design and construction, using an overnight mailing service. The Government will furnish the Contractor addresses where each copy shall be mailed to after award of the contract. The submittals shall be mailed to four (4) different addresses.

6.2 Each design submittal shall have a transmittal letter accompanying it indicating the date, design percentage, type of submittal, list of items submitted, transmittal number and point of contact with telephone number.

**6.0 COORDINATION**

6.1 Written Records. The Contractor shall prepare a written record of each design site visit, meeting, or conference, either telephonic or personal, and furnish within five (5) working days copies to the Contracting Officer and all parties involved. The written record shall include subject, names of participants, outline of discussion, and recommendation or conclusions. Number each written record for the particular project under design in consecutive order.

6.2 Design Needs List. Throughout the life of his contract the Contractor shall furnish the COR a monthly "needs" list for design related items. This list shall itemize in an orderly fashion design data

required by the Contractor to advance the design in a timely manner. Each list shall include a sequence number, description of action item, name of the individual or agency responsible for satisfying the action item and remarks. The list will be maintained on a continuous basis with satisfied action items checked off and new action items added as required. Once a request for information is initiated, that item shall remain on the list until the requested information has been furnished or otherwise resolved. Copies of the list will be mailed to both the Administrative Contracting Officer and the agencies tasked with supplying the information.

## **7.0 GOVERNMENT REVIEW**

7.1 Within 30 days after Notice to Proceed, the Contractor shall submit, for approval, a complete design schedule with all submittals and review times indicated in calendar dates. The Contractor shall update this schedule monthly. No design submittals will be reviewed or evaluated until after receipt and acceptance of the proposed design/review schedule.

7.2 After receipt, the Government will be allowed fourteen (14) days to review and comment on each design submittal. For each design review submittal, the COR will furnish, to the Contractor, a single consolidated listing of all comments from the various design sections and from other concerned agencies involved in the review process. The review will be for conformance with the technical requirements of the solicitation and the Successful Offeror's (Contractor's) RFP proposal. If the Contractor disagrees technically with any comment or comments and does not intend to comply with the comment, he must clearly outline, with ample justification, the reasons for noncompliance within five (5) days after receipt of these comments in order that the comment can be resolved. The Contractor shall furnish disposition of all comments, in writing, with the next scheduled submittal. The Contractor is cautioned in that if he believes the action required by any comment exceeds the requirements of this contract, that he should take no action and notify the COR in writing immediately. Review conferences will be held for each design submittal at (NAME OF BASE). The Contractor shall bring the personnel that developed the design submittal to the review conference. These conferences will take place the week after the receipt of the comments by the Contractor.

7.3 If a design submittal is over one (1) day late in accordance with the latest design schedule, the Government review period will be extended 7 days. Submittals date revisions must be made in writing at least one (1) week prior to the effect submittal.

7.4 Post review conference action: Copies of comments, annotated with comment action agreed on, will be made available to all parties before the conference adjourns. Unresolved problems will be resolved by immediate follow-on action at the end of conferences. Valid comments will be incorporated. After receipt of final corrected design documents upon incorporation of backcheck comments the [USACE Design District] will recommend issuance of a Construction Notice to Proceed (NTP). The Government, however, reserves the right to disapprove design document submittals if comments are significant. If final or backcheck submittal(s) are incomplete or deficient, and require correction by the Contractor and resubmittal for review, the cost of rehandling and reviewing will be deducted from payment due the Contractor at the rate of \$ 5,000.00 per submittal.

## **8.0 DESIGN ANALYSIS**

8.1 Media and Format. Present the design analysis on 8-1/2-inch by 11-inch paper except that larger sheets may be used when required for graphs or other special calculation forms. All sheets shall be in reproducible form. The material may be typewritten, hand lettered, handwritten, or a combination thereof, provided it is legible. Side margins shall be 1-inch minimum to permit side binding and head to head printing. Bottom margins shall be 1-1/4-inches, with page numbers centered 1 inch from the bottom.

8.2 Organization. Assign the several parts and sheets of the design analysis a sequential binding

number and bind them under a cover indicating the name of the facility and project number, if applicable. The title page shall carry the designation of the submittal being made. The complete design analysis presented for final review with the final drawings and specifications shall carry the designation "FINAL DESIGN ANALYSIS" on the title page.

8.3 Design Calculations. Design calculations are a part of the design analysis. When they are voluminous, bind them separately from the narrative part of the design analysis. Present the design calculations in a clean and legible form incorporating a title page and index for each volume. Furnish a table of contents, which shall be an index of the indices, when there is more than one volume. Identify the source of loading conditions, supplementary sketches, graphs, formulae, and references. Explain all assumptions and conclusions. Calculation sheets shall carry the names or initials of the author and the checker and the dates of calculations and checking. No portion of the calculations shall be computed and checked by the same person.

8.4 Automatic Data Processing Systems (ADPS). When ADPS are used to perform design calculations, the design analysis shall include descriptions of the computer programs used and copies of the ADPS input data and output summaries. When the computer output is large, it may be divided into volumes at logical division points. Precede each set of computer printouts by an index and by a description of the computation performed. If several sets of computations are submitted, they shall be accompanied by a general table of contents in addition to the individual indices. Preparation of the description which must accompany each set of ADPS printouts shall include the following:

1. Explain the design method, including assumptions, theories, and formulae.
2. Include applicable diagrams, adequately identified.
3. State exactly the computation performed by the computer.
4. Provide all necessary explanations of the computer printout format, symbols, and abbreviations.
5. Use adequate and consistent notation.
6. Provide sufficient information to permit manual checks of the results.

## 9.0 DRAWINGS

9.1 Prepare all drawings on Computer-Aided Design and Drafting (CADD) so that they are well-arranged and placed for ready reference and so that they present complete information. The Contractor shall prepare the drawings with the expectation that the Corps of Engineers, in the role of supervision, will be able to construct the facility without any additional assistance from the Contractor. Drawings shall be complete, unnecessary work such as duplicate views, notes and lettering, and repetition of details shall not be permitted. Do not show standard details not applicable to the project, and minimize unnecessary wasted space. Do not include details of standard products or items which are adequately covered by specifications on the drawings. Detail the drawings such that conformance with the RFP can be checked and to the extent that shop drawings can be checked. Do not use shop drawings as design drawings. The design documents shall consist of drawings on a 36" x 24" format. The Contractor shall use standard Corps of Engineers title blocks and borders on all drawings. Submit an index of drawings with each submittal. The COR will furnish the Contractor file, drawing, and specification numbers for inclusion in the title blocks of the drawings.

9.2 Create all drawings using CADD methods in MicroStation or AutoCAD format. Save all Design Complete CADD files as MicroStation 5.0 and AutoCAD R2002. The Contractor shall use EM 1110-1-1807 Standards Manual for U.S. Army Corps of Engineers Computer-Aided Design and Drafting (CADD) Systems as guidance to for standard details, cell libraries, title blocks, and layer/level assignments. Drawing features not addressed in EM 1110-1-1807 shall conform to drafting standards.

9.3 Only standard fonts provided by MicroStation or AutoCAD are allowed to be used in the creation of CADD files. No fonts created by third parties or the designer are permitted.

9.4 The uses of Reference files and Xrefs during the design stage is up to the discretion of the designers. All CADD files at Design Complete submittal shall be free standing, independent files, and not supported by reference files. All Reference files (MicroStation) and all Xrefs files (AutoCAD) shall be removed at Design Complete submittal.

9.5 Submit all Design Complete CADD files on the following media.

- Read/Write CD-ROM Disk

## **10.0 SPECIFICATIONS**

10.1 The Contractor shall submit marked-up and final specifications as required. The specifications may be any one of the major, well known master guide specification sources such as MASTERSPEC from the American Institute of Architects, SPECTEXT from Construction Specification Institute or Corps of Engineers Guide Specifications, etc. Use only one source for the project. Edit the specifications for this project and submit in marked-up or redlined draft version at the Final Review submittal stage. If the design is based on a specific product, the specification shall consist of the important features of the product. The specification shall be detailed enough such that another product meeting the specification could be substituted and it would not adversely impact the project. After incorporation of comments, submit a final, design complete specification package. Delete all marked-out or redlined text and type in all inserted text.

10.2 Submittal Register. Develop the submittal requirements during construction during the design phase of the contract, by producing a Contractor Submittal Register during design. Attach a submittal register to each section of the specifications for the submittal requirements of that section. Prepare the Submittal Register on ENG Form 4288. The Contractor shall be responsible for listing all required submittals necessary to insure the project requirements are complied with. The Register shall identify submittal items such as shop drawings, manufacturer's literature, certificates of compliance, material samples, guarantees, test results, etc that the Contractor shall submit for review and/or approval action during the life of the construction contract. The Contractor shall place all the Submittal Register pages in an appendix of the final specifications.

## **11.0 CONTENTS OF DESIGN SUBMITTALS**

11.1 The First Site/Utility Design Submittal – 100% shall contain as a minimum, the following:

11.1.1 General Narratives:

11.1.1.1 Site/Layout: Explanation of objectives and factors influencing siting decisions. General overview of major site features planned, such as building orientation, drainage patterns, parking provisions, traffic circulation, provisions for the handicapped, security requirements, etc. Rationale for locating major site elements. Set back requirements or specific clearance requirements. Locations of borrow and spoil areas.

11.1.1.2 Utility Systems: Design narrative for the natural gas, water supply, storm drainage, and wastewater systems relating to this project. Include an analysis of the existing distribution systems capability to supply sufficient quantity at adequate levels. If the existing distribution systems are inadequate, provide the design solution to augment the systems to provide the requirements for the new facilities.

11.2 All drawings included in the required technical data for the proposal submission (see SECTION 00110A: PHASE 2 TECHNICAL SUBMISSION REQUIREMENTS AND INSTRUCTIONS), shall be developed to 100 percent completion. In addition to the individual utility plans, submit a combined utility plan drawn to the same scale as the individual utility plans.

11.2.1 General Site Layout: Scale shall be included.

11.2.2 Site Grading and Drainage Plans: Show locations of all sediment basins, diversion ditches, and other erosion control structures. Indicate the approximate drainage areas each will service. Indicate the materials, construction and capacity of each structure. Include limits of landscaping and seeded areas. General site grading and drainage shall be indicated by contour lines with an interval of not more than approximately 1 m [3 feet].

11.2.3 Road Alignment Plans: Scale shall be no greater than as indicated in SECTION 00110A: PHASE 2 TECHNICAL SUBMISSION REQUIREMENTS AND INSTRUCTIONS and profiles showing pavement and shoulder widths, azimuths and curve data, limits of grading, and erosion control. The materials to be used shall be indicated.

11.2.4 Traffic Control Plan: Traffic routing and signage shall be in accordance with The Manual on Uniform Traffic Control Devices for Streets and Highways, U.S. Department of Transportation, Federal Highways Administration.

11.2.5 Sanitary Sewer Plan: Scale shall be as indicated in SECTION 00110A: PHASE 2 TECHNICAL SUBMISSION REQUIREMENTS AND INSTRUCTIONS and profiles showing location and elevation of pipe, thrust blocks, manholes, etc. Materials and construction of main and appurtenances shall be indicated. Specifications shall be provided.

11.2.6 Water Supply Line Plans: Scale shall be as indicated in SECTION 00110A: PHASE 2 TECHNICAL SUBMISSION REQUIREMENTS AND INSTRUCTIONS and profiles showing locations of valves, thrust blocks, connections, etc. Materials shall be indicated and specifications shall be provided for valves, pipes, etc.

11.2.7 Electrical Plan Requirements:

11.1.7.1 Required diagrams and details on Site Electrical Drawings.

11.1.7.1.a. Off-Site Electrical Distribution Plan:

11.1.7.1.b. Off-Site Primary Circuit Routing Plans:

11.1.7.1.c. Off-Site One Line Diagram. (If applicable)

11.1.7.1.d. Off-Site Details. (Aerial Pole Line Construction, etc.) (If applicable).

11.1.7.1.e. On-Site Electrical Distribution Plan:

11.1.7.1.f. On-Site One Line Diagram.

11.1.7.1.g. On-Site Distribution Transformer Schedule: Provide with the following headings:  
Transformer Designation. Transformer Size (KVA). Building(s) Served.  
Primary Phase(s) and Circuit to which connected.

11.1.7.1.h. On-Site Details (Site Lighting, Trenching, Pad-Mounted Transformer, etc.).

11.1.8 Specifications: Provide final draft specifications which include all sections which apply to site/utility work.

11.1.9 Design Analysis: Design analysis shall include design calculations fully developed to support the design of the site and utility systems included in this submittal.

11.1.10 Geotechnical: Soils analysis and geotechnical report. Geotechnical information must be provided to support all assumptions and design parameters utilized in the presented site/utility design as applicable.

11.2 The Preliminary Conformance - 50% Building Design Submittal shall contain as a minimum, the following:

*[Design District shall delete the following paragraph where irrigation systems are not authorized or required.]*

11.2.1 Lawn and Landscaping Irrigation System: The design submittal shall include drawings clearly showing the piping layout and location of sprinkler heads coordinated with the landscaping plan, control valves, backflow preventers, rain check switches, controllers, etc. Indicate buildings, walks, shrubbery, trees, and other obstacles that might interfere with the proper operation of the sprinkler system. A design analysis calculating the pressures at each sprinkler head for the capacity and radius of throw is required. Details of the sprinkler head installation, valve boxes, and other irrigation appurtenances shall be submitted.

#### 11.2.2 Landscape, Planting and Turfing

11.2.2.1 The landscape planting design narrative shall describe the analysis of existing site conditions, including an indication of existing plant materials that are to remain on the site. The statement of concept shall indicate specific site problems related to proposed development and the rationale for proposed plant locations. The narrative shall also include a list of suggested types and sizes of plant materials which are to be used, based upon the designated functional and visual criteria.

11.2.2.2 The concept drawings shall be prepared at a scale which corresponds with the site layout and grading plans and, likewise, shall include reference coordinates, north arrows, graphic scales and appropriate legends. An overall planting layout shall be developed and shall include enlarged detail plans of specific areas, as needed, to clarify requirements. The proposed layout shall indicate shade trees, evergreen trees, flowering trees, shrub masses, etc., according to designated functional and visual locations of planting. A legend which also indicates sizes of plants recommended for each of the above categories shall be included. The drawings and all subsequent plans shall indicate existing and proposed buildings, paved areas, signs, light standards, transformers, dumpster areas, storm drainage system, and other structures and utilities.

#### 11.2.3 Architectural

11.2.3.1 Design narrative shall provide a summary of functional space relationships, as well as circulation. There shall also be a general statement for the rationale behind the major design decisions.

11.2.3.2 Architectural Floor Plans shall indicate dimensions, columns lines, and detail references. Toilets and other specialized areas shall be drawn to 1/4" scale and shall show any needed interior features.

11.2.3.3 Finish schedule shall indicate material, finishes, colors and any special interior design features such as soffits, fascias, and lighting troughs, etc.

11.2.3.4 All required equipment shall be shown on the drawings with an equipment list.

11.2.3.5 List any special graphics requirements that will be provided.

11.2.3.6 Schedules shall be provided for both doors and windows. These schedules shall indicate sizes, types, and details for all items shown on floor plans.

11.2.3.7 Hardware sets using BHMA designations.

11.2.3.8 Composite floor plan showing all prewired workstations. Also show typical elevations of each type of workstation.

11.2.3.9 SID package.

11.2.3.10 Fire Protection and Life Safety Analysis. This analysis must be performed by a Registered Fire Protection Engineer (FPE). NICET certification is not sufficient to address this requirement.

#### 11.2.4 Structural Systems

11.2.4.1 State the live loads to be used for design. Include roof and floor loads; wind loads, lateral earth pressure loads, seismic loads, etc., as applicable.

11.2.4.2 Describe the method of providing lateral stability for the structural system to meet seismic and wind load requirements. Include sufficient calculations to verify the adequacy of the method.

11.2.4.3 Furnish calculations for all principal roof, floor, and foundation members.

11.2.4.4 This submittal shall include drawings showing roof and floor framing plans as applicable. Principal members will be shown on the plans. A foundation plan shall also be furnished showing main footings and grade beams where applicable. Where beam, column, and footing schedules are used, show schedules and fill in sufficient items to indicate method to be used. Show typical bar bending diagram if applicable. Typical sections shall be furnished for roof, floor, and foundation conditions. Structural drawings for proposals and submittals shall be separate from architectural drawings.

11.2.4.5 Provide any computer analyses used shall be widely accepted, commercially available programs and complete documentation of the input and output of the program.

11.2.4.6 Provide complete seismic analyses for all building structural components. Seismic calculations shall clearly demonstrate compliance with all requirements set forth in the Statement of Work.

#### 11.2.5 Plumbing Systems

11.2.5.1 List all references used in the design including Government design documents and industry standards.

11.2.5.2 Provide justification and brief description of the types of plumbing fixtures, piping materials and equipment proposed for use.

11.2.5.3 Prepare detail calculations for systems such as sizing of domestic hot water heater and piping; natural gas piping; [lp gas piping and tanks] [fuel oil piping and tanks].

11.2.5.4. Indicate locations and general arrangement of plumbing fixtures and major equipment.

11.2.5.5 Include plan and isometric riser diagrams of all areas including hot water, cold water, waste and vent piping. Piping layouts and risers should also include natural gas (and meter as required), [LP gas], [fuel oil] and other specialty systems as applicable.

11.2.5.6 Include equipment and fixture connection schedules with descriptions, capacities, locations, connection sizes and other information as required.

#### 11.2.6 Fire Protection/Suppression

11.2.6.1 List all references used in the design including Government design documents and industry standards used to generate the fire protection analysis.

11.2.6.2 Classify each building in accordance with fire zone, building floor areas and height and number of stories. This information shall be contained in the fire protection analysis.

11.2.6.3 Discuss and provide description of required fire protection requirements including extinguishing equipment, detection equipment, alarm equipment [and water supply]. Alarm and detection equipment shall interface to requirements of Electronic Systems. This information shall be contained in the fire protection design analysis.

11.2.6.4 Prepare a plan for each floor of each building that presents a compendium of the total fire protection features being incorporated into the design. Provide the following types of information:

The location and rating of any fire-resistive construction such as occupancy separations, area separations, exterior walls, shaft enclosures, corridors, stair enclosures, exit passageways, etc.

The location and coverage of any fire detection systems.

The location and coverage of any fire suppression systems (sprinkler risers, standpipes, etc.).

The location of any other major fire protection equipment.

Indicate any hazardous areas and their classification.

11.2.6.5 Prepare a schedule describing the internal systems with the following information: fire hazard and occupancy classifications, building construction type, GPM/square foot sprinkler density, area of operation and other as required.

11.2.6.6 Hydraulic calculations based on water flow test shall be prepared for each sprinkler system to insure that flow and pressure requirements can be met with current water supply. Include copies of contractor water flow testing done to certify the available water source.

#### 11.2.7 Elevators

11.2.7.1 A list of criteria codes, documents and design conditions used. Reference to any authorized waiver of these criteria or codes.

11.2.7.2 Permits and Registration: Provide a list of all required permits and registrations for construction of items of special mechanical systems and equipment.

11.2.7.3 A description of the proposed control system.

11.2.7.4 Description, approximate capacity and location of any special mechanical equipment such as elevators, etc.

11.2.8 Electronic Systems: Electronic Systems responsibilities include the following:

Fire Detection and Alarm System  
Fire Suppression System Control  
Public Address System  
Telephone System  
Cable Television System  
Special Grounding Systems  
Cathodic Protection  
Intrusion Detection, Card Access System  
Central Control and Monitoring System

11.2.8.1 The design analysis shall include all calculations required to support design decisions and estimates at this stage of design. The analysis shall include specific criteria furnished, conference minutes and cost analyses of all systems considered.

11.2.8.2 Design of the fire alarm and detection system shall include layout drawings for all devices and a riser diagram showing the control panel, annunciator panel, all zones, radio transmitter and interfaces to other systems (HVAC, sprinkler, etc.).

11.2.8.3 Specify all components of the Fire Suppression (FS) System in the FS section of the specifications. Provide a clear description of how the system will operate and interact with other systems such as the fire alarm system. Include a riser diagram on the drawings showing principal components and interconnections with other systems. Include FS system components on drawing legend. All components shown on floor plans shall be designated as FS system components (as opposed to Fire Alarm components). Show the location of FS control panels, HVAC control devices, sensors, and 120V power panel connections on the floor plans. Indicate zoning of areas by numbers (1, 2, 3) and detectors subzoned for cross zoning by letter designations (A and B). Differentiate between ceiling mounted and underfloor detectors with distinct symbols and indicate subzone of each.

11.2.8.4 Show location of telephone outlets (including pay phones) on the plans. Include legend and symbol definition to indicate height above finished floor. Show Telephone Conduit System Riser Diagram. Size conduit on Riser Diagram. Do not show conduit runs between backboard and outlets on the floor plans. Underground telephone distribution conduit shall be shown on either the electrical or electronic site plan.

11.2.8.5 Grounding System. The specifications and drawings shall completely reflect all of the design requirements. The specifications shall require field tests (in the construction phase), witnessed by the Contracting Officer, to determine the effectiveness of the grounding system. The design shall include drawings showing existing construction. Verification of the validity of any existing drawings and/or any other data furnished by the Government shall be the responsibility of the engineering services firm.

11.2.8.6 Provide a statement describing the extent of any exterior work such as telephone lines, cable television (TV) distribution cables, duct banks, etc., outside of 5 feet from the building line.

11.2.8.7 Provide the name of the licensed corrosion engineer or NACE specialist. Provide the following for cathodic protection systems:

Clearly define areas of structures or components in soil or water to be protected.  
Type system recommended, comparison of systems, cost estimates showing all equipment alternatives.

Calculations on all systems that are considered showing all information and descriptions.

11.2.8.7.1 Design of Cathodic Protection. The design shall clearly provide a thorough and comprehensive specification and drawing. The design plans and specifications shall show extent of the facilities to be protected, location and type of anodes, location of test points, details for sectionalizing an underground piping system. This design shall be complete enough to purchase equipment and build without design changes to meet criteria of protection.

11.2.8.8 Exterior work to be shown on electrical site plan.

Existing and new communications service lines, both overhead and underground, shall be properly identified.

Show removals and relocations, if any.

11.2.8.9 Provide a descriptive narrative of all electronic systems that are required for project. Define any hazardous areas (as defined in the National Electric Code) and indicate the type of equipment proposed for use in such areas. Show the location of all electronic system panels, etc., on the floor plans. Show the proposed riser diagrams for all systems. Sizes of all conduit, wires, cables, panels, etc. Provide a complete symbol legend for all devices or equipment shown on the plans. For work requiring removals or demolition, the designer shall show by use of drawings or narrative, how demolition work is to be done.

11.2.9 Electrical and Mechanical Systems: Provide all information as required on the 100% design submittal developed to 50% completion.

11.2.10 Specifications: Draft of specifications for housing units, including index and trade sections.

11.3 The Final Design - 100% Building Submittal shall contain, as a minimum, the following items for all submittals:

11.3.1 General: A complete set of construction documents plans and specifications at the same level of detail as if the project were to be bid including a complete list of equipment, fixtures and materials to be used. The final drawings are an extension of the reviewed 50% drawings and are to include the 50% comments and responses. All details shall be shown on the drawings.

11.3.2 The design analysis is an extension of the reviewed 50% design analysis and supports and verifies that the design complies with the requirements of the project.

11.3.3 Submit marked-up specifications. The specifications shall be coordinated with the drawings and describe in detail all items shown on the drawings.

11.3.4 Landscape, Planting and Turfing Final design drawing(s) shall include a complete schedule of plant materials which indicates their botanical and common names, plan symbols, quantities, sizes, condition furnished, and pertinent remarks. Scale of drawing shall be prepared at 1" = 30'. Drawing shall correspond with the site layout and grading plans and reference coordinates, north arrows, graphic scales and appropriate legends. An overall planting layout shall be developed and shall include enlarged detail plans of specific areas as needed, to clarify requirements. Final design drawings, indicating proposed plants by a (+) mark for the plant location and a circle which is scaled at approximately 2/3 the ultimate growth spread (diameter) of plants, shall also include a complete schedule of plant materials which indicates botanical and common names, plan symbols, quantities, sizes, condition furnished, and pertinent remarks. Final drawings shall also include the basic details for installation of tree, shrub, and ground cover planting, as well as any other applicable details for clarification of specific project requirements.

11.3.5 Architectural

11.3.5.1 All architectural drawings shall be coordinated with the other engineering disciplines. Ensure that the plans are in compliance with the applicable codes. It will be the Contractor's responsibility to implement the comments generated from any design review submittal as well as verify the consistency between plans and specification. The evaluation of the Contractor's submittals shall be based on degree to which the submittal meet the requirements set forth in this document and the specifications.

11.3.5.2 Prewired workstation composite floor plans. Prewired workstation typicals - elevations and component inventory. Prewired workstation panel identification plan with electrical outlet placement including base feed.

11.3.5.3 SID package.

11.3.5.4 Fire Protection and Life Safety Analysis. This analysis must be performed by a Registered Fire Protection Engineer (FPE). NICET certification is not sufficient to address this requirement.

11.3.6 Structural Design

11.3.6.1 Furnish complete checked calculations for all structural members. Incorporate any changes required by comments on 50% Design Submittal.

11.3.6.2 Prior to this submittal, structural drawings shall be coordinated with all other design disciplines.

11.3.6.3 The final structural drawings shall contain the following information as a set of general notes:

- The allowable soil bearing value.
- The design stresses of structural materials used.
- The design live loads used in the design of various portions of the structures.
- The design wind speed.
- The seismic zone and the "K", "C", "I" and "Z" values used in design.

11.3.6.4 All structural drawings and calculations shall be checked and stamped by the designer of record (a registered Professional Engineer).

[11.3.7 Fire Suppression System: Provide a file of the input data used in the computer program to design the fire suppression system as well as the output data.]

11.3.8 Specific Mechanical and Plumbing Requirements:

11.3.8.1 Required Plans, Diagrams, Schedules and Details on Unit Mechanical Drawings:

11.3.8.1.1. Mechanical Floor Plan: The floor plans shall show all principle architectural features of the building which will affect the mechanical design. The floor plans shall also show the following:

- Room designations.
- Mechanical legend and applicable notes.
- Location of all ductwork or piping (double line ductwork required).
- Location and capacity of all terminal units (i.e., registers, diffusers, grilles, hydronic baseboards).
- Exhaust fan and range hood location.
- Size of all ductwork and piping.
- Thermostat location.
- Location of heating/cooling plant (i.e., boiler, chiller, cooling tower, etc).
- Location of all air handling equipment.
- Return air paths (i.e., undercut doors, transfer grilles).
- Flue piping size and location.
- Piping diagram for forced hot water system (if used).
- Fuel supply and return piping

11.3.8.1.2. Equipment Schedule: Complete equipment Schedules shall be provided. Schedule shall also include:

- Capacity
- Electrical characteristics
- Efficiency (if applicable)
- Manufacturer's name
- Optional features to be provided
- Physical size

11.3.8.1.3 Details: Construction details, sections, elevations, etc., shall be provided where required for clarification of methods and materials of design. Roof and exterior wall penetrations shall be detailed on the drawings.

11.3.8.2 Plumbing Floor Plan: The floor plan shall show all principal architectural features of the building which will affect the plumbing design. Separate plumbing plans will not be required if sufficient information can be shown on the mechanical plans to meet the requirements shown above. The floor plan shall also show the following:

- Room designations.

Fixture Schedule.  
Location of utility entrances.  
Waste and water pipe location and size.  
Fixture designations.

11.3.8.3 Design Analysis: Complete design calculations for mechanical systems. Include computations for sizing PM&E equipment, air duct design, and U-factors for ceilings, roofs and exterior walls and floors. Contractor shall employ commercially available energy analysis techniques to determine the energy performance of all passive systems and features. Use of hourly energy load computer simulation (e.g., TRNSYS, DOE 2.1 Blast, etc.) is required. These calculations can be used to size the mechanical systems. Based on the results of calculations, provide a complete list of the materials and equipment proposed for heating and plumbing, with the manufacturer's published cataloged product installation specifications and roughing-in data. The heating and cooling equipment data shall include the manufacturer's wiring diagrams, installation specifications, ARI certification, and the standard warranty for the equipment.

#### 11.3.9 Specific Electrical Requirements:

##### 11.3.9.1 Required Plans, Diagrams, Schedules, and Details on Unit Electrical Drawings:

11.3.9.1.1. Electrical Floor Plan. The floor plans shall show all principle architectural features of the building which will affect the electrical design. The floor plan shall also show the following:

- Room designations.
- Electrical legend and applicable notes.
- Lighting fixtures, properly identified.
- Location of smoke and CO detectors.
- Location of telephone and cable TV outlets.
- Switches for control of lighting.
- Receptacles.
- Location and designation of panelboards. Plans should clearly indicate type of mounting required (flush or surface) and be reflected accordingly in specifications. Service entrance (conduit and main disconnect).
- Location, designation and rating of motors and/or equipment which requires electrical service. Show method of termination and/or connection to motors and/or equipment. Show necessary junction boxes, disconnects, controllers (approximate only), conduit stubs, and receptacles required to serve the motor and/or equipment.

11.3.9.1.2. Building Riser Diagram (from pad-mounted transformer to unit load center panelboard): Indicate the types and sizes of electrical equipment and wiring. Include grounding and metering requirements.

11.3.9.1.3. Load Center Panelboard Schedule(s): Schedule shall indicate the following information:

- Panelboard Characteristics (Panel Designation, Voltage, Phase, Wires, Main Breaker Rating and Mounting).
- Branch Circuit Designations.
- Load Designations.
- Circuit Breaker Characteristics. (Number of Poles, Trip Rating, AIC Rating)
- Branch Circuit Connected Loads (AMPS).
- Special Features.

11.3.9.1.4 Lighting Fixture Schedule: (Schedule shall indicate the following information:)

- Fixture Designation.
- General Fixture Description.

Number and Type of Lamp(s).  
Type of Mounting.  
Special Features.

11.3.9.1.5. Details: Construction details, sections, elevations, etc., shall be provided where required for clarification of methods and materials of design.

11.3.9.2. Required Electrical Design Analysis: Design analysis and calculations for the electrical systems shall be prepared by a licensed professional engineer with experience in family housing, and shall be stamped as such. The design analysis shall be separately bound, in one or more volumes. Show functional and engineering criteria, design information, and calculations applicable to the project. The analysis shall be organized in a format appropriate for review, approval, and record purposes. The design calculations shall indicate methods and references identified, and shall explain assumptions and conclusions.

11.3.9.2.1. Voltage Drop (VD) Calculations: Select conductor sizes of primary feeders, site lighting circuits, service laterals, and unit feeder conductors. Calculate maximum length for each phase of each primary circuit, using a maximum allowable VD for each circuit. Calculate voltage drops for each conductor. Maximum allowable voltage drop for site lighting and service laterals is 3%. The combined voltage drop for the service laterals, unit feeders, and branch circuit cannot exceed 5%. Calculate the available fault current at the main breaker for the living unit panel. Provide a coordination study to support breaker selection.

11.3.10 Specifications: Provide final specifications. The Contractor shall make final identification of all materials and finishes at this stage.

11.4 Design complete submittal:

11.4.1 Design Drawings: Drawings shall be 100% complete, signed and sealed by the designer of record. All previous review comments shall be incorporated.

11.4.2 Design Analysis: Complete design analysis for all design disciplines. The final Fire Protection and Life Safety Analysis shall be included in the Design Analysis.

11.4.3 Comment Response Package: Complete package showing all comments from all previous reviews and the respective response and disposition.

11.4.4 This submittal shall include all drawings and design information from the 100% site/utility and 100% building design submittal to form a complete design package.

## **12.0 DESIGN RELATED PRODUCTS**

12.1 Architectural Renderings: Contractor shall provide the original and three copies of each ground level perspective artist's renderings of completed typical facilities with walks, parking, and landscaping. Renderings shall be no smaller than 14" x 18" or larger than 28" x 36", multi-colored, and shall be suitably titled, matted, and framed.

12.2 DD Form 1354: Three (3) sets of DD Form 1354, Transfer and Acceptance of Military Real Property shall be prepared in accordance with ER 415-345-38 and submitted to the Contracting Officer. Copies of Form 1354 and ER 415-345-38 will be furnished to the successful contractor following award of the project.

12.3 Submittal Register, ENG FORM 4288: The Contractor shall complete and submit three (03) copies of a "preliminary" Eng Form 4288, Submittal Register to Contracting Officer. The "preliminary" Eng Form 4288, Submittal Register shall have the column "Submittal Identification", "Specification Paragraph Number", "Description of Submittal" "Type of Submittal", and "Remarks" completed; the

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

Contractor shall identify whether the submittal is for "Government Approval" or for "Government Information" under the column "Remarks." The "final" Eng Form 4288, Submittal Register, shall be in accordance with clause CONTRACTOR SUBMITTALS AND SUBMITTAL CONTROL in this section.

12.4 Reproduction: Upon Government approval of 100% design documents, the original will be returned to the Contractor for reproduction purposes. The Contractor will be responsible for his own reproduction as well as reproduction for Government use. The Government will require twice the number of copies of the plans and specifications as were required for the review stages, no color boards will be required. The originals will be retained by the Contractor for recording of as-built conditions. Upon completion of the project, the original design documents corrected to reflect as-built conditions will be supplied to the Government.

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**ATTACHMENT 2**

**RESERVED**

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**ATTACHMENT 3**

**RESERVED**

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**ATTACHMENT 4**

**Reserved**

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**ATTACHMENT 5**  
**PROPOSAL DRAWING FORMAT**

**ATTACHMENT 5**  
**PROPOSAL DRAWING FORMAT**

NOTE TO USACE DESIGN ACTIVITY: TECHNICAL SUBMISSION REQUIREMENTS AND INSTRUCTIONS are stated in Section 00110A. Inclusion of additional drawing format standards in the RFP is optional. If this attachment is used, it should be coordinated with Section 00110A.

**1. POLICY.**

Drawings shall be prepared in accordance with Section 00110A, PHASE 2 TECHNICAL SUBMISSION REQUIREMENTS AND INSTRUCTIONS, and the following instructions on graphic format.

**2. DRAFTING.**

a. The drawings shall show sufficient detail so that they clearly delineate the proposed construction. Original drawings shall be made on size standard size A1 [approximately 594mm x 841mm, 23 1/2" x 33"] sheets, and CADD format as defined by the design agent. The final proposal submittal of drawings shall also be in CADD format on A1 standard full size sheets. The revision block and title block shall be as provided by the design agent. Design agent may request offerors to provide proposal drawings in half-size format. [Insert Revision Block and Title Block Example at end of this attachment.]

b. The first or cover sheet shall contain the title and location of the project and the Drawing Index.

c. The drawing layout will be evaluated with care before the beginning of the drafting. Ample space, without crowding, will be provided, not only for the required plans and details with all necessary titles, dimensions and notes, but also for incidental information required, such as graphic scales, general and reference notes, schedules, North Arrow, etc.

d. Sheets shall be well ordered and drawn at the scales indicated in Section 00110A. Any drawings not specifically listed shall be drawn at a reasonable scale and suitable for reduction. Cluttered and overcrowded layouts shall be avoided.

e. A graphic scale for each of the different scales used on a drawing shall be placed on the particular drawing to the left of the title block. Scale shall be indicated at each plan, elevation, section, and detail, unless all drawings on the same are at the same scale. No scale larger than 1:2 shall be used without prior approval.

f. Sheets devoted to details should have such details reasonably spaced and arranged left to right or top to bottom. Groups of details relating to one particular aspect should be adequately separated from other groups and identified with a title. Sections and details of the final design should be numerous enough to show all design features.

g. Unnecessary details or details of small standard products or items which are adequately covered by specifications and/or catalogs shall not be included on the drawings.

h. A symbol for major disciplines should be selected to properly arrange the sheets in the package. Adequate cross-referencing must be shown to avoid confusion and misunderstanding between disciplines.

**3. DRAWING PREPARATION.**

- a. Preparation for Size Reduction. Since drawings will be reduced, all drafting (line widths, spacing, lettering sizes, etc.) shall be adequate size and density to be easily legible after reduction.
- b. Scales. Carefully plan drawing layout together with suitable scales in advance to properly delineate the project. Similar work for all design disciplines shall, whenever possible, be shown at the same scale on the various drawings involved.
- c. Lettering. Use single stroke lettering, all capitals. Minimum height shall be 5/32".
- d. Sheet Reference. The proposer will reference all drawings within a discipline of work. The divisions designated below will be utilized.

Discipline Designation	Design Discipline
T	Title, Location Map, & General Notes
L	Site Planning, Landscaping Planting and Children's Outdoor Play Areas
C	Civil Engineering
A	Architecture
S	Structural Engineering
M	Mechanical Engineering
E	Electrical Engineering
G	Geotechnical Engineering

- e. Drawing Designation. Each drawing in the particular division shall be designated by the discipline designation and sheet number (i.e., E-6 is the sixth electrical drawing.) This system as listed will be used in establishing sequence of drawings. The notation system shall be placed in the last increment of the drawing number block entitled "sheet."
- f. Ring Number. Consecutive ring numbering shall begin with the cover sheet. Ring number shall be placed in a circle directly below "Sheet" block of the Title Block. Sheets inserted after ring numbers have been finalized shall be designated with the ring number of the original sheet preceding it and an alpha from A to Z beginning with A (i.e., ring 32A follows ring 32).
- g. Cross Reference. Cross-referencing for sections and details shall be based on the sheet reference number.
- h. Symbols and Conventions. Symbols and conventions serve two main purposes. One is to simplify the drawing and improve comprehension; the other is to follow or establish a standard which is easily recognized. Symbols shall be the standards used by the various disciplines.
- ii. Legends. Place legends of symbols and material indications on the drawings. Since many symbols are limited to certain design disciplines, use separate symbol legends on the initial sheet of each design discipline. Symbols in the legend shall be at the same scale or slightly larger than used on the drawings.

## **ATTACHMENT 6**

### **SITE AND LOCALITY MAPS**

USACE Design District shall include general site and locality maps in this attachment for information purposes. Maps included in this attachment are not meant to provide driving directions for potential contractors.

Project Name

Project No. \_\_\_\_\_  
UFC 4-721-11.1, UEPH Complexes, 26 Nov 01

**ATTACHMENT 7**  
**PROJECT AND SAFETY SIGNS**

USACE Design Activity to include the size and design requirements for the project and safety signs.

**ATTACHMENT 8**  
**GEOTECHNICAL REPORT**

11\ USACE Design District shall include in this attachment the geotechnical report for the proposed construction site. This report should include boring logs, a site map identifying bore hole locations, and an engineering analysis of the soils information which makes recommendations and conclusions with respect to the suitability of the existing site soils to support the proposed project. Investigations should be performed to a level which assures adequate information to determine the general type of structure best suited to the site conditions and sufficient to ascertain the costs of the project. See Statement of Work paragraph 4-1.1 for suggested report content suitable for general type structure best suited for the site conditions.

If the USACE Design District Geotechnical Engineer feels that the site conditions warrant specific mandatory requirements for a particular project, those requirements must be included in the Statement of Work as well as included in this appendix. /1/

## **ATTACHMENT 9**

### **EXCERPTS FROM THE INSTALLATION DESIGN GUIDE**

USACE Design District shall obtain from the Installation copies of the Installation Design Guide (IDG). PA/PE shall thoroughly review the IDG with the Installation Project Manager and identify all areas of the IDG which could apply to the construction of the new UEPH Facilities. Those pieces of the DG shall be included in the solicitation in this attachment for review, use, and consideration by the contractor.

Complete copies of the IDG inserted in this attachment is discouraged as it will add volume to the solicitation with little additional value added to the project.

**ATTACHMENT 10****FIRE FLOW DATA**

11 The Activity preparing the RFP shall address the adequacy of the existing water supply to meet the demands of the fire protection system required. The Activity preparing the RFP shall perform or witness the required water flow testing and verify that test results are accurate. Flow testing shall be conducted at or near the point of connection to the existing water main. Accepting historical water supply information without verification is not acceptable. The Activity preparing the RFP shall perform a preliminary hydraulic analysis to determine if the existing water supply is adequate to meet the demand, or if a fire pump and water storage tank is needed. Information shown below must be completed by the RFP preparing Activity. *11/*

**ATTACHMENT 11**  
**LIST OF DRAWINGS**

USACE Design District shall include a list of all informational drawings provided as part of the solicitation. Typical drawings include topographic surveys of the proposed site as well as utilities information and proposed tap points for the utilities to serve the new housing development.

## **ATTACHMENT 12**

### **ASBESTOS AND LEAD PAINT SURVEY RESULTS**

If the project includes the demolition of existing structures, the provision of the asbestos and lead survey and testing results is imperative to the success of the project. USACE Design District must include this information in the solicitation.

Typically the Installation can provide this information for inclusion in the solicitation, if this information is not available from the Installation, the Design District shall have these surveys conducted and completed during the development of the solicitation.